

Result of Nuclide Analysis of Radioactive Materials in the Air  
at the Site of Fukushima Nuclear Power Stations

Reference

(data summarised on June 3)

Place of sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm <sup>3</sup> ) <sup>2</sup>
	Date and time of sampling	June 2, 2011 11:30 am - 11:50 am	Date and time of sampling	June 2, 2011 9:04 am - 9:13 am	Date and time of sampling	June 2, 2011 3:15 pm - 3:24 pm	
Detected nuclide (half-life)	Radioactivity density <sup>1</sup> (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Radioactivity density <sup>1</sup> (Bq/cm <sup>3</sup> )	Scaling factor ( / )	Radioactivity density <sup>1</sup> (Bq/cm <sup>3</sup> )	Scaling factor ( / )	
I-131 (approx. 8 days)	1.6E-06	0.00	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	9.0E-06	0.00	1.3E-05	0.01	1.4E-05	0.01	2E-03
Cs-137 (approx. 30 years)	9.8E-06	0.00	1.0E-05	0.00	1.5E-05	0.01	3E-03

1 The value of Radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density

. E - means . x 10<sup>-</sup>

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.