

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 4)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/6/3 11:55	2011/6/3 12:00	2011/6/3 12:05	2011/6/3 11:50	2011/6/3 11:45	2011/6/3 11:40	2011/6/3 14:13
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	1.6E+00	1.8E+00	1.7E+00	2.3E-01	ND	ND	ND
Cs-134 (about 2 years)	2.7E+01	9.6E+00	8.7E-01	1.6E-01	ND	ND	ND
Cs-137 (about 30 years)	3.3E+01	1.2E+01	9.5E-01	1.7E-01	ND	ND	ND

. E - means . x10.

Data of other nuclides are under evaluation.

ND: when the detected amount is below the detection limit in this analysis (I-131: approx. 9E-3Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 2E-2Bq/cm³)