

Results of Nuclide Analysis of Seawater <Coast>

Reference

(Data summarized on June 5)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)				Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)				Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		② Density limit by the announcement of Reactor Regulation (Bq/cm ³) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and Date of Sample Collection	9:20 June 4, 2011		14:00 June 4, 2011		9:00 June 4, 2011		13:40 June 4, 2011		9:30 June 4, 2011		8:05 June 4, 2011	
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	33	0.55	110	1.8	26	0.43	73	1.2	ND	-	ND	-	60
Cs-137 (about 30 years)	29	0.32	120	1.3	33	0.37	76	0.84	18	0.20	20	0.22	90

※ Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L

※ Data of other nuclides are under evaluation.

※ In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

※ In the case that the data is below measurable limit (approximately 6Bq/L for I-131, approximately 14Bq/L for Cs-134), "ND" is stated.