

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 7)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/6/6 11:50	2011/6/6 11:55	2011/6/6 12:00	2011/6/6 11:45	2011/6/6 11:45	2011/6/6 11:40	2011/6/6 9:02
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	2.1E+00	1.5E+00	1.3E+00	1.2E-01	ND	ND	ND
Cs-134 (about 2 years)	2.5E+01	1.1E+01	6.2E-01	9.9E-02	8.5E-03	1.1E-02	ND
Cs-137 (about 30 years)	3.0E+01	1.3E+01	6.8E-01	1.2E-01	1.5E-02	9.4E-03	ND

. E - means . ×10.

Data of other nuclides are under evaluation.

ND: when the detected amount is below the detection limit in this analysis (I-131: approx. 5E-3Bq/cm³ Cs-134: approx. 7E-2Bq/cm³ Cs-137: approx. 7E-2Bq/cm³)