

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason | |
|------|-----------|--------------|-----------------|-----------------|-----------------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|-----------------|-----------------|
| 3/11 | 17:00 | Gym Hall | 47 nSv/h | - | - | - | - | ○ | | | | | Sec Team unsent | |
| | 17:00 | Gym Hall | 41 nSv/h | - | - | - | - | ○ | | | | | Sec Team unsent | |
| | 17:20 | Gym Hall | 54 nSv/h | - | - | - | - | ○ | | | | | Sec Team unsent | |
| | 17:30 | Gym Hall | 49 nSv/h | - | - | - | - | | | | | | | |
| | 17:40 | Main Gate | 56 nSv/h | - | - | - | - | | | | | | | |
| | 17:49 | Main Gate | 56 nSv/h | - | - | - | - | | ○ | | | | HQ not received | |
| | 17:50 | Admin. Build | 64 nSv/h | - | - | - | - | | | | | | | |
| | 18:00 | Admin. Build | 63 nSv/h | - | - | - | - | ○ | | | | | | Sec Team unsent |
| | 18:10 | Admin. Build | 65 nSv/h | - | - | - | - | ○ | | | | | | Sec Team unsent |
| | 18:35 | Admin. Build | 55 nSv/h | - | - | - | - | ○ | | | | | | Sec Team unsent |
| | 18:45 | MP-6 | 56 nSv/h | - | - | - | - | | | | | | | |
| | 19:00 | MP-7 | 57 nSv/h | - | - | - | - | | | | | | | |
| | 19:10 | MP-5 | 55 nSv/h | - | - | - | - | | | | | | | |
| | 19:15 | MP-4 | 59 nSv/h | - | - | - | - | | | | | | | |
| | 19:20 | MP-3 | 59 nSv/h | - | - | - | - | | | | | | | |
| | 19:45 | Main Gate | 57 nSv/h | - | - | NW | 2.8 | | ○ | | | | | HQ not received |
| | 19:52 | Main Gate | 57 nSv/h | - | - | - | - | | | | | | | |
| | 20:00 | Main Gate | 60 nSv/h | - | - | - | - | | | | | | | |
| | 20:10 | Main Gate | 59 nSv/h | - | - | - | - | | | | | | | |
| | 20:20 | Main Gate | 67 nSv/h | - | - | - | - | | | | | | | |
| | 20:35 | Main Gate | 67 nSv/h | below 0.01μSv/h | - | E | 0.4 | | ○ | | | | | HQ not received |
| | 20:45 | Main Gate | 61 nSv/h | - | - | NE | 0.4 | | ○ | | | | | HQ not received |
| | 21:00 | Main Gate | 60 nSv/h | - | - | NW | 0.4 | | ○ | | | | | HQ not received |
| | 21:15 | Main Gate | 64 nSv/h | - | - | SW | 0.5 | | ○ | | | | | HQ not received |
| | 21:30 | Main Gate | 62 nSv/h | below 0.01μSv/h | - | NE | 0.4 | | | | | | | |
| | 21:40 | Main Gate | 61 nSv/h | below 0.01μSv/h | - | NW | 0.5 | | | | | | | |
| | 21:50 | Main Gate | 61 nSv/h | below 0.01μSv/h | - | ENE | 0.4 | | | | | | | |
| | 22:00 | Main Gate | 59 nSv/h | below 0.01μSv/h | - | N | 0.4 | | | | | | | |
| | 22:10 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | ENE | 0.6 | | | | | | | |
| | 22:20 | Main Gate | 62 nSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | | |
| | 22:30 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | NNW | 0.5 | | | | | | | |
| | 22:40 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | N | 0.6 | | | | | | | |
| | 22:50 | Main Gate | 59 nSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | | |
| | 23:00 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | N | 0.8 | | | | | | | |
| | 23:10 | Main Gate | 63 nSv/h | below 0.01μSv/h | - | WNW | 0.4 | | | | | | | |
| | 23:20 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | | |
| | 23:30 | Main Gate | 61 nSv/h | below 0.01μSv/h | - | N | 0.2 | | ○ | | | | | HQ not received |
| | 23:40 | Main Gate | 63 nSv/h | below 0.01μSv/h | - | N | 0.4 | | | | | | | |
| | 23:50 | Main Gate | 59 nSv/h | below 0.01μSv/h | - | NNE | 0.4 | | | | | | | |
| | 3/12 | 0:00 | Main Gate | 60 nSv/h | below 0.01μSv/h | - | SE | 0.5 | | | | | | |
| 0:10 | | Main Gate | 62 nSv/h | below 0.01μSv/h | - | NE | 2.0 | | | | | | | |
| 0:20 | | Main Gate | 65 nSv/h | below 0.01μSv/h | - | NE | 1.8 | | | | | | | |
| 0:30 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | ENE | 0.9 | | | | | | | |
| 0:40 | | Main Gate | 63 nSv/h | below 0.01μSv/h | - | ENE | 1.1 | | | | | | | |
| 0:50 | | Main Gate | 63 nSv/h | below 0.01μSv/h | - | WSW | 1.4 | | ○ | | | | | HQ not received |
| 1:00 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | NW | 1.3 | | ○ | | | | | HQ not received |
| 1:10 | | Main Gate | 68 nSv/h | below 0.01μSv/h | - | N | 1.4 | | ○ | | | | | HQ not received |
| 1:20 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | NNW | 1.5 | | ○ | | | | | HQ not received |
| 1:30 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | W | 1.4 | | ○ | | | | | HQ not received |
| 1:40 | | Main Gate | 68 nSv/h | below 0.01μSv/h | - | NNW | 0.6 | | | | | | | |
| 1:50 | | Main Gate | 66 nSv/h | below 0.01μSv/h | - | WSW | 0.8 | | | | | | | |
| 2:00 | | Main Gate | 68 nSv/h | below 0.01μSv/h | - | SW | 0.7 | | | | | | | |
| 2:10 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | WSW | 0.7 | | | | | | | |
| 2:20 | | Main Gate | 67 nSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | | |
| 2:30 | | Main Gate | 65 nSv/h | below 0.01μSv/h | - | NNW | 0.9 | | | | | | | |
| 2:40 | | Main Gate | 66 nSv/h | below 0.01μSv/h | - | NNW | 1.4 | | | | | | | |
| 2:50 | | Main Gate | 65 nSv/h | below 0.01μSv/h | - | NNW | 2.0 | | | | | | | |
| 3:00 | | Main Gate | 69 nSv/h | below 0.01μSv/h | - | NW | 1.7 | | | | | | | |
| 3:10 | | Main Gate | 66 nSv/h | below 0.01μSv/h | - | W | 0.9 | | | | | | | |
| 3:20 | | Main Gate | 69 nSv/h | below 0.01μSv/h | - | W | 1.0 | | | | | | | |
| 3:30 | | Main Gate | 68 nSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | | |
| 3:34 | | MP-8 | 70 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 3:40 | | MP-8 | 80 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 3:40 | | Main Gate | 66 nSv/h | below 0.01μSv/h | - | WSW | 0.5 | | | | | | | |
| 3:50 | | MP-8 | 70 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 3:50 | | Main Gate | 64 nSv/h | below 0.01μSv/h | - | NNW | 0.4 | | | | | | | |
| 4:00 | | MP-8 | 70 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:00 | | Main Gate | 69 nSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | | |
| 4:04 | | MP-8 | 130 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:05 | | Main Gate | 160 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:10 | | MP-8 | 190 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:10 | | Main Gate | 289 nSv/h | below 0.01μSv/h | - | W | 0.6 | | ○ | | | | | HQ not received |
| 4:15 | | MP-8 | 230 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:20 | | MP-8 | 280 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:20 | | Main Gate | 525 nSv/h | below 0.01μSv/h | - | WSW | 0.5 | | ○ | | | | | HQ not received |
| 4:23 | | Main Gate | 590 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:25 | | MP-8 | 310 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:30 | | MP-8 | 340 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:35 | | MP-8 | 380 nSv/h | - | - | - | - | | ○ | | | | | HQ not received |
| 4:40 | Main Gate | 866 nSv/h | - | - | - | - | | | | | | | | |
| 4:45 | MP-8 | 430 nSv/h | - | - | - | - | | ○ | | | | | HQ not received | |
| 4:50 | Main Gate | 1002 nSv/h | - | - | - | - | | | | | | | | |
| 4:55 | MP-8 | 570 nSv/h | - | - | - | - | | ○ | | | | | HQ not received | |
| 5:00 | MP-8 | 880 nSv/h | - | - | - | - | | ○ | | | | | HQ not received | |
| 5:00 | Main Gate | 1307 nSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | | | |
| 5:05 | MP-8 | 1430 nSv/h | - | - | - | - | | ○ | | | | | HQ not received | |
| 5:10 | MP-8 | 1800 nSv/h | - | - | - | - | | ○ | | | | | HQ not received | |
| 5:10 | Main Gate | 1590 nSv/h | below 0.01μSv/h | - | ENE | 0.5 | | | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-----------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 5:15 | MP-8 | 1.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:20 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:20 | Main Gate | 1.8 μSv/h | below 0.01μSv/h | - | SW | 0.5 | | ○ | | | | HQ not received |
| | 5:25 | MP-8 | 3.8 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:30 | MP-8 | 4.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:30 | Main Gate | 1.3 μSv/h | below 0.01μSv/h | - | SW | 0.9 | | ○ | | | | HQ not received |
| | 5:35 | MP-8 | 2.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:40 | MP-8 | 2.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:40 | Main Gate | 1.2 μSv/h | below 0.01μSv/h | - | W | 0.9 | | ○ | | | | HQ not received |
| | 5:45 | MP-8 | 1.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:50 | MP-8 | 1.3 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 5:50 | Main Gate | 1.2 μSv/h | below 0.01μSv/h | - | WSW | 0.4 | | ○ | | | | HQ not received |
| | 5:55 | MP-8 | 2.3 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:00 | MP-8 | 3.1 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:00 | Main Gate | 1.2 μSv/h | below 0.01μSv/h | - | W | 0.5 | | ○ | | | | HQ not received |
| | 6:05 | MP-8 | 1.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:10 | MP-8 | 1.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:10 | Main Gate | 2.1 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | ○ | | | | HQ not received |
| | 6:15 | MP-8 | 0.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:20 | MP-8 | 1.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:25 | MP-8 | 1.2 μSv/h | - | - | - | - | | | | | | |
| | 6:30 | MP-8 | 1.5 μSv/h | - | - | - | - | | | | | | |
| | 6:30 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | WSW | 0.2 | | | | | | |
| | 6:35 | MP-8 | 2.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:40 | MP-8 | 2.2 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:40 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 6:45 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:50 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 6:50 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | W | 0.4 | | ○ | | | | HQ not received |
| | 6:55 | MP-8 | 2.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 7:00 | MP-8 | 2.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 7:00 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | W | 0.4 | | ○ | | | | HQ not received |
| | 7:05 | MP-8 | 2.6 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 7:10 | MP-8 | 2.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 7:10 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | W | 0.4 | | ○ | | | | HQ not received |
| | 7:15 | MP-8 | 2.5 μSv/h | - | - | - | - | ○ | | | | | Sec Team unsent |
| | 7:20 | MP-8 | 2.5 μSv/h | - | - | - | - | ○ | | | | | Sec Team unsent |
| | 7:20 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | SW | 0.4 | | ○ | | | | HQ not received |
| | 7:25 | MP-8 | 2.3 μSv/h | - | - | - | - | ○ | | | | | Sec Team unsent |
| | 7:30 | MP-8 | 2.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 7:30 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | Fine | SW | 0.4 | | ○ | | | | HQ not received |
| | 7:35 | MP-8 | 2.5 μSv/h | - | - | - | - | | | | | | |
| | 7:40 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 7:40 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | - | - | | ○ | | | | HQ not received |
| | 7:45 | MP-8 | 2.5 μSv/h | - | - | - | - | | | | | | |
| | 7:50 | MP-8 | 2.5 μSv/h | - | - | - | - | | | | | | |
| | 7:50 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 7:55 | MP-8 | 2.5 μSv/h | - | - | - | - | | | | | | |
| | 8:00 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:00 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | SE | 0.9 | | | | | | |
| | 8:05 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:10 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 8:10 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | SW | 0.9 | | | | | | |
| | 8:15 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:20 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:20 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | S | 1.2 | | | | | | |
| | 8:25 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:30 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:35 | MP-8 | 2.4 μSv/h | - | - | - | - | | | | | | |
| | 8:40 | MP-8 | 2.3 μSv/h | - | - | - | - | | | | | | |
| | 8:40 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | S | 2.0 | | | | | | |
| | 8:45 | MP-8 | 2.5 μSv/h | - | - | - | - | | | | | | |
| | 8:50 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 8:50 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | S | 1.6 | | | | | | |
| | 8:55 | MP-8 | 2.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 9:00 | MP-8 | 2.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 9:00 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | SE | 2.0 | | ○ | | | | HQ not received |
| | 9:05 | MP-8 | 2.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 9:10 | MP-8 | 2.7 μSv/h | - | - | - | - | | | | | | |
| | 9:10 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | S | 2.4 | | ○ | | | | HQ not received |
| | 9:15 | MP-8 | 2.8 μSv/h | - | - | - | - | | | | | | |
| | 9:20 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:25 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:30 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:30 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | SE | 2.5 | | | | | | |
| | 9:35 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:40 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:40 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | SE | 2.8 | | ○ | | | | HQ not received |
| | 9:45 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:50 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 9:50 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | SSE | 2.8 | | | | | | |
| | 9:55 | MP-8 | 2.6 μSv/h | - | - | - | - | | | | | | |
| | 10:00 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 10:00 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | S | 1.9 | | | | | | |
| | 10:05 | MP-8 | 4.6 μSv/h | - | - | - | - | | | | | | |
| | 10:10 | MP-8 | 4.6 μSv/h | - | - | - | - | | | | | | |
| | 10:10 | Main Gate | 6.7 μSv/h | below 0.01μSv/h | - | SE | 2.2 | | | | | | |
| | 10:15 | MP-8 | 4.3 μSv/h | - | - | - | - | | | | | | |

3/12

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|
| | 10:20 | MP-8 | 3.9 μSv/h | - | - | - | - | | | | | | |
| | 10:20 | Main Gate | 180.2 μSv/h | below 0.01μSv/h | - | SE | 2.0 | | | | | | |
| | 10:25 | MP-8 | 4.8 μSv/h | - | - | - | - | | | | | | |
| | 10:30 | MP-8 | 9.1 μSv/h | - | - | - | - | | | | | | |
| | 10:30 | Main Gate | 385.5 μSv/h | below 0.01μSv/h | - | N | 1.8 | | | | | | |
| | 10:35 | MP-8 | 24.1 μSv/h | - | - | - | - | | | | | | |
| | 10:40 | Main Gate | 162.9 μSv/h | below 0.01μSv/h | - | N | 2.0 | | | | | | |
| | 10:45 | MP-8 | 16.9 μSv/h | - | - | - | - | | | | | | |
| | 10:50 | MP-8 | 7.0 μSv/h | - | - | - | - | | | | | | |
| | 10:50 | Main Gate | 7.0 μSv/h | below 0.01μSv/h | - | N | 1.7 | | | | | | |
| | 11:00 | MP-8 | 5.2 μSv/h | - | - | - | - | | | | | | |
| | 11:00 | Main Gate | 6.7 μSv/h | below 0.01μSv/h | - | SW | 1.6 | | | | | | |
| | 11:10 | MP-8 | 4.9 μSv/h | - | - | - | - | | | | | | |
| | 11:10 | Main Gate | 6.3 μSv/h | below 0.01μSv/h | - | SW | 2.7 | | | | | | |
| | 11:20 | MP-8 | 5.2 μSv/h | - | - | - | - | | | | | | |
| | 11:20 | Main Gate | 9.4 μSv/h | below 0.01μSv/h | - | NE | 2.2 | | | | | | |
| | 11:30 | MP-1 | 12.2 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 11:30 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 11:30 | Main Gate | 35.8 μSv/h | below 0.01μSv/h | - | E | 1.6 | | | | | | |
| | 11:35 | MP-1 | 11.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 11:40 | MP-8 | 3.8 μSv/h | - | - | - | - | | | | | | |
| | 11:40 | Main Gate | 12.5 μSv/h | below 0.01μSv/h | - | SW | 2.0 | | | | | | |
| | 11:40 | MP-1 | 10.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 11:45 | MP-1 | 10.6 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 11:50 | MP-8 | 4.1 μSv/h | - | - | - | - | | | | | | |
| | 11:50 | Main Gate | 17.1 μSv/h | below 0.01μSv/h | - | NW | 2.7 | | | | | | |
| | 11:50 | MP-1 | 10.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 11:55 | MP-1 | 10.9 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:00 | MP-8 | 5.3 μSv/h | - | - | - | - | | | | | | |
| | 0:00 | Main Gate | 23.2 μSv/h | below 0.01μSv/h | - | N | 2.3 | | | | | | |
| | 0:00 | MP-1 | 14.1 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:05 | MP-8 | 8.8 μSv/h | - | - | - | - | | | | | | |
| | 0:05 | MP-1 | 10.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:10 | MP-8 | 13.5 μSv/h | - | - | - | - | | | | | | |
| | 0:10 | Main Gate | 48.2 μSv/h | below 0.01μSv/h | - | W | 1.9 | | | | | | |
| | 0:10 | MP-1 | 9.8 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:15 | MP-8 | 11.7 μSv/h | - | - | - | - | | | | | | |
| | 0:15 | MP-1 | 10.3 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:20 | MP-8 | 4.1 μSv/h | - | - | - | - | | | | | | |
| | 0:20 | Main Gate | 11.6 μSv/h | below 0.01μSv/h | - | NW | 2.2 | | | | | | |
| | 0:20 | MP-1 | 14.1 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:25 | MP-8 | 3.8 μSv/h | - | - | - | - | | | | | | |
| | 0:25 | MP-1 | 9.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:30 | MP-8 | 3.6 μSv/h | - | - | - | - | | | | | | |
| | 0:30 | Main Gate | 5.8 μSv/h | below 0.01μSv/h | Fine | SE | 1.8 | | | | | | |
| | 0:35 | MP-1 | 9.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:40 | MP-8 | 3.6 μSv/h | - | - | - | - | | | | | | |
| | 0:40 | Main Gate | 5.6 μSv/h | below 0.01μSv/h | - | S | 2.0 | | | | | | |
| | 0:40 | MP-1 | 8.8 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:45 | MP-1 | 10.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 0:50 | MP-8 | 3.5 μSv/h | - | - | - | - | | | | | | |
| | 0:50 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | SE | 1.7 | | | | | | |
| | 0:50 | MP-1 | 8.3 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 13:00 | MP-8 | 3.7 μSv/h | - | - | - | - | | | | | | |
| | 13:00 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | E | 1.7 | | | | | | |
| | 13:10 | MP-8 | 3.7 μSv/h | - | - | - | - | | | | | | |
| | 13:10 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | S | 2.6 | | | | | | |
| | 13:20 | MP-8 | 3.3 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 13:20 | Main Gate | 10.9 μSv/h | below 0.01μSv/h | - | E | 2.6 | | | | | | |
| | 13:25 | MP-8 | 3.0 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 13:30 | MP-8 | 2.3 μSv/h | - | - | - | - | | | | | | |
| | 13:40 | MP-8 | 2.3 μSv/h | - | - | - | - | | | | | | |
| | 13:40 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | SE | 2.3 | | | | | | |
| | 13:50 | MP-8 | 2.8 μSv/h | - | - | - | - | | | | | | |
| | 13:50 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | E | 2.9 | | | | | | |
| | 13:55 | MP-8 | 3.1 μSv/h | - | - | - | - | | | | | | |
| | 14:00 | MP-8 | 2.1 μSv/h | - | - | - | - | | | | | | |
| | 14:00 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | SSE | 3.5 | | | | | | |
| | 14:10 | MP-8 | 3.0 μSv/h | - | - | - | - | | | | | | |
| | 14:10 | Main Gate | 7.3 μSv/h | below 0.01μSv/h | - | SSE | 3.3 | | | | | | |
| | 14:20 | MP-8 | 3.8 μSv/h | - | - | - | - | | | | | | |
| | 14:20 | Main Gate | 10.9 μSv/h | below 0.01μSv/h | - | SSE | 3.3 | | | | | | |
| | 14:30 | MP-8 | 3.5 μSv/h | - | - | - | - | | | | | | |
| | 14:30 | Main Gate | 10.0 μSv/h | below 0.01μSv/h | - | S | 2.7 | | | | | | |
| | 14:40 | MP-8 | 3.3 μSv/h | - | - | - | - | | | | | | |
| | 14:40 | Main Gate | 8.9 μSv/h | below 0.01μSv/h | - | S | 2.7 | | | | | | |
| | 14:50 | MP-8 | 3.5 μSv/h | - | - | - | - | | | | | | |
| | 14:50 | Main Gate | 7.7 μSv/h | below 0.01μSv/h | - | S | 3.4 | | | | | | |
| | 15:00 | MP-8 | 3.5 μSv/h | - | - | - | - | | | | | | |
| | 15:00 | Main Gate | 7.0 μSv/h | below 0.01μSv/h | - | SSE | 2.7 | | | | | | |
| | 15:10 | MP-8 | 3.3 μSv/h | - | - | - | - | | | | | | |
| | 15:10 | Main Gate | 7.0 μSv/h | below 0.01μSv/h | - | S | 2.5 | | | | | | |
| | 15:13 | MP-4 | 162.4 μSv/h | - | Fine | SW | 7.3 | | ○ | | | | disc std uncertain |
| | 15:15 | MP-4 | 166.2 μSv/h | - | Fine | SSW | 5.8 | | ○ | | | | disc std uncertain |
| | 15:17 | MP-4 | 131.3 μSv/h | - | Fine | SSW | 3.8 | | ○ | | | | disc std uncertain |
| | 15:19 | MP-4 | 173.7 μSv/h | - | Fine | S | 2.3 | | ○ | | | | disc std uncertain |
| | 15:20 | MP-8 | 3.2 μSv/h | - | - | - | - | | | | | | |
| | 15:20 | Main Gate | 5.6 μSv/h | below 0.01μSv/h | - | SSE | 3.2 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|----------------------|-------|-----------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------------------|
| | 15:21 | MP-4 | 145.9 μSv/h | - | Fine | SSE | 0.8 | | | ○ | | | disc std uncertain |
| | 15:23 | MP-4 | 132.0 μSv/h | - | Fine | SSE | 0.6 | | | ○ | | | disc std uncertain |
| | 15:25 | MP-4 | 129.4 μSv/h | - | Fine | SSE | 0.6 | | | ○ | | | disc std uncertain |
| | 15:27 | MP-4 | 138.3 μSv/h | - | Fine | SSE | 0.6 | | | ○ | | | disc std uncertain |
| Article 15-24 notice | 15:29 | MP-4 | 1015.1 μSv/h | - | Fine | SSE | 0.7 | | | ○ | | | disc std uncertain |
| | 15:30 | MP-8 | 3.2 μSv/h | - | - | - | - | | | | | | |
| | 15:30 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | S | 2.5 | | | | | | |
| | 15:31 | MP-4 | 569.2 μSv/h | - | Fine | SSE | 0.7 | | | ○ | | | disc std uncertain |
| | 15:33 | MP-4 | 431.3 μSv/h | - | Fine | SSE | 0.7 | | | ○ | | | disc std uncertain |
| | 15:35 | MP-4 | 270.5 μSv/h | - | Fine | SSE | 0.7 | | | ○ | | | disc std uncertain |
| | 15:37 | MP-4 | 230.8 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:39 | MP-4 | 204.3 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:40 | MP-8 | 3.3 μSv/h | - | - | - | - | | | | | | |
| | 15:40 | Main Gate | 8.2 μSv/h | below 0.01μSv/h | - | S | 3.0 | | | | | | |
| | 15:41 | MP-4 | 174.7 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:43 | MP-4 | 153.3 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:45 | MP-4 | 150.0 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:47 | MP-4 | 141.8 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:49 | MP-4 | 133.0 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:50 | MP-8 | 2.2 μSv/h | - | - | - | - | | | | | | |
| | 15:50 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | S | 2.6 | | | | | | |
| | 15:51 | MP-4 | 132.3 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:53 | MP-4 | 134.7 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:55 | MP-4 | 129.1 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:57 | MP-4 | 129.3 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 15:59 | MP-4 | 132.3 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 16:00 | MP-8 | 2.2 μSv/h | - | - | - | - | | | | | | |
| | 16:00 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | SSE | 2.3 | | | | | | |
| | 16:01 | MP-4 | 131.4 μSv/h | - | Fine | SSE | 0.7 | | ○ | | | | HQ not received |
| | 16:03 | MP-4 | 129.5 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:05 | MP-4 | 122.2 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:07 | MP-4 | 116.7 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:09 | MP-4 | 113.8 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:10 | MP-8 | 2.2 μSv/h | - | - | - | - | | | | | | |
| | 16:10 | Main Gate | 3.6 μSv/h | below 0.01μSv/h | - | SSE | 2.4 | | | | | | |
| | 16:11 | MP-4 | 108.8 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:13 | MP-4 | 106.9 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:15 | MP-4 | 108.2 μSv/h | - | Fine | SSE | 0.6 | | ○ | | | | HQ not received |
| | 16:20 | MP-8 | 2.2 μSv/h | - | - | - | - | | | | | | |
| | 16:20 | Main Gate | 3.4 μSv/h | below 0.01μSv/h | - | SSE | 2.4 | | | | | | |
| | 16:30 | MP-8 | 2.1 μSv/h | - | - | - | - | | | | | | |
| | 16:30 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | S | 2.2 | | | | | | |
| | 16:40 | MP-8 | 2.1 μSv/h | - | - | - | - | | | | | | |
| | 16:40 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | SSW | 2.4 | | | | | | |
| | 16:50 | MP-8 | 3.8 μSv/h | - | - | - | - | | | | | | |
| | 16:50 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | SSW | 1.9 | | | | | | |
| | 17:00 | MP-8 | 3.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:00 | Main Gate | 3.7 μSv/h | below 0.01μSv/h | - | S | 1.7 | | ○ | | | | HQ not received |
| | 17:10 | MP-8 | 3.5 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:10 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | S | 1.8 | | ○ | | | | HQ not received |
| | 17:20 | MP-8 | 3.4 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:20 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | SSE | 1.7 | | ○ | | | | HQ not received |
| | 17:30 | MP-8 | 3.2 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:30 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | E | 0.8 | | ○ | | | | HQ not received |
| | 17:40 | MP-8 | 2.8 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:40 | Main Gate | 2.9 μSv/h | below 0.01μSv/h | - | N | 0.5 | | ○ | | | | HQ not received |
| | 17:50 | MP-8 | 2.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 17:50 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | SW | 0.6 | | ○ | | | | HQ not received |
| | 17:54 | MP-4 | 84.8 μSv/h | - | - | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 17:56 | MP-4 | 84.3 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 17:58 | MP-4 | 83.8 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:00 | MP-4 | 83.2 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:00 | MP-8 | 2.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 18:00 | Main Gate | 9.1 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | ○ | | | | HQ not received |
| | 18:02 | MP-4 | 80.7 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:04 | MP-4 | 73.5 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:06 | MP-4 | 79.6 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:08 | MP-4 | 78.8 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:10 | MP-4 | 78.5 μSv/h | - | Fine | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 18:10 | MP-8 | 2.7 μSv/h | - | - | - | - | | ○ | | | | HQ not received |
| | 18:10 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | S | 0.3 | | ○ | | | | HQ not received |
| | 18:12 | MP-4 | 78.4 μSv/h | - | Fine | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 18:14 | MP-4 | 77.9 μSv/h | - | Fine | NW | 0.8 | | | ○ | | | disc std uncertain |
| | 18:16 | MP-4 | 77.3 μSv/h | - | Fine | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 18:18 | MP-4 | 76.9 μSv/h | - | Fine | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 18:20 | MP-4 | 76.6 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:20 | Main Gate | 25.4 μSv/h | below 0.01μSv/h | - | W | 0.6 | | ○ | | | | HQ not received |
| | 18:22 | MP-4 | 76.2 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:24 | MP-4 | 76.2 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:26 | MP-4 | 76.6 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 18:28 | MP-4 | 77.5 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 18:30 | MP-4 | 76.3 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:32 | MP-4 | 73.9 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:34 | MP-4 | 73.4 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:36 | MP-4 | 73.1 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:38 | MP-4 | 72.7 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:40 | MP-4 | 72.4 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:42 | MP-4 | 72.4 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|
| | 18:44 | MP-4 | 72.1 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:46 | MP-4 | 71.8 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:48 | MP-4 | 71.5 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:50 | MP-4 | 71.0 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:52 | MP-4 | 70.7 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:54 | MP-4 | 70.4 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:56 | MP-4 | 70.0 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 18:58 | MP-4 | 70.5 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 19:00 | MP-4 | 72.1 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 19:00 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | ○ | | | | HQ not received |
| | 19:02 | MP-4 | 71.8 μSv/h | - | Fine | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 19:04 | MP-4 | 69.9 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:06 | MP-4 | 68.3 μSv/h | - | Fine | S | 0.5 | | | ○ | | | disc std uncertain |
| | 19:10 | Main Gate | 3.8 μSv/h | below 0.01μSv/h | - | W | 0.6 | | ○ | | | | HQ not received |
| | 19:18 | MP-4 | 68.0 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 19:20 | MP-4 | 67.7 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 19:20 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | W | 0.6 | | ○ | | | | HQ not received |
| | 19:22 | MP-4 | 67.4 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 19:24 | MP-4 | 67.2 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:25 | MP-8 | 80.0 μSv/h | - | - | - | - | | | | | | |
| | 19:26 | MP-4 | 66.9 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:28 | MP-4 | 66.3 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:30 | MP-4 | 66.0 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:30 | Main Gate | 2.8 μSv/h | below 0.01μSv/h | - | W | 0.5 | | ○ | | | | HQ not received |
| | 19:32 | MP-4 | 65.7 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:34 | MP-4 | 65.3 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:36 | MP-4 | 65.3 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:38 | MP-4 | 65.0 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:40 | MP-4 | 64.7 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:40 | Main Gate | 2.7 μSv/h | below 0.01μSv/h | Fine | W | 0.5 | | ○ | | | | HQ not received |
| | 19:42 | MP-4 | 64.5 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:44 | MP-4 | 64.2 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:46 | MP-4 | 65.3 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:48 | MP-4 | 64.7 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 19:50 | MP-4 | 63.6 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:50 | MP-8 | 23.9 μSv/h | - | - | - | - | | ○ | | | | Sec Team unsent |
| | 19:50 | Main Gate | 23.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 19:52 | MP-4 | 63.0 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:54 | MP-4 | 62.7 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 19:56 | MP-4 | 62.5 μSv/h | - | Fine | SSE | 0.5 | | | ○ | | | disc std uncertain |
| | 19:58 | MP-4 | 62.2 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 20:00 | MP-4 | 62.2 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 20:00 | MP-8 | 10 μSv/h | - | - | - | - | | | | | | |
| | 20:00 | Main Gate | 2.7 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 20:02 | MP-4 | 62.0 μSv/h | - | Fine | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 20:04 | MP-4 | 61.9 μSv/h | - | Fine | NE | 0.3 | | | ○ | | | disc std uncertain |
| | 20:06 | MP-4 | 61.6 μSv/h | - | Fine | NE | 0.3 | | | ○ | | | disc std uncertain |
| | 20:08 | MP-4 | 62.1 μSv/h | - | Fine | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 20:10 | MP-4 | 61.3 μSv/h | - | Fine | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 20:10 | MP-8 | 10 μSv/h | - | - | - | - | | | | | | |
| | 20:10 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 20:12 | MP-4 | 61.0 μSv/h | - | Fine | N | 0.2 | | | ○ | | | disc std uncertain |
| | 20:14 | MP-4 | 60.6 μSv/h | - | Fine | N | 0.2 | | | ○ | | | disc std uncertain |
| | 20:16 | MP-4 | 60.3 μSv/h | - | Fine | N | 0.2 | | | ○ | | | disc std uncertain |
| | 20:18 | MP-4 | 60.0 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 20:20 | MP-4 | 59.7 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 20:20 | MP-8 | 10 μSv/h | - | - | - | - | | | | | | |
| | 20:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 20:22 | MP-4 | 59.6 μSv/h | - | Fine | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 20:24 | MP-4 | 59.4 μSv/h | - | Fine | SSW | 0.3 | | | ○ | | | disc std uncertain |
| | 20:26 | MP-4 | 59.1 μSv/h | - | Fine | SW | 0.3 | | | ○ | | | disc std uncertain |
| | 20:28 | MP-4 | 59.3 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | HQ not received |
| | 20:30 | MP-4 | 60.0 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | HQ not received |
| | 20:30 | MP-8 | 3.2 μSv/h | - | - | - | - | | ○ | | | | Sec Team unsent |
| | 20:30 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | SW | 0.6 | | | | | | |
| | 20:32 | MP-4 | 59.0 μSv/h | - | Fine | W | 0.3 | | ○ | | | | HQ not received |
| | 20:34 | MP-4 | 57.9 μSv/h | - | Fine | WNW | 0.3 | | ○ | | | | HQ not received |
| | 20:36 | MP-4 | 57.8 μSv/h | - | Fine | NW | 0.4 | | ○ | | | | HQ not received |
| | 20:38 | MP-4 | 57.5 μSv/h | - | Fine | N | 0.4 | | ○ | | | | HQ not received |
| | 20:40 | MP-4 | 57.4 μSv/h | - | Fine | NNE | 0.4 | | ○ | | | | HQ not received |
| | 20:40 | MP-8 | 5 μSv/h | - | - | - | - | | | | | | |
| | 20:42 | MP-4 | 57.4 μSv/h | - | Fine | NNE | 0.4 | | ○ | | | | HQ not received |
| | 20:44 | MP-4 | 57.2 μSv/h | - | Fine | ENE | 0.4 | | ○ | | | | HQ not received |
| | 20:46 | MP-4 | 57.0 μSv/h | - | Fine | NNW | 0.4 | | ○ | | | | HQ not received |
| | 20:48 | MP-4 | 56.8 μSv/h | - | Fine | NNW | 0.5 | | ○ | | | | HQ not received |
| | 20:50 | MP-4 | 56.5 μSv/h | - | Fine | NW | 0.5 | | ○ | | | | HQ not received |
| | 20:50 | MP-8 | 6 μSv/h | - | - | - | - | | | | | | |
| | 20:52 | MP-4 | 56.5 μSv/h | - | Fine | NW | 0.5 | | ○ | | | | HQ not received |
| | 20:54 | MP-4 | 69.1 μSv/h | - | Fine | NNW | 0.4 | | ○ | | | | HQ not received |
| | 20:56 | MP-4 | 324.5 μSv/h | - | Fine | NNW | 0.5 | | ○ | | | | HQ not received |
| | 20:58 | MP-4 | 357.4 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:00 | MP-4 | 406.9 μSv/h | - | Fine | W | 0.5 | | ○ | | | | HQ not received |
| | 21:00 | MP-8 | 80 μSv/h | - | - | - | - | | | | | | |
| | 21:02 | MP-4 | 365.8 μSv/h | - | Fine | WSW | 0.6 | | ○ | | | | HQ not received |
| | 21:04 | MP-4 | 187.3 μSv/h | - | Fine | W | 0.6 | | ○ | | | | HQ not received |
| | 21:06 | MP-4 | 149.5 μSv/h | - | Fine | WNW | 0.6 | | ○ | | | | HQ not received |
| | 21:08 | MP-4 | 114.5 μSv/h | - | Fine | NW | 0.7 | | ○ | | | | HQ not received |
| | 21:10 | MP-4 | 92.2 μSv/h | - | Fine | NW | 0.7 | | ○ | | | | HQ not received |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------------------|
| | 21:10 | MP-8 | 80 μSv/h | - | - | - | - | | | | | | |
| | 21:12 | MP-4 | 86.8 μSv/h | - | Fine | NW | 0.6 | | ○ | | | | HQ not received |
| | 21:14 | MP-4 | 85.3 μSv/h | - | Fine | NW | 0.5 | | ○ | | | | HQ not received |
| | 21:16 | MP-4 | 71.0 μSv/h | - | Fine | NW | 0.5 | | ○ | | | | HQ not received |
| | 21:18 | MP-4 | 74.5 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:20 | MP-4 | 75.8 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:20 | MP-8 | 70 μSv/h | - | - | - | - | | | | | | |
| | 21:22 | MP-4 | 69.9 μSv/h | - | Fine | WNW | 0.3 | | ○ | | | | HQ not received |
| | 21:24 | MP-4 | 66.1 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:26 | MP-4 | 65.4 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:28 | MP-4 | 64.8 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:30 | MP-4 | 61.6 μSv/h | - | Fine | NW | 0.4 | | ○ | | | | HQ not received |
| | 21:30 | MP-8 | 80 μSv/h | - | - | - | - | | | | | | |
| | 21:32 | MP-4 | 60.4 μSv/h | - | Fine | WNW | 0.4 | | ○ | | | | HQ not received |
| | 21:34 | MP-4 | 60.4 μSv/h | - | Fine | NW | 0.3 | | ○ | | | | HQ not received |
| | 21:36 | MP-4 | 60.3 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 21:38 | MP-4 | 59.2 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 21:40 | MP-4 | 58.1 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 21:40 | MP-8 | 50 μSv/h | - | - | - | - | | | | | | |
| | 21:42 | MP-4 | 56.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 21:44 | MP-4 | 56.2 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 21:46 | MP-4 | 55.9 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 21:48 | MP-4 | 55.4 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 21:50 | MP-4 | 55.1 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 21:50 | MP-8 | 70 μSv/h | - | - | - | - | | | | | | |
| | 21:50 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | SW | 0.5 | | | | | | |
| | 21:52 | MP-4 | 54.8 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 21:54 | MP-4 | 54.5 μSv/h | - | Fine | WNW | 0.6 | | | ○ | | | disc std uncertain |
| | 21:56 | MP-4 | 54.2 μSv/h | - | Fine | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 21:58 | MP-4 | 54.1 μSv/h | - | Fine | WNW | 0.8 | | | ○ | | | disc std uncertain |
| | 22:00 | MP-4 | 53.9 μSv/h | - | Fine | WNW | 0.8 | | | ○ | | | disc std uncertain |
| | 22:00 | MP-8 | 70 μSv/h | - | - | - | - | | | | | | |
| | 22:00 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 22:02 | MP-4 | 53.7 μSv/h | - | Fine | WNW | 0.8 | | | ○ | | | disc std uncertain |
| | 22:04 | MP-4 | 53.5 μSv/h | - | Fine | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 22:06 | MP-4 | 53.3 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 22:08 | MP-4 | 53.2 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:10 | MP-4 | 53.1 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:10 | Main Gate | 21.6 μSv/h | below 0.01μSv/h | - | SW | 0.4 | | | | | | |
| | 22:12 | MP-4 | 52.9 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:14 | MP-4 | 52.8 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:16 | MP-4 | 52.6 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:18 | MP-4 | 52.4 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:20 | MP-4 | 52.2 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:20 | Main Gate | 2.9 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 22:22 | MP-4 | 52.1 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:24 | MP-4 | 52.0 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:26 | MP-4 | 52.0 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 22:28 | MP-4 | 51.8 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 22:30 | MP-4 | 51.5 μSv/h | - | Fine | N | 0.4 | | | ○ | | | disc std uncertain |
| | 22:30 | MP-8 | 4.9 μSv/h | - | - | - | - | | | | | | |
| | 22:30 | Main Gate | 2.9 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 22:32 | MP-4 | 51.4 μSv/h | - | Fine | ESE | 0.4 | | | ○ | | | disc std uncertain |
| | 22:34 | MP-4 | 51.3 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:35 | MP-8 | 4.7 μSv/h | - | - | - | - | | | | | | |
| | 22:36 | MP-4 | 51.3 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:38 | MP-4 | 53.3 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:40 | MP-4 | 53.0 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:40 | MP-8 | 4.1 μSv/h | - | - | - | - | | | | | | |
| | 22:40 | Main Gate | 2.9 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 22:42 | MP-4 | 50.6 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:44 | MP-4 | 50.3 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:46 | MP-4 | 50.2 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:48 | MP-4 | 50.1 μSv/h | - | Fine | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:50 | MP-4 | 49.9 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:50 | MP-8 | 4.4 μSv/h | - | - | - | - | | | | | | |
| | 22:50 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | S | 0.4 | | | | | | |
| | 22:52 | MP-4 | 49.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 22:54 | MP-4 | 49.9 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:56 | MP-4 | 50.3 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 22:58 | MP-4 | 49.4 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 23:00 | MP-4 | 49.3 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 23:00 | MP-8 | 4.3 μSv/h | - | - | - | - | | | | | | |
| | 23:00 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | N | 0.4 | | | | | | |
| | 23:02 | MP-4 | 49.2 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 23:04 | MP-4 | 49.1 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 23:06 | MP-4 | 48.9 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:08 | MP-4 | 48.8 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:10 | MP-4 | 49.1 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:10 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 23:12 | MP-4 | 48.7 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:14 | MP-4 | 48.4 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:16 | MP-4 | 48.3 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:18 | MP-4 | 48.2 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:20 | MP-4 | 48.0 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:20 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 23:22 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 23:24 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason | |
|------|-----------|------------|-----------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|--------------------|
| 3/13 | 23:26 | MP-4 | 47.7 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain | |
| | 23:28 | MP-4 | 47.6 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | disc std uncertain | |
| | 23:30 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | disc std uncertain | |
| | 23:30 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | | |
| | 23:30 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | | |
| | 23:32 | MP-4 | 48.3 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:34 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.2 | | | ○ | | | | disc std uncertain |
| | 23:36 | MP-4 | 47.2 μSv/h | - | Fine | WSW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:38 | MP-4 | 47.1 μSv/h | - | Fine | N | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:40 | MP-4 | 46.9 μSv/h | - | Fine | N | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:40 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | | |
| | 23:42 | MP-4 | 46.9 μSv/h | - | Fine | N | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:44 | MP-4 | 46.7 μSv/h | - | Fine | N | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:46 | MP-4 | 46.6 μSv/h | - | Fine | WSW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:48 | MP-4 | 46.5 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:50 | MP-4 | 46.4 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:50 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | | | | | | |
| | 23:52 | MP-4 | 46.4 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:54 | MP-4 | 46.2 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:56 | MP-4 | 46.0 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain |
| | 23:58 | MP-4 | 46.0 μSv/h | - | Fine | SW | 0.2 | | | ○ | | | | disc std uncertain |
| | 0:00 | MP-4 | 45.9 μSv/h | - | Fine | N | 0.2 | | | ○ | | | | disc std uncertain |
| | 0:00 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | | |
| | 0:00 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | NE | 0.3 | | | | | | | |
| | 0:02 | MP-4 | 45.8 μSv/h | - | Fine | NW | 0.2 | | | ○ | | | | disc std uncertain |
| | 0:04 | MP-4 | 45.7 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain |
| | 0:06 | MP-4 | 45.7 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain |
| 0:08 | MP-4 | 45.6 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:10 | MP-4 | 45.7 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:10 | MP-8 | 4.7 μSv/h | - | - | - | - | | | | | | | | |
| 0:10 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | NNW | 0.4 | | | | | | | | |
| 0:12 | MP-4 | 46.6 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:14 | MP-4 | 46.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:16 | MP-4 | 45.3 μSv/h | - | Fine | N | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:18 | MP-4 | 45.1 μSv/h | - | Fine | N | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:20 | MP-4 | 45.0 μSv/h | - | Fine | N | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:20 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | | | |
| 0:20 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | E | 0.4 | | | | | | | | |
| 0:22 | MP-4 | 44.9 μSv/h | - | Fine | E | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:24 | MP-4 | 44.8 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:26 | MP-4 | 44.8 μSv/h | - | Fine | NW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:28 | MP-4 | 44.7 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:30 | MP-4 | 44.6 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:30 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | | | |
| 0:30 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | S | 0.4 | | | | | | | | |
| 0:32 | MP-4 | 44.5 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:34 | MP-4 | 44.5 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:36 | MP-4 | 44.4 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:38 | MP-4 | 44.4 μSv/h | - | Fine | SW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:40 | MP-4 | 45.4 μSv/h | - | Fine | S | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:40 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | | | |
| 0:40 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | | | |
| 0:42 | MP-4 | 45.0 μSv/h | - | Fine | SSW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:44 | MP-4 | 44.2 μSv/h | - | Fine | SSW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:46 | MP-4 | 44.0 μSv/h | - | Fine | WSW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:48 | MP-4 | 43.9 μSv/h | - | Fine | WNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 0:50 | MP-4 | 43.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:50 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | | | |
| 0:50 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | | | |
| 0:52 | MP-4 | 43.7 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:54 | MP-4 | 43.6 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:56 | MP-4 | 43.5 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 0:58 | MP-4 | 43.5 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:00 | MP-4 | 43.4 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:00 | MP-8 | 5.5 μSv/h | - | - | - | - | | | | | | | | |
| 1:00 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | SE | 0.5 | | | | | | | | |
| 1:02 | MP-4 | 43.1 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:04 | MP-4 | 43.1 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:06 | MP-4 | 43.0 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:08 | MP-4 | 43.7 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:10 | MP-4 | 44.5 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:10 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | | | |
| 1:10 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | | | |
| 1:12 | MP-4 | 42.9 μSv/h | - | Fine | NNW | 0.3 | | | ○ | | | | disc std uncertain | |
| 1:14 | MP-4 | 42.8 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:16 | MP-4 | 42.7 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:18 | MP-4 | 42.6 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:20 | MP-4 | 42.6 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:20 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | | | |
| 1:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | | | |
| 1:22 | MP-4 | 42.5 μSv/h | - | Fine | SW | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:24 | MP-4 | 42.5 μSv/h | - | Fine | N | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:26 | MP-4 | 42.4 μSv/h | - | Fine | NNE | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:28 | MP-4 | 42.4 μSv/h | - | Fine | NE | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:30 | MP-4 | 42.3 μSv/h | - | Fine | NE | 0.4 | | | ○ | | | | disc std uncertain | |
| 1:30 | MP-8 | 5.5 μSv/h | - | - | - | - | | | | | | | | |
| 1:30 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | NE | 0.6 | | | | | | | | |
| 1:32 | MP-4 | 42.2 μSv/h | - | Fine | NNE | 0.3 | | | ○ | | | | disc std uncertain | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|------|-----------|------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|
| | 1:34 | MP-4 | 42.2 μSv/h | - | Fine | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 1:38 | MP-4 | 42.0 μSv/h | - | - | E | 0.3 | | | ○ | | | disc std uncertain |
| | 1:40 | MP-4 | 42.0 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 1:40 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 1:40 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | |
| | 1:42 | MP-4 | 41.9 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 1:44 | MP-4 | 41.9 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 1:46 | MP-4 | 43.2 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 1:48 | MP-4 | 43.0 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 1:50 | MP-4 | 41.7 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 1:50 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 1:50 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 1:52 | MP-4 | 41.7 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 1:54 | MP-4 | 41.6 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 1:56 | MP-4 | 41.5 μSv/h | - | - | WNW | 0.3 | | | ○ | | | disc std uncertain |
| | 1:58 | MP-4 | 41.4 μSv/h | - | - | ESE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:00 | MP-4 | 41.3 μSv/h | - | - | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 2:00 | MP-8 | 5.5 μSv/h | - | - | - | - | | | | | | |
| | 2:00 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 2:02 | MP-4 | 41.3 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:04 | MP-4 | 41.2 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:06 | MP-4 | 41.1 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:08 | MP-4 | 41.1 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:10 | MP-4 | 41.0 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:10 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 2:10 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 2:12 | MP-4 | 40.9 μSv/h | - | - | NNW | 0.4 | | | | | | |
| | 2:14 | MP-4 | 40.9 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:16 | MP-4 | 40.8 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:18 | MP-4 | 40.8 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:20 | MP-4 | 40.8 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:20 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 2:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | SE | 0.5 | | | | | | |
| | 2:22 | MP-4 | 40.7 μSv/h | - | - | WNW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:24 | MP-4 | 40.7 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:26 | MP-4 | 42.3 μSv/h | - | - | S | 0.3 | | | ○ | | | disc std uncertain |
| | 2:28 | MP-4 | 42.1 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:30 | MP-4 | 41.6 μSv/h | - | - | NE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:30 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 2:30 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | S | 0.6 | | | | | | |
| | 2:32 | MP-4 | 40.5 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:34 | MP-4 | 40.4 μSv/h | - | - | NE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:36 | MP-4 | 40.3 μSv/h | - | - | ENE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:38 | MP-4 | 40.3 μSv/h | - | - | ENE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:40 | MP-4 | 40.2 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:40 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 2:40 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | SW | 0.7 | | | | | | |
| | 2:42 | MP-4 | 40.6 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:44 | MP-4 | 40.9 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:46 | MP-4 | 40.9 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:48 | MP-4 | 40.1 μSv/h | - | - | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 2:50 | MP-4 | 39.8 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:50 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 2:50 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | S | 0.7 | | | | | | |
| | 2:52 | MP-4 | 39.8 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 2:54 | MP-4 | 39.8 μSv/h | - | - | SE | 0.3 | | | ○ | | | disc std uncertain |
| | 2:56 | MP-4 | 39.8 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 2:58 | MP-4 | 39.8 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 3:00 | MP-4 | 39.8 μSv/h | - | - | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 3:00 | Main Gate | 3.6 μSv/h | below 0.01μSv/h | - | S | 1.2 | | | | | | |
| | 3:02 | MP-4 | 39.7 μSv/h | - | - | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 3:04 | MP-4 | 39.7 μSv/h | - | - | W | 0.3 | | | ○ | | | disc std uncertain |
| | 3:06 | MP-4 | 39.7 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 3:08 | MP-4 | 39.6 μSv/h | - | - | WSW | 0.4 | | | ○ | | | disc std uncertain |
| | 3:10 | MP-4 | 41.2 μSv/h | - | - | S | 0.3 | | | ○ | | | disc std uncertain |
| | 3:10 | Main Gate | 4.0 μSv/h | below 0.01μSv/h | - | SE | 1.5 | | | | | | |
| | 3:12 | MP-4 | 41.0 μSv/h | - | - | S | 0.4 | | | ○ | | | disc std uncertain |
| | 3:14 | MP-4 | 40.0 μSv/h | - | - | S | 0.4 | | | ○ | | | disc std uncertain |
| | 3:16 | MP-4 | 39.2 μSv/h | - | - | S | 0.5 | | | ○ | | | disc std uncertain |
| | 3:18 | MP-4 | 39.2 μSv/h | - | - | S | 0.5 | | | ○ | | | disc std uncertain |
| | 3:20 | MP-4 | 39.1 μSv/h | - | - | S | 0.5 | | | ○ | | | disc std uncertain |
| | 3:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | SSE | 2.0 | | | | | | |
| | 3:22 | MP-4 | 39.1 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:24 | MP-4 | 39.0 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:26 | MP-4 | 38.9 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:28 | MP-4 | 38.9 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:30 | MP-4 | 38.8 μSv/h | - | - | SE | 0.3 | | | ○ | | | disc std uncertain |
| | 3:30 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | S | 1.6 | | | | | | |
| | 3:32 | MP-4 | 38.8 μSv/h | - | - | SSE | 0.3 | | | ○ | | | disc std uncertain |
| | 3:34 | MP-4 | 38.7 μSv/h | - | - | SSE | 0.3 | | | ○ | | | disc std uncertain |
| | 3:36 | MP-4 | 38.8 μSv/h | - | - | S | 0.3 | | | ○ | | | disc std uncertain |
| | 3:38 | MP-4 | 38.7 μSv/h | - | - | SSE | 0.3 | | | ○ | | | disc std uncertain |
| | 3:40 | MP-4 | 39.0 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:40 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 3:40 | Main Gate | 3.4 μSv/h | below 0.01μSv/h | - | SW | 1.2 | | | | | | |
| | 3:42 | MP-4 | 40.1 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:44 | MP-4 | 40.1 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:46 | MP-4 | 38.5 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|------|-----------|------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|
| | 3:48 | MP-4 | 38.4 μSv/h | - | - | SSE | 0.5 | | | ○ | | | disc std uncertain |
| | 3:50 | MP-4 | 38.4 μSv/h | - | - | SSE | 0.5 | | | ○ | | | disc std uncertain |
| | 3:50 | MP-8 | 5.1 μSv/h | - | - | - | - | | | | | | |
| | 3:50 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | S | 0.8 | | | | | | |
| | 3:52 | MP-4 | 38.3 μSv/h | - | - | SSE | 0.5 | | | ○ | | | disc std uncertain |
| | 3:54 | MP-4 | 38.3 μSv/h | - | - | SSE | 0.5 | | | ○ | | | disc std uncertain |
| | 3:56 | MP-4 | 38.2 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 3:58 | MP-4 | 38.3 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:00 | MP-4 | 38.2 μSv/h | - | - | SSE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:00 | MP-8 | 5.2 μSv/h | - | - | - | - | | | | | | |
| | 4:00 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | SE | 1.2 | | | | | | |
| | 4:02 | MP-4 | 38.1 μSv/h | - | - | SE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:04 | MP-4 | 38.1 μSv/h | - | - | ESE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:06 | MP-4 | 38.1 μSv/h | - | - | ESE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:08 | MP-4 | 38.1 μSv/h | - | - | ESE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:10 | MP-4 | 38.0 μSv/h | - | - | E | 0.4 | | | ○ | | | disc std uncertain |
| | 4:10 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 4:10 | Main Gate | 3.6 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 4:12 | MP-4 | 37.9 μSv/h | - | - | E | 0.4 | | | ○ | | | disc std uncertain |
| | 4:14 | MP-4 | 39.3 μSv/h | - | - | E | 0.4 | | | ○ | | | disc std uncertain |
| | 4:16 | MP-4 | 39.4 μSv/h | - | - | E | 0.4 | | | ○ | | | disc std uncertain |
| | 4:18 | MP-4 | 38.2 μSv/h | - | - | ENE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:20 | MP-4 | 37.8 μSv/h | - | - | ENE | 0.4 | | | ○ | | | disc std uncertain |
| | 4:20 | MP-8 | 5.5 μSv/h | - | - | - | - | | | | | | |
| | 4:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | SSW | 1.3 | | | | | | |
| | 4:22 | MP-4 | 37.8 μSv/h | - | - | NE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:24 | MP-4 | 37.7 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:26 | MP-4 | 37.7 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:28 | MP-4 | 37.6 μSv/h | - | - | SE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:30 | MP-4 | 37.6 μSv/h | - | - | WSW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:30 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 4:30 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | - | S | 0.6 | | | | | | |
| | 4:32 | MP-4 | 37.6 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 4:34 | MP-4 | 37.5 μSv/h | - | - | NNE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:36 | MP-4 | 37.4 μSv/h | - | - | N | 0.4 | | | ○ | | | disc std uncertain |
| | 4:38 | MP-4 | 37.4 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 4:40 | MP-4 | 37.4 μSv/h | - | - | N | 0.3 | | | ○ | | | disc std uncertain |
| | 4:40 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 4:40 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | W | 1.2 | | | | | | |
| | 4:42 | MP-4 | 37.3 μSv/h | - | - | ESE | 0.3 | | | ○ | | | disc std uncertain |
| | 4:44 | MP-4 | 38.2 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:46 | MP-4 | 38.5 μSv/h | - | - | NNW | 0.2 | | | ○ | | | disc std uncertain |
| | 4:48 | MP-4 | 38.7 μSv/h | - | - | NNW | 0.2 | | | ○ | | | disc std uncertain |
| | 4:50 | MP-4 | 37.2 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:50 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 4:50 | Main Gate | 3.1 μSv/h | below 0.01μSv/h | Fine | NNE | 0.7 | | | | | | |
| | 4:52 | MP-4 | 37.2 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:54 | MP-4 | 37.1 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:56 | MP-4 | 37.0 μSv/h | - | - | NW | 0.3 | | | ○ | | | disc std uncertain |
| | 4:58 | MP-4 | 37.0 μSv/h | - | - | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 5:00 | MP-4 | 37.0 μSv/h | - | - | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 5:00 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 5:00 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | N | 0.8 | | | | | | |
| | 5:02 | MP-4 | 36.9 μSv/h | - | - | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 5:04 | MP-4 | 36.9 μSv/h | - | - | W | 0.5 | | | ○ | | | disc std uncertain |
| | 5:06 | MP-4 | 37.0 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:08 | MP-4 | 37.1 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:10 | MP-4 | 37.2 μSv/h | - | - | SW | 0.7 | | | ○ | | | disc std uncertain |
| | 5:10 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 5:10 | Main Gate | 3.4 μSv/h | below 0.01μSv/h | - | N | 0.7 | | | | | | |
| | 5:12 | MP-4 | 37.1 μSv/h | - | - | SSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:14 | MP-4 | 37.5 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:16 | MP-4 | 37.0 μSv/h | - | - | W | 0.7 | | | ○ | | | disc std uncertain |
| | 5:18 | MP-4 | 38.0 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:20 | MP-4 | 38.1 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:20 | MP-8 | 4.6 μSv/h | - | - | - | - | | | | | | |
| | 5:20 | Main Gate | 3.5 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 5:22 | MP-4 | 38.3 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:24 | MP-4 | 38.1 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:26 | MP-4 | 37.7 μSv/h | - | - | SSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:28 | MP-4 | 37.7 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:30 | MP-4 | 37.8 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 5:30 | MP-8 | 5.0 μSv/h | - | - | - | - | | | | | | |
| | 5:30 | Main Gate | 3.8 μSv/h | 0.02 μSv/h | - | NW | 0.6 | | | | | | |
| | 5:32 | MP-4 | 37.1 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 5:34 | MP-4 | 36.6 μSv/h | - | - | W | 0.7 | | | ○ | | | disc std uncertain |
| | 5:36 | MP-4 | 36.7 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:38 | MP-4 | 36.5 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:40 | MP-4 | 36.4 μSv/h | - | - | SW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:40 | MP-8 | 4.5 μSv/h | - | - | - | - | | | | | | |
| | 5:40 | Main Gate | 3.2 μSv/h | 0.02 μSv/h | - | W | 0.6 | | | | | | |
| | 5:42 | MP-4 | 36.4 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:44 | MP-4 | 36.4 μSv/h | - | - | SW | 0.7 | | | ○ | | | disc std uncertain |
| | 5:46 | MP-4 | 36.3 μSv/h | - | - | WSW | 0.7 | | | ○ | | | disc std uncertain |
| | 5:48 | MP-4 | 36.3 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 5:50 | MP-4 | 36.3 μSv/h | - | - | WSW | 0.5 | | | ○ | | | disc std uncertain |
| | 5:50 | MP-8 | 5.2 μSv/h | - | - | - | - | | | | | | |
| | 5:50 | Main Gate | 3.2 μSv/h | 0.01 μSv/h | - | SE | 0.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|------|-----------|------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------------------|
| | 5:52 | MP-4 | 36.2 μSv/h | - | - | WSW | 0.5 | | | ○ | | | disc std uncertain |
| | 5:54 | MP-4 | 36.2 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:56 | MP-4 | 36.2 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 5:58 | MP-4 | 36.2 μSv/h | - | - | WSW | 0.6 | | | ○ | | | disc std uncertain |
| | 6:00 | MP-4 | 36.7 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 6:00 | MP-8 | 5.6 μSv/h | - | - | - | - | | | | | | |
| | 6:00 | Main Gate | 3.5 μSv/h | below 0.01μSv/h | - | S | 0.6 | | | | | | |
| | 6:02 | MP-4 | 37.9 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 6:04 | MP-4 | 37.7 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 6:06 | MP-4 | 36.1 μSv/h | - | - | W | 0.6 | | | ○ | | | disc std uncertain |
| | 6:08 | MP-4 | 36.0 μSv/h | - | - | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 6:10 | MP-4 | 36.0 μSv/h | - | - | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 6:10 | MP-8 | 5.9 μSv/h | - | - | - | - | | | | | | |
| | 6:10 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | S | 0.9 | | | | | | |
| | 6:12 | MP-4 | 36.0 μSv/h | - | - | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 6:14 | MP-4 | 35.9 μSv/h | - | - | WNW | 0.5 | | | ○ | | | disc std uncertain |
| | 6:16 | MP-4 | 36.0 μSv/h | - | - | WNW | 0.6 | | | ○ | | | disc std uncertain |
| | 6:18 | MP-4 | 36.0 μSv/h | - | - | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 6:20 | MP-4 | 35.9 μSv/h | - | - | W | 0.7 | | | ○ | | | disc std uncertain |
| | 6:20 | MP-8 | 5.7 μSv/h | - | - | - | - | | | | | | |
| | 6:20 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 6:22 | MP-4 | 35.8 μSv/h | - | - | W | 0.7 | | | ○ | | | disc std uncertain |
| | 6:24 | MP-4 | 35.8 μSv/h | - | - | WNW | 0.6 | | | ○ | | | disc std uncertain |
| | 6:26 | MP-4 | 35.7 μSv/h | - | - | W | 0.5 | | | ○ | | | disc std uncertain |
| | 6:28 | MP-4 | 35.6 μSv/h | - | - | W | 0.4 | | | ○ | | | disc std uncertain |
| | 6:30 | MP-4 | 35.7 μSv/h | - | - | W | 0.3 | | | ○ | | | disc std uncertain |
| | 6:30 | MP-8 | 5.7 μSv/h | - | - | - | - | | | | | | |
| | 6:30 | Main Gate | 3.6 μSv/h | 0.02 μSv/h | - | SSW | 0.9 | | | | | | |
| | 6:32 | MP-4 | 35.7 μSv/h | - | - | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 6:34 | MP-4 | 35.6 μSv/h | - | - | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 6:36 | MP-4 | 35.5 μSv/h | - | - | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 6:38 | MP-4 | 36.8 μSv/h | - | - | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 6:40 | MP-4 | 37.2 μSv/h | - | - | SW | 0.5 | | | ○ | | | disc std uncertain |
| | 6:40 | MP-8 | 5.7 μSv/h | - | - | - | - | | | | | | |
| | 6:40 | Main Gate | 3.1 μSv/h | 0.01 μSv/h | - | W | 0.8 | | | | | | |
| | 6:42 | MP-4 | 37.3 μSv/h | - | - | N | 0.5 | | | ○ | | | disc std uncertain |
| | 6:44 | MP-4 | 35.3 μSv/h | - | - | ENE | 0.6 | | | ○ | | | disc std uncertain |
| | 6:46 | MP-4 | 35.3 μSv/h | - | - | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 6:48 | MP-4 | 35.4 μSv/h | - | - | NNW | 0.6 | | | ○ | | | disc std uncertain |
| | 6:50 | MP-4 | 35.4 μSv/h | - | - | NW | 0.7 | | | ○ | | | disc std uncertain |
| | 6:50 | MP-8 | 5.7 μSv/h | - | - | - | - | | | | | | |
| | 6:50 | Main Gate | 3.0 μSv/h | below 0.01μSv/h | - | SSW | 1.3 | | | | | | |
| | 6:52 | MP-4 | 35.5 μSv/h | - | - | N | 0.7 | | | ○ | | | disc std uncertain |
| | 6:54 | MP-4 | 35.9 μSv/h | - | - | NNE | 0.6 | | | ○ | | | disc std uncertain |
| | 6:56 | MP-4 | 35.8 μSv/h | - | - | NE | 0.6 | | | ○ | | | disc std uncertain |
| | 6:58 | MP-4 | 35.7 μSv/h | - | - | ENE | 0.5 | | | ○ | | | disc std uncertain |
| | 7:00 | MP-4 | 35.7 μSv/h | - | - | ENE | 0.4 | | | ○ | | | disc std uncertain |
| | 7:00 | MP-8 | 7.7 μSv/h | - | - | - | - | | | | | | |
| | 7:00 | Main Gate | 3.7 μSv/h | below 0.01μSv/h | - | WNW | 1.6 | | | | | | |
| | 7:02 | MP-4 | 35.5 μSv/h | - | - | NE | 0.4 | | | ○ | | | disc std uncertain |
| | 7:04 | MP-4 | 35.6 μSv/h | - | - | E | 0.3 | | | ○ | | | disc std uncertain |
| | 7:06 | MP-4 | 36.1 μSv/h | - | - | NNW | 0.3 | | | ○ | | | disc std uncertain |
| | 7:08 | MP-4 | 37.1 μSv/h | - | - | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:10 | MP-4 | 37.0 μSv/h | - | - | NW | 0.5 | | ○ | | | | HQ not received |
| | 7:10 | MP-8 | 8.5 μSv/h | - | - | - | - | | | | | | |
| | 7:10 | Main Gate | 3.4 μSv/h | 0.01 μSv/h | - | N | 0.9 | | | | | | |
| | 7:12 | MP-4 | 36.9 μSv/h | - | - | NW | 0.5 | | ○ | | | | HQ not received |
| | 7:14 | MP-4 | 36.8 μSv/h | - | - | WNW | 0.7 | | ○ | | | | HQ not received |
| | 7:16 | MP-4 | 36.8 μSv/h | - | - | WNW | 0.6 | | ○ | | | | HQ not received |
| | 7:20 | MP-8 | 6.0 μSv/h | - | - | - | - | | | | | | |
| | 7:20 | Main Gate | 3.3 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 7:23 | MP-4 | 36.6 μSv/h | - | Fine | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 7:25 | MP-4 | 37.0 μSv/h | - | Fine | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 7:27 | MP-4 | 35.0 μSv/h | - | Fine | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 7:29 | MP-4 | 34.9 μSv/h | - | Fine | WNW | 0.7 | | | ○ | | | disc std uncertain |
| | 7:30 | MP-8 | 5.6 μSv/h | - | - | - | - | | | | | | |
| | 7:30 | Main Gate | 3.5 μSv/h | below 0.01μSv/h | - | WSW | 0.9 | | | | | | |
| | 7:31 | MP-4 | 34.9 μSv/h | - | Fine | NW | 0.6 | | | ○ | | | disc std uncertain |
| | 7:33 | MP-4 | 34.9 μSv/h | - | Fine | NW | 0.5 | | | ○ | | | disc std uncertain |
| | 7:35 | MP-4 | 35.0 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 7:37 | MP-4 | 34.9 μSv/h | - | Fine | NNW | 0.5 | | | ○ | | | disc std uncertain |
| | 7:39 | MP-4 | 34.9 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:40 | Main Gate | 3.4 μSv/h | 0.01 μSv/h | - | NW | 0.9 | | | | | | |
| | 7:41 | MP-4 | 34.9 μSv/h | - | Fine | ENE | 0.4 | | | ○ | | | disc std uncertain |
| | 7:43 | MP-4 | 34.8 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:45 | MP-4 | 34.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:47 | MP-4 | 34.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:49 | MP-4 | 34.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:50 | Main Gate | 7.2 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 7:51 | MP-4 | 34.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:53 | MP-4 | 34.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:55 | MP-4 | 35.8 μSv/h | - | Fine | NW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:57 | MP-4 | 36.4 μSv/h | - | Fine | WNW | 0.4 | | | ○ | | | disc std uncertain |
| | 7:59 | MP-4 | 34.9 μSv/h | - | Fine | W | 0.4 | | | ○ | | | disc std uncertain |
| | 8:00 | Main Gate | 3.5 μSv/h | 0.01 μSv/h | - | S | 0.4 | | | | | | |
| | 8:01 | MP-4 | 34.9 μSv/h | - | Fine | WNW | 0.3 | | | ○ | | | disc std uncertain |
| | 8:03 | MP-4 | 35.0 μSv/h | - | Fine | W | 0.3 | | | ○ | | | disc std uncertain |
| | 8:05 | MP-4 | 35.0 μSv/h | - | Fine | W | 0.3 | | | ○ | | | disc std uncertain |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason | |
|----------------------|-----------|------------|-----------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------------------|--------------------|
| | 8:07 | MP-4 | 35.0 μSv/h | - | Fine | SW | 0.3 | | | ○ | | | disc std uncertain | |
| | 8:09 | MP-4 | 35.3 μSv/h | - | Fine | SSW | 0.3 | | | ○ | | | disc std uncertain | |
| | 8:10 | MP-1 | 100 μSv/h | - | - | - | - | | | | | | | |
| | 8:10 | Main Gate | 3.2 μSv/h | below 0.01μSv/h | - | E | 0.5 | | | | | | | |
| | 8:11 | MP-4 | 36.0 μSv/h | - | Fine | SSW | 0.3 | | | ○ | | | disc std uncertain | |
| | 8:13 | MP-4 | 41.4 μSv/h | - | Fine | SSE | 0.2 | | | ○ | | | disc std uncertain | |
| | 8:15 | MP-4 | 66.6 μSv/h | - | Fine | SE | 0.2 | | | ○ | | | disc std uncertain | |
| | 8:17 | MP-4 | 135.5 μSv/h | - | Fine | SE | 0.2 | | | ○ | | | disc std uncertain | |
| | 8:19 | MP-4 | 347.5 μSv/h | - | Fine | SE | 0.2 | | | ○ | | | disc std uncertain | |
| | 8:20 | MP-1 | 100 μSv/h | - | - | - | - | | | | | | | |
| | 8:20 | Main Gate | 5.9 μSv/h | below 0.01μSv/h | - | E | 0.7 | | | | | | | |
| Article 15-33 notice | 8:21 | MP-4 | 698.2 μSv/h | - | Fine | SE | 0.2 | | ○ | | | | HQ not received | |
| | 8:23 | MP-4 | 882.2 μSv/h | - | Fine | SSW | 0.2 | | ○ | | | | HQ not received | |
| | 8:25 | MP-4 | 864.2 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | HQ not received | |
| | 8:27 | MP-4 | 1124.3 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | HQ not received | |
| | 8:29 | MP-4 | 1038.2 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | HQ not received | |
| | 8:30 | MP-1 | 80 μSv/h | - | - | - | - | | | | | | | |
| | 8:30 | Main Gate | 14.7 μSv/h | below 0.01μSv/h | - | SSE | 1.6 | | | | | | | |
| | 8:31 | MP-4 | 1144.1 μSv/h | - | Fine | WSW | 0.4 | | ○ | | | | | HQ not received |
| | 8:33 | MP-4 | 1204.2 μSv/h | - | Fine | WSW | 0.4 | | ○ | | | | | HQ not received |
| | 8:35 | MP-4 | 1153.6 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | | HQ not received |
| | 8:37 | MP-4 | 717.7 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | | HQ not received |
| | 8:39 | MP-4 | 554.1 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | | HQ not received |
| | 8:40 | MP-1 | 80 μSv/h | - | - | - | - | | | | | | | |
| | 8:40 | Main Gate | 16.0 μSv/h | 0.01 μSv/h | - | SE | 1.4 | | | | | | | |
| | 8:41 | MP-4 | 307.8 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | | HQ not received |
| | 8:43 | MP-4 | 197.7 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | | HQ not received |
| | 8:45 | MP-4 | 186.2 μSv/h | - | Fine | SW | 0.4 | | ○ | | | | | HQ not received |
| | 8:47 | MP-4 | 261.9 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | | HQ not received |
| | 8:49 | MP-4 | 473.1 μSv/h | - | Fine | SW | 0.3 | | ○ | | | | | HQ not received |
| | 8:50 | MP-1 | 90 μSv/h | - | - | - | - | | | | | | | |
| | 8:50 | Main Gate | 15.9 μSv/h | below 0.01μSv/h | - | SE | 2.0 | | | | | | | |
| | 8:51 | MP-4 | 679.8 μSv/h | - | Fine | SE | 0.4 | | | ○ | | | | disc std uncertain |
| | 8:58 | MP-4 | 221.3 μSv/h | - | Fine | NNW | 0.4 | | | ○ | | | | disc std uncertain |
| | 9:00 | MP-1 | 37 μSv/h | - | - | - | - | | | | | | | |
| | 9:00 | MP-4 | 143.5 μSv/h | - | Fine | ENE | 0.5 | | | | | | | |
| | 9:00 | Main Gate | 10.2 μSv/h | below 0.01μSv/h | - | SSE | 2.4 | | | | | | | |
| | 9:02 | MP-4 | 108.5 μSv/h | - | Fine | ENE | 0.6 | | | | ○ | | | |
| | 9:04 | MP-4 | 97.4 μSv/h | - | Fine | E | 0.7 | | | | ○ | | | |
| | 9:06 | MP-4 | 88.7 μSv/h | - | Fine | ENE | 0.7 | | | | ○ | | | |
| | 9:08 | MP-4 | 101.8 μSv/h | - | Fine | S | 0.9 | | | | ○ | | | |
| | 9:10 | MP-1 | 30 μSv/h | - | - | - | - | | | | | | | |
| | 9:10 | MP-4 | 137.8 μSv/h | - | Fine | WNW | 0.8 | | | | | | | |
| | 9:10 | Main Gate | 175.0 μSv/h | below 0.01μSv/h | - | E | 1.5 | | | | | | | |
| | 9:12 | MP-4 | 193.2 μSv/h | - | Fine | WNW | 0.9 | | | | ○ | | | |
| | 9:14 | MP-4 | 199.5 μSv/h | - | Fine | NW | 1.1 | | | | ○ | | | |
| | 9:16 | MP-4 | 187.3 μSv/h | - | Fine | NW | 1.3 | | | | ○ | | | |
| | 9:18 | MP-4 | 124.5 μSv/h | - | Fine | W | 1.4 | | | | ○ | | | |
| | 9:20 | MP-1 | 27 μSv/h | - | - | - | - | | | | | | | |
| | 9:20 | MP-4 | 76.9 μSv/h | - | Fine | WNW | 1.8 | | | | | | | |
| | 9:20 | Main Gate | 281.7 μSv/h | below 0.01μSv/h | - | SSW | 1.4 | | | | | | | |
| 9:22 | MP-4 | 75.3 μSv/h | - | Fine | NW | 2.1 | | | | ○ | | | | |
| 9:24 | MP-4 | 73.8 μSv/h | - | Fine | WNW | 2.0 | | | | ○ | | | | |
| 9:26 | MP-4 | 72.3 μSv/h | - | Fine | NW | 1.9 | | | | ○ | | | | |
| 9:28 | MP-4 | 71.2 μSv/h | - | Fine | NW | 1.9 | | | | ○ | | | | |
| 9:30 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | | | |
| 9:30 | MP-4 | 70.3 μSv/h | - | Fine | NW | 1.8 | | | | | | | | |
| 9:30 | Main Gate | 26.0 μSv/h | 0.01 μSv/h | - | N | 1.5 | | | | | | | | |
| 9:32 | MP-4 | 69.4 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | | | |
| 9:34 | MP-4 | 68.6 μSv/h | - | Fine | NW | 1.8 | | | | ○ | | | | |
| 9:36 | MP-4 | 69.5 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | | | |
| 9:38 | MP-4 | 68.3 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | | | |
| 9:40 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | | | |
| 9:40 | MP-4 | 66.8 μSv/h | - | Fine | NW | 2.3 | | | | | | | | |
| 9:42 | MP-4 | 66.3 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | | | |
| 9:44 | MP-4 | 65.8 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 9:46 | MP-4 | 65.4 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 9:48 | MP-4 | 65.0 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 9:50 | MP-1 | 23 μSv/h | - | - | - | - | | | | | | | | |
| 9:50 | MP-4 | 64.7 μSv/h | - | Fine | NW | 2.7 | | | | | | | | |
| 9:52 | MP-4 | 64.3 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | | | |
| 9:54 | MP-4 | 63.9 μSv/h | - | Fine | NW | 2.6 | | | | ○ | | | | |
| 9:56 | MP-4 | 63.5 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | | | |
| 9:58 | MP-4 | 63.2 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 10:00 | MP-1 | 23 μSv/h | - | - | - | - | | | | | | | | |
| 10:00 | MP-4 | 62.9 μSv/h | - | Fine | NW | 2.6 | | | | | | | | |
| 10:00 | Main Gate | 6.5 μSv/h | below 0.01μSv/h | - | NW | 3.1 | | | | | | | | |
| 10:02 | MP-4 | 62.5 μSv/h | - | Fine | NW | 2.5 | | | | ○ | | | | |
| 10:04 | MP-4 | 62.1 μSv/h | - | Fine | NNW | 2.8 | | | | ○ | | | | |
| 10:06 | MP-4 | 61.8 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 10:08 | MP-4 | 61.4 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 10:10 | MP-1 | 23 μSv/h | - | - | - | - | | | | | | | | |
| 10:10 | MP-4 | 61.1 μSv/h | - | Fine | NW | 2.9 | | | | | | | | |
| 10:10 | Main Gate | 6.4 μSv/h | below 0.01μSv/h | - | NW | 3.2 | | | | | | | | |
| 10:12 | MP-4 | 60.8 μSv/h | - | Fine | NW | 3.0 | | | | ○ | | | | |
| 10:14 | MP-4 | 60.6 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | | | |
| 10:16 | MP-4 | 60.3 μSv/h | - | Fine | NW | 2.5 | | | | ○ | | | | |
| 10:18 | MP-4 | 61.5 μSv/h | - | Fine | NW | 2.4 | | | | ○ | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 10:20 | MP-1 | 20 μSv/h | - | - | - | - | | | | | | |
| | 10:20 | MP-4 | 61.8 μSv/h | - | Fine | NW | 2.3 | | | | | | |
| | 10:20 | Main Gate | 8.3 μSv/h | below 0.01μSv/h | - | NNW | 4.2 | | | | | | |
| | 10:22 | MP-4 | 59.3 μSv/h | - | Fine | NW | 2.1 | | | | ○ | | |
| | 10:24 | MP-4 | 59.1 μSv/h | - | Fine | NW | 2.1 | | | | ○ | | |
| | 10:26 | MP-4 | 58.8 μSv/h | - | Fine | NW | 2.2 | | | | ○ | | |
| | 10:28 | MP-4 | 58.4 μSv/h | - | Fine | NW | 2.3 | | | | ○ | | |
| | 10:30 | MP-1 | 19 μSv/h | - | - | - | - | | | | | | |
| | 10:30 | MP-4 | 58.0 μSv/h | - | Fine | NW | 2.4 | | | | | | |
| | 10:30 | Main Gate | 6.8 μSv/h | below 0.01μSv/h | - | N | 2.8 | | | | | | |
| | 10:32 | MP-4 | 57.7 μSv/h | - | Fine | NW | 2.6 | | | | ○ | | |
| | 10:34 | MP-4 | 57.5 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 10:36 | MP-4 | 57.3 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 10:38 | MP-4 | 57.1 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 10:40 | MP-1 | 19 μSv/h | - | - | - | - | | | | | | |
| | 10:40 | MP-4 | 56.8 μSv/h | - | Fine | NW | 2.8 | | | | | | |
| | 10:40 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | N | 3.3 | | | | | | |
| | 10:42 | MP-4 | 56.4 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 10:44 | MP-4 | 56.2 μSv/h | - | Fine | NW | 3.0 | | | | ○ | | |
| | 10:46 | MP-4 | 55.9 μSv/h | - | Fine | WNW | 3.1 | | | | ○ | | |
| | 10:48 | MP-4 | 55.8 μSv/h | - | Fine | NW | 3.0 | | | | ○ | | |
| | 10:50 | MP-1 | 19 μSv/h | - | - | - | - | | | | | | |
| | 10:50 | MP-4 | 55.5 μSv/h | - | Fine | NW | 2.7 | | | | | | |
| | 10:50 | Main Gate | 6.0 μSv/h | 0.02 μSv/h | - | NNW | 3.3 | | | | | | |
| | 10:52 | MP-4 | 55.3 μSv/h | - | Fine | NW | 2.6 | | | | ○ | | |
| | 10:54 | MP-4 | 55.1 μSv/h | - | Fine | NW | 2.3 | | | | ○ | | |
| | 10:56 | MP-4 | 54.9 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | |
| | 10:58 | MP-4 | 54.7 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | |
| | 11:00 | MP-1 | 18 μSv/h | - | - | - | - | | | | | | |
| | 11:00 | MP-4 | 54.3 μSv/h | - | Fine | NW | 2.2 | | | | | | |
| | 11:00 | Main Gate | 5.8 μSv/h | below 0.01μSv/h | - | SE | 3.3 | | | | | | |
| | 11:02 | MP-4 | 54.1 μSv/h | - | Fine | NNW | 2.2 | | | | ○ | | |
| | 11:04 | MP-4 | 53.9 μSv/h | - | Fine | NNW | 2.2 | | | | ○ | | |
| | 11:06 | MP-4 | 53.7 μSv/h | - | Fine | NNW | 2.3 | | | | ○ | | |
| | 11:08 | MP-4 | 53.5 μSv/h | - | Fine | NNW | 2.4 | | | | ○ | | |
| | 11:10 | MP-1 | 18 μSv/h | - | - | - | - | | | | | | |
| | 11:10 | MP-4 | 53.3 μSv/h | - | Fine | NNW | 2.3 | | | | | | |
| | 11:10 | Main Gate | 5.6 μSv/h | below 0.01μSv/h | - | S | 2.4 | | | | | | |
| | 11:12 | MP-4 | 53.1 μSv/h | - | Fine | NW | 2.3 | | | | ○ | | |
| | 11:14 | MP-4 | 52.8 μSv/h | - | Fine | NW | 2.4 | | | | ○ | | |
| | 11:16 | MP-4 | 52.6 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 11:18 | MP-4 | 52.8 μSv/h | - | Fine | NW | 2.6 | | | | ○ | | |
| | 11:20 | MP-1 | 18 μSv/h | - | - | - | - | | | | | | |
| | 11:20 | MP-4 | 53.7 μSv/h | - | Fine | WNW | 2.5 | | | | | | |
| | 11:20 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | NW | 2.8 | | | | | | |
| | 11:22 | MP-4 | 52.7 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 11:24 | MP-4 | 51.8 μSv/h | - | Fine | WNW | 2.4 | | | | ○ | | |
| | 11:26 | MP-4 | 51.5 μSv/h | - | Fine | NW | 2.1 | | | | ○ | | |
| | 11:28 | MP-4 | 51.5 μSv/h | - | Fine | NW | 2.1 | | | | ○ | | |
| | 11:30 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 11:30 | MP-4 | 51.3 μSv/h | - | Fine | NW | 2.1 | | | | | | |
| | 11:30 | Main Gate | 7.9 μSv/h | below 0.01μSv/h | - | NW | 2.7 | | | | | | |
| | 11:32 | MP-4 | 51.1 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | |
| | 11:34 | MP-4 | 50.8 μSv/h | - | Fine | NW | 2.2 | | | | ○ | | |
| | 11:36 | MP-4 | 50.6 μSv/h | - | Fine | WNW | 2.4 | | | | ○ | | |
| | 11:38 | MP-4 | 50.3 μSv/h | - | Fine | WNW | 2.7 | | | | ○ | | |
| | 11:40 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 11:40 | MP-4 | 50.0 μSv/h | - | Fine | WNW | 3.1 | | | | | | |
| | 11:40 | Main Gate | 6.8 μSv/h | below 0.01μSv/h | - | W | 2.7 | | | | | | |
| | 11:42 | MP-4 | 49.9 μSv/h | - | Fine | NW | 3.3 | | | | ○ | | |
| | 11:44 | MP-4 | 49.7 μSv/h | - | Fine | NW | 3.2 | | | | ○ | | |
| | 11:46 | MP-4 | 49.6 μSv/h | - | Fine | NW | 3.1 | | | | ○ | | |
| | 11:48 | MP-4 | 49.6 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 11:50 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 11:50 | MP-4 | 49.4 μSv/h | - | Fine | NW | 2.4 | | | | | | |
| | 11:50 | Main Gate | 6.6 μSv/h | below 0.01μSv/h | - | NNW | 2.5 | | | | | | |
| | 11:52 | MP-4 | 49.2 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | |
| | 11:54 | MP-4 | 49.0 μSv/h | - | Fine | NNW | 1.8 | | | | ○ | | |
| | 11:56 | MP-4 | 48.8 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | |
| | 11:58 | MP-4 | 48.7 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | |
| | 0:00 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 0:00 | MP-4 | 48.6 μSv/h | - | Fine | NNW | 1.6 | | | | | | |
| | 0:00 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | E | 2.4 | | | | | | |
| | 0:02 | MP-4 | 48.5 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | |
| | 0:04 | MP-4 | 48.3 μSv/h | - | Fine | NW | 1.4 | | | | ○ | | |
| | 0:06 | MP-4 | 48.1 μSv/h | - | Fine | NW | 1.3 | | | | ○ | | |
| | 0:08 | MP-4 | 47.9 μSv/h | - | Fine | NW | 1.3 | | | | ○ | | |
| | 0:10 | MP-1 | 18 μSv/h | - | - | - | - | | | | | | |
| | 0:10 | MP-4 | 47.8 μSv/h | - | Fine | NW | 1.4 | | | | | | |
| | 0:10 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | W | 2.2 | | | | | | |
| | 0:12 | MP-4 | 47.6 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | |
| | 0:14 | MP-4 | 47.5 μSv/h | - | Fine | NW | 2.0 | | | | ○ | | |
| | 0:16 | MP-4 | 47.4 μSv/h | - | Fine | NW | 2.2 | | | | ○ | | |
| | 0:18 | MP-4 | 47.2 μSv/h | - | Fine | NW | 2.4 | | | | ○ | | |
| | 0:20 | MP-1 | 18 μSv/h | - | - | - | - | | | | | | |
| | 0:20 | MP-4 | 47.1 μSv/h | - | Fine | NW | 2.6 | | | | | | |
| | 0:20 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | S | 2.1 | | | | | | |
| | 0:22 | MP-4 | 48.1 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|----------------------|-------|-----------|--------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 0:24 | MP-4 | 48.3 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 0:26 | MP-4 | 46.7 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 0:28 | MP-4 | 46.5 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 0:30 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 0:30 | MP-4 | 46.3 μSv/h | - | Fine | NW | 2.8 | | | | | | |
| | 0:30 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | N | 2.0 | | | | | | |
| | 0:32 | MP-4 | 46.2 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 0:34 | MP-4 | 46.1 μSv/h | - | Fine | NW | 2.8 | | | | ○ | | |
| | 0:36 | MP-4 | 46.0 μSv/h | - | Fine | NW | 2.9 | | | | ○ | | |
| | 0:38 | MP-4 | 47.7 μSv/h | - | Fine | NW | 2.7 | | | | ○ | | |
| | 0:40 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 0:40 | MP-4 | 49.7 μSv/h | - | Fine | NW | 2.7 | | | | | | |
| | 0:40 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | SSW | 2.1 | | | | | | |
| | 0:42 | MP-4 | 45.9 μSv/h | - | Fine | NW | 2.6 | | | | ○ | | |
| | 0:44 | MP-4 | 46.0 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 0:46 | MP-4 | 48.6 μSv/h | - | Fine | NW | 2.4 | | | | ○ | | |
| | 0:48 | MP-4 | 45.3 μSv/h | - | Fine | NNW | 2.2 | | | | ○ | | |
| | 0:50 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 0:50 | MP-4 | 45.2 μSv/h | - | Fine | NNW | 1.9 | | | | | | |
| | 0:50 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | W | 2.1 | | | | | | |
| | 0:52 | MP-4 | 45.0 μSv/h | - | Fine | NNW | 1.7 | | | | ○ | | |
| | 0:54 | MP-4 | 44.9 μSv/h | - | Fine | NW | 1.7 | | | | ○ | | |
| | 0:56 | MP-4 | 44.8 μSv/h | - | Fine | WNW | 1.9 | | | | ○ | | |
| | 0:58 | MP-4 | 44.7 μSv/h | - | Fine | WNW | 2.2 | | | | ○ | | |
| | 13:00 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 13:00 | MP-4 | 44.6 μSv/h | - | Fine | WNW | 2.3 | | | | | | |
| | 13:00 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | NW | 2.2 | | | | | | |
| | 13:02 | MP-4 | 44.5 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:04 | MP-4 | 44.4 μSv/h | - | Fine | WNW | 2.6 | | | | ○ | | |
| | 13:06 | MP-4 | 44.3 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:08 | MP-4 | 44.2 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:10 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 13:10 | MP-4 | 44.0 μSv/h | - | Fine | WNW | 2.6 | | | | | | |
| | 13:10 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | SSW | 2.6 | | | | | | |
| | 13:12 | MP-4 | 44.0 μSv/h | - | Fine | WNW | 2.6 | | | | ○ | | |
| | 13:14 | MP-4 | 43.8 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:16 | MP-4 | 43.7 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:18 | MP-4 | 43.6 μSv/h | - | Fine | WNW | 2.5 | | | | ○ | | |
| | 13:20 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | S | 2.7 | | | | | | |
| | 13:20 | MP-1 | 17 μSv/h | - | - | - | - | | | | | | |
| | 13:20 | MP-4 | 43.5 μSv/h | - | Fine | WNW | 2.5 | | | | | | |
| | 13:22 | MP-4 | 43.5 μSv/h | - | Fine | WNW | 2.3 | | | | ○ | | |
| | 13:24 | MP-4 | 43.3 μSv/h | - | Fine | W | 2.1 | | | | ○ | | |
| | 13:26 | MP-4 | 43.1 μSv/h | - | Fine | W | 2.0 | | | | ○ | | |
| | 13:28 | MP-4 | 43.0 μSv/h | - | Fine | WNW | 1.9 | | | | ○ | | |
| | 13:30 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | SW | 1.6 | | | | | | |
| | 13:30 | MP-1 | 16 μSv/h | - | - | - | - | | | | | | |
| | 13:30 | MP-4 | 42.9 μSv/h | - | Fine | WNW | 1.7 | | | | | | |
| | 13:32 | MP-4 | 42.8 μSv/h | - | Fine | WNW | 1.8 | | | | ○ | | |
| | 13:34 | MP-4 | 42.7 μSv/h | - | Fine | WNW | 1.9 | | | | ○ | | |
| | 13:36 | MP-4 | 42.7 μSv/h | - | Fine | WNW | 1.7 | | | | ○ | | |
| | 13:38 | MP-4 | 42.7 μSv/h | - | Fine | NW | 1.7 | | | | ○ | | |
| | 13:40 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | NNW | 2.2 | | | | | | |
| | 13:40 | MP-1 | 16 μSv/h | - | - | - | - | | | | | | |
| | 13:40 | MP-4 | 44.0 μSv/h | - | Fine | NW | 1.6 | | | | | | |
| | 13:42 | MP-4 | 50.2 μSv/h | - | Fine | NNW | 1.5 | | | | ○ | | |
| | 13:44 | MP-4 | 80.5 μSv/h | - | Fine | SSE | 1.3 | | | | ○ | | |
| | 13:46 | MP-4 | 97.9 μSv/h | - | Fine | NNE | 1.4 | | | | ○ | | |
| | 13:48 | MP-4 | 251.8 μSv/h | - | Fine | NE | 1.5 | | | | ○ | | |
| | 13:50 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | SE | 1.7 | | | | | | |
| | 13:50 | MP-1 | 24 μSv/h | - | - | - | - | | | | | | |
| Article 15 clause 38 | 13:50 | MP-4 | 905.1 μSv/h | - | Fine | ENE | 1.5 | | | | | | |
| | 13:52 | MP-4 | 1557.5 μSv/h | - | Fine | E | 1.3 | | | | ○ | | |
| | 13:54 | MP-4 | 829.7 μSv/h | - | Fine | ESE | 1.2 | | | | ○ | | |
| | 13:56 | MP-4 | 595.5 μSv/h | - | Fine | SE | 1.0 | | | | ○ | | |
| | 13:58 | MP-4 | 531.8 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:00 | Main Gate | 21.9 μSv/h | below 0.01μSv/h | - | S | 2.6 | | | | | | |
| | 14:00 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | |
| | 14:00 | MP-4 | 499.3 μSv/h | - | Fine | S | 0.6 | | | | | | |
| | 14:02 | MP-4 | 602.6 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 14:04 | MP-4 | 490.9 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:06 | MP-4 | 599.1 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:08 | MP-4 | 595.3 μSv/h | - | Fine | SE | 0.7 | | | | ○ | | |
| | 14:10 | Main Gate | 39.7 μSv/h | below 0.01μSv/h | - | SSE | 2.1 | | | | | | |
| | 14:10 | MP-1 | 21 μSv/h | - | - | - | - | | | | | | |
| | 14:10 | MP-4 | 646.0 μSv/h | - | Fine | ESE | 0.7 | | | | | | |
| | 14:12 | MP-4 | 547.3 μSv/h | - | Fine | ESE | 0.7 | | | | ○ | | |
| | 14:14 | MP-4 | 289.7 μSv/h | - | Fine | ESE | 0.6 | | | | ○ | | |
| | 14:16 | MP-4 | 170.6 μSv/h | - | Fine | SE | 0.6 | | | | ○ | | |
| | 14:18 | MP-4 | 154.3 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 14:20 | Main Gate | 57.6 μSv/h | below 0.01μSv/h | - | SSE | 2.5 | | | | | | |
| | 14:20 | MP-1 | 21 μSv/h | - | - | - | - | | | | | | |
| | 14:20 | MP-4 | 135.4 μSv/h | - | Fine | S | 0.6 | | | | | | |
| | 14:22 | MP-4 | 157.8 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 14:24 | MP-4 | 160.1 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 14:26 | MP-4 | 148.9 μSv/h | - | Fine | S | 0.6 | | | | ○ | | |
| | 14:28 | MP-4 | 137.9 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 14:30 | Main Gate | 17.6 μSv/h | below 0.01μSv/h | - | SSE | 2.2 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 14:30 | MP-1 | 32 μSv/h | - | - | - | - | | | | | | |
| | 14:30 | MP-4 | 129.9 μSv/h | - | Fine | SSE | 0.5 | | | | | | |
| | 14:32 | MP-4 | 113.5 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 14:34 | MP-4 | 117.2 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 14:36 | MP-4 | 115.0 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 14:38 | MP-4 | 112.2 μSv/h | - | Fine | SE | 0.6 | | | | ○ | | |
| | 14:40 | Main Gate | 10.1 μSv/h | below 0.01μSv/h | - | SE | 1.6 | | | | | | |
| | 14:40 | MP-1 | 52 μSv/h | - | - | - | - | | | | | | |
| | 14:40 | MP-4 | 133.0 μSv/h | - | Fine | SSE | 0.7 | | | | | | |
| | 14:42 | MP-4 | 184.1 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:44 | MP-4 | 179.8 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:46 | MP-4 | 176.5 μSv/h | - | Fine | SSE | 0.8 | | | | ○ | | |
| | 14:48 | MP-4 | 186.7 μSv/h | - | Fine | SSW | 0.8 | | | | ○ | | |
| | 14:50 | Main Gate | 10.9 μSv/h | below 0.01μSv/h | - | SSE | 2.0 | | | | | | |
| | 14:50 | MP-1 | 35 μSv/h | - | - | - | - | | | | | | |
| | 14:50 | MP-4 | 169.8 μSv/h | - | Fine | SW | 0.8 | | | | | | |
| | 14:52 | MP-4 | 156.9 μSv/h | - | Fine | E | 0.8 | | | | ○ | | |
| | 14:54 | MP-4 | 106.5 μSv/h | - | Fine | ESE | 0.8 | | | | ○ | | |
| | 14:56 | MP-4 | 73.3 μSv/h | - | Fine | SSE | 0.7 | | | | ○ | | |
| | 14:58 | MP-4 | 65.6 μSv/h | - | Fine | SE | 0.7 | | | | ○ | | |
| | 15:00 | Main Gate | 8.3 μSv/h | below 0.01μSv/h | - | SW | 1.3 | | | | | | |
| | 15:00 | MP-1 | 52 μSv/h | - | - | - | - | | | | | | |
| | 15:00 | MP-4 | 58.8 μSv/h | - | Fine | SSE | 0.8 | | | | | | |
| | 15:02 | MP-4 | 55.7 μSv/h | - | Fine | SW | 1.1 | | | | ○ | | |
| | 15:04 | MP-4 | 54.5 μSv/h | - | Fine | W | 1.4 | | | | ○ | | |
| | 15:06 | MP-4 | 54.2 μSv/h | - | Fine | WNW | 1.8 | | | | ○ | | |
| | 15:08 | MP-4 | 54.0 μSv/h | - | Fine | WNW | 2.1 | | | | ○ | | |
| | 15:10 | Main Gate | 5.7 μSv/h | below 0.01μSv/h | - | SSE | 1.6 | | | | | | |
| | 15:10 | MP-1 | 100 μSv/h | - | - | - | - | | | | | | |
| | 15:10 | MP-4 | 54.3 μSv/h | - | Fine | WNW | 2.3 | | | | | | |
| | 15:12 | MP-4 | 54.8 μSv/h | - | Fine | WNW | 2.1 | | | | ○ | | |
| | 15:14 | MP-4 | 54.8 μSv/h | - | Fine | WNW | 1.8 | | | | ○ | | |
| | 15:16 | MP-4 | 54.2 μSv/h | - | Fine | WNW | 1.6 | | | | ○ | | |
| | 15:18 | MP-4 | 53.8 μSv/h | - | Fine | WNW | 1.4 | | | | ○ | | |
| | 15:20 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | NNW | 1.9 | | | | | | |
| | 15:20 | MP-1 | 24 μSv/h | - | - | - | - | | | | | | |
| | 15:20 | MP-4 | 53.0 μSv/h | - | Fine | WNW | 1.1 | | | | | | |
| | 15:22 | MP-4 | 52.5 μSv/h | - | Fine | W | 1.3 | | | | ○ | | |
| | 15:24 | MP-4 | 52.3 μSv/h | - | Fine | WNW | 1.6 | | | | ○ | | |
| | 15:26 | MP-4 | 52.1 μSv/h | - | Fine | WNW | 1.8 | | | | ○ | | |
| | 15:28 | MP-4 | 51.9 μSv/h | - | Fine | WNW | 2.0 | | | | ○ | | |
| | 15:30 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | NW | 2.0 | | | | | | |
| | 15:30 | MP-1 | 34 μSv/h | - | - | - | - | | | | | | |
| | 15:30 | MP-4 | 51.8 μSv/h | - | Fine | NW | 2.1 | | | | | | |
| | 15:32 | MP-4 | 51.7 μSv/h | - | Fine | WNW | 1.9 | | | | ○ | | |
| | 15:34 | MP-4 | 51.6 μSv/h | - | Fine | NW | 1.6 | | | | ○ | | |
| | 15:36 | MP-4 | 51.6 μSv/h | - | Fine | NNW | 1.4 | | | | ○ | | |
| | 15:38 | MP-4 | 52.1 μSv/h | - | Fine | NNW | 1.3 | | | | ○ | | |
| | 15:40 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | WNW | 1.5 | | | | | | |
| | 15:40 | MP-1 | 24 μSv/h | - | - | - | - | | | | | | |
| | 15:40 | MP-4 | 56.5 μSv/h | - | Fine | ENE | 1.2 | | | | | | |
| | 15:42 | MP-4 | 85.0 μSv/h | - | Fine | NE | 1.2 | | | | | | |
| | 15:44 | MP-4 | 135.8 μSv/h | - | Fine | ESE | 1.2 | | | | ○ | | |
| | 15:46 | MP-4 | 116.6 μSv/h | - | Fine | SE | 1.0 | | | | ○ | | |
| | 15:48 | MP-4 | 100.7 μSv/h | - | Fine | SSE | 0.8 | | | | ○ | | |
| | 15:50 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | SE | 2.3 | | | | | | |
| | 15:50 | MP-1 | 30 μSv/h | - | - | - | - | | | | | | |
| | 15:50 | MP-4 | 76.1 μSv/h | - | Fine | SSE | 0.7 | | | | | | |
| | 15:52 | MP-4 | 77.3 μSv/h | - | Fine | S | 0.6 | | | | ○ | | |
| | 15:54 | MP-4 | 80.6 μSv/h | - | Fine | SSE | 0.6 | | | | ○ | | |
| | 15:56 | MP-4 | 82.8 μSv/h | - | Fine | S | 0.6 | | | | ○ | | |
| | 15:58 | MP-4 | 89.6 μSv/h | - | Fine | SSW | 0.6 | | | | ○ | | |
| | 16:00 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | SE | 2.2 | | | | | | |
| | 16:00 | MP-1 | 31 μSv/h | - | - | - | - | | | | | | |
| | 16:00 | MP-4 | 107.3 μSv/h | - | Fine | S | 0.7 | | | | | | |
| | 16:02 | MP-4 | 83.8 μSv/h | - | Fine | S | 0.6 | | | | ○ | | |
| | 16:04 | MP-4 | 71.1 μSv/h | - | Fine | S | 0.5 | | | | ○ | | |
| | 16:06 | MP-4 | 64.7 μSv/h | - | Fine | S | 0.5 | | | | ○ | | |
| | 16:08 | MP-4 | 61.4 μSv/h | - | Fine | S | 0.4 | | | | ○ | | |
| | 16:10 | MP-1 | 45 μSv/h | - | - | - | - | | | | | | |
| | 16:10 | MP-4 | 58.0 μSv/h | - | Fine | S | 0.4 | | | | | | |
| | 16:10 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | S | 1.8 | | | | | | |
| | 16:12 | MP-4 | 56.6 μSv/h | - | Fine | S | 0.4 | | | | ○ | | |
| | 16:14 | MP-4 | 55.1 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:16 | MP-4 | 54.2 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:18 | MP-4 | 55.6 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:20 | MP-1 | 150 μSv/h | - | - | - | - | | | | | | |
| | 16:20 | MP-4 | 57.6 μSv/h | - | Fine | SSE | 0.4 | | | | | | |
| | 16:20 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | S | 1.5 | | | | | | |
| | 16:22 | MP-4 | 57.6 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:24 | MP-4 | 60.7 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 16:26 | MP-4 | 67.1 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 16:28 | MP-4 | 72.8 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 16:30 | MP-1 | 46 μSv/h | - | - | - | - | | | | | | |
| | 16:30 | MP-4 | 71.5 μSv/h | - | Fine | SSE | 0.5 | | | | | | |
| | 16:30 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | SE | 1.1 | | | | | | |
| | 16:32 | MP-4 | 66.7 μSv/h | - | Fine | S | 0.4 | | | | ○ | | |
| | 16:34 | MP-4 | 63.5 μSv/h | - | Fine | S | 0.4 | | | | ○ | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 16:36 | MP-4 | 60.0 μSv/h | - | Fine | SSW | 0.4 | | | | ○ | | |
| | 16:38 | MP-4 | 57.9 μSv/h | - | Fine | SSW | 0.4 | | | | ○ | | |
| | 16:40 | MP-1 | 60 μSv/h | - | - | - | - | | | | | | |
| | 16:40 | MP-4 | 57.2 μSv/h | - | Fine | SSW | 0.4 | | | | | | |
| | 16:40 | Main Gate | 4.2 μSv/h | below 0.01μSv/h | - | WSW | 1.1 | | | | | | |
| | 16:42 | MP-4 | 61.9 μSv/h | - | Fine | S | 0.5 | | | | ○ | | |
| | 16:44 | MP-4 | 78.5 μSv/h | - | Fine | SSE | 0.5 | | | | ○ | | |
| | 16:46 | MP-4 | 163.5 μSv/h | - | Fine | SE | 0.5 | | | | ○ | | |
| | 16:48 | MP-4 | 136.3 μSv/h | - | Fine | SE | 0.5 | | | | ○ | | |
| | 16:50 | MP-1 | 30 μSv/h | - | - | - | - | | | | | | |
| | 16:50 | MP-4 | 100.1 μSv/h | - | Fine | SE | 0.5 | | | | | | |
| | 16:50 | Main Gate | 4.2 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 16:52 | MP-4 | 68.7 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:54 | MP-4 | 63.9 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:56 | MP-4 | 62.0 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 16:58 | MP-4 | 72.1 μSv/h | - | Fine | SE | 0.5 | | | | ○ | | |
| | 17:00 | MP-1 | 120 μSv/h | - | - | - | - | | | | | | |
| | 17:00 | MP-4 | 79.4 μSv/h | - | Fine | ESE | 0.6 | | | | | | |
| | 17:00 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | SSW | 1.5 | | | | | | |
| | 17:02 | MP-4 | 72.1 μSv/h | - | Fine | E | 0.6 | | | | ○ | | |
| | 17:04 | MP-4 | 64.8 μSv/h | - | Fine | E | 0.6 | | | | ○ | | |
| | 17:06 | MP-4 | 63.0 μSv/h | - | Fine | ESE | 0.7 | | | | ○ | | |
| | 17:08 | MP-4 | 62.4 μSv/h | - | Fine | SE | 0.5 | | | | ○ | | |
| | 17:10 | MP-1 | 62 μSv/h | - | - | - | - | | | | | | |
| | 17:10 | MP-4 | 60.8 μSv/h | - | Fine | SW | 0.4 | | | | | | |
| | 17:10 | Main Gate | 4.2 μSv/h | below 0.01μSv/h | - | S | 1.8 | | | | | | |
| | 17:12 | MP-4 | 58.6 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 17:14 | MP-4 | 56.5 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 17:16 | MP-4 | 55.4 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 17:18 | MP-4 | 56.4 μSv/h | - | Fine | W | 0.4 | | | | ○ | | |
| | 17:20 | MP-1 | 45 μSv/h | - | - | - | - | | | | | | |
| | 17:20 | MP-4 | 57.0 μSv/h | - | Fine | WSW | 0.5 | | | | | | |
| | 17:20 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | SSE | 0.6 | | | | | | |
| | 17:22 | MP-4 | 56.1 μSv/h | - | Fine | WSW | 0.5 | | | | ○ | | |
| | 17:24 | MP-4 | 55.1 μSv/h | - | Fine | WSW | 0.5 | | | | ○ | | |
| | 17:26 | MP-4 | 54.1 μSv/h | - | Fine | S | 0.5 | | | | ○ | | |
| | 17:28 | MP-4 | 54.6 μSv/h | - | Fine | SSE | 0.4 | | | | ○ | | |
| | 17:30 | MP-1 | 36 μSv/h | - | - | - | - | | | | | | |
| | 17:30 | MP-4 | 55.3 μSv/h | - | Fine | SE | 0.4 | | | | | | |
| | 17:30 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | NNW | 0.5 | | | | | | |
| | 17:32 | MP-4 | 56.1 μSv/h | - | Fine | SSW | 0.4 | | | | ○ | | |
| | 17:34 | MP-4 | 56.6 μSv/h | - | Fine | W | 0.4 | | | | ○ | | |
| | 17:36 | MP-4 | 57.4 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 17:38 | MP-4 | 56.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 17:40 | MP-1 | 40 μSv/h | - | - | - | - | | | | | | |
| | 17:40 | MP-4 | 56.8 μSv/h | - | Fine | NNW | 0.5 | | | | | | |
| | 17:40 | Main Gate | 5.9 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 17:42 | MP-4 | 56.3 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 17:44 | MP-4 | 53.8 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 17:46 | MP-4 | 53.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 17:48 | MP-4 | 52.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 17:50 | MP-1 | 35 μSv/h | - | - | - | - | | | | | | |
| | 17:50 | MP-4 | 52.3 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| | 17:50 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 17:52 | MP-4 | 51.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 17:54 | MP-4 | 52.3 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 17:56 | MP-4 | 53.3 μSv/h | - | Fine | NW | 0.6 | | | | ○ | | |
| | 17:58 | MP-4 | 51.2 μSv/h | - | Fine | NW | 0.6 | | | | ○ | | |
| | 18:00 | MP-1 | 35 μSv/h | - | - | - | - | | | | | | |
| | 18:00 | MP-4 | 50.1 μSv/h | - | Fine | NW | 0.6 | | | | | | |
| | 18:00 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | |
| | 18:02 | MP-4 | 49.9 μSv/h | - | Fine | NNW | 0.6 | | | | ○ | | |
| | 18:04 | MP-4 | 49.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:06 | MP-4 | 49.7 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:08 | MP-4 | 49.5 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:10 | MP-1 | 30 μSv/h | - | - | - | - | | | | | | |
| | 18:10 | MP-4 | 49.4 μSv/h | - | Fine | NNW | 0.6 | | | | | | |
| | 18:10 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | NW | 0.8 | | | | | | |
| | 18:12 | MP-4 | 49.2 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:14 | MP-4 | 49.1 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:16 | MP-4 | 48.9 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 18:18 | MP-4 | 48.8 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 18:20 | MP-1 | 27 μSv/h | - | - | - | - | | | | | | |
| | 18:20 | MP-4 | 48.6 μSv/h | - | Fine | NNE | 0.3 | | | | | | |
| | 18:20 | Main Gate | 5.3 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 18:22 | MP-4 | 48.4 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 18:24 | MP-4 | 48.4 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 18:26 | MP-4 | 48.2 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 18:28 | MP-4 | 48.1 μSv/h | - | Fine | SSW | 0.3 | | | | ○ | | |
| | 18:30 | MP-1 | 26 μSv/h | - | - | - | - | | | | | | |
| | 18:30 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 18:30 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | NW | 1.1 | | | | | | |
| | 18:32 | MP-4 | 47.9 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 18:34 | MP-4 | 47.8 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 18:36 | MP-4 | 47.6 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 18:38 | MP-4 | 47.4 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 18:40 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | |
| | 18:40 | MP-4 | 47.3 μSv/h | - | Fine | N | 0.3 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 18:40 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | NW | 1.3 | | | | | | |
| | 18:42 | MP-4 | 47.2 μSv/h | - | Fine | SSE | 0.3 | | | | ○ | | |
| | 18:44 | MP-4 | 47.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 18:46 | MP-4 | 46.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:48 | MP-4 | 46.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 18:50 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | |
| | 18:50 | MP-4 | 46.7 μSv/h | - | Fine | NW | 0.6 | | | | | | |
| | 18:50 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | NNW | 1.2 | | | | | | |
| | 18:52 | MP-4 | 46.6 μSv/h | - | Fine | NNW | 0.6 | | | | ○ | | |
| | 18:54 | MP-4 | 46.5 μSv/h | - | Fine | NNW | 0.6 | | | | ○ | | |
| | 18:56 | MP-4 | 46.4 μSv/h | - | Fine | NNW | 0.6 | | | | ○ | | |
| | 18:58 | MP-4 | 46.3 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 19:00 | MP-1 | 25 μSv/h | - | - | - | - | | | | | | |
| | 19:00 | MP-4 | 46.1 μSv/h | - | Fine | NNW | 0.5 | | | | | | |
| | 19:00 | Main Gate | 5.2 μSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | |
| | 19:02 | MP-4 | 46.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 19:04 | MP-4 | 46.3 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 19:06 | MP-4 | 47.3 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 19:08 | MP-4 | 47.1 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 19:10 | MP-4 | 46.9 μSv/h | - | Fine | NW | 0.3 | | | | | | |
| | 19:10 | MP-1 | 23 μSv/h | - | - | - | - | | | | | | |
| | 19:10 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | W | 0.8 | | | | | | |
| | 19:12 | MP-4 | 46.8 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 19:14 | MP-4 | 46.6 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 19:16 | MP-4 | 46.4 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 19:20 | MP-1 | 22 μSv/h | - | - | - | - | | | | | | |
| | 19:20 | Main Gate | 4.7 μSv/h | below 0.01μSv/h | - | NW | 0.8 | | | | | | |
| | 19:23 | MP-4 | 44.8 μSv/h | - | - | NW | 0.4 | | | | | | |
| | 19:25 | MP-4 | 44.8 μSv/h | - | - | WNW | 0.5 | | | | ○ | | |
| | 19:27 | MP-4 | 44.6 μSv/h | - | - | WNW | 0.5 | | | | ○ | | |
| | 19:29 | MP-4 | 44.5 μSv/h | - | - | WNW | 0.4 | | | | ○ | | |
| | 19:30 | MP-1 | 20 μSv/h | - | - | - | - | | | | | | |
| | 19:30 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | SW | 0.8 | | | | | | |
| | 19:31 | MP-4 | 44.4 μSv/h | - | - | WNW | 0.4 | | | | | | |
| | 19:33 | MP-4 | 44.3 μSv/h | - | - | NW | 0.3 | | | | ○ | | |
| | 19:35 | MP-4 | 45.3 μSv/h | - | - | NNW | 0.3 | | | | ○ | | |
| | 19:37 | MP-4 | 44.8 μSv/h | - | - | NNW | 0.3 | | | | ○ | | |
| | 19:39 | MP-4 | 43.9 μSv/h | - | - | NNE | 0.3 | | | | ○ | | |
| | 19:40 | MP-1 | 26 μSv/h | - | - | - | - | | | | | | |
| | 19:40 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 19:41 | MP-4 | 44.0 μSv/h | - | - | N | 0.3 | | | | | | |
| | 19:43 | MP-4 | 43.9 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 19:45 | MP-4 | 43.9 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 19:47 | MP-4 | 43.8 μSv/h | - | Fine | WNW | 0.4 | | | | ○ | | |
| | 19:49 | MP-4 | 43.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 19:50 | MP-1 | 24 μSv/h | - | - | - | - | | | | | | |
| | 19:50 | Main Gate | 5.6 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 19:51 | MP-4 | 43.8 μSv/h | - | Fine | NNW | 0.5 | | | | | | |
| | 19:53 | MP-4 | 44.2 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 19:55 | MP-4 | 43.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 19:57 | MP-4 | 43.5 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 19:59 | MP-4 | 43.3 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 20:00 | MP-1 | 24 μSv/h | - | - | - | - | | | | | | |
| | 20:00 | Main Gate | 5.7 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | |
| | 20:01 | MP-4 | 43.2 μSv/h | - | Fine | NW | 0.5 | | | | | | |
| | 20:03 | MP-4 | 43.1 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 20:05 | MP-4 | 43.0 μSv/h | - | Fine | NW | 0.6 | | | | ○ | | |
| | 20:07 | MP-4 | 42.9 μSv/h | - | Fine | WNW | 0.6 | | | | ○ | | |
| | 20:09 | MP-4 | 42.9 μSv/h | - | Fine | WNW | 0.6 | | | | ○ | | |
| | 20:10 | MP-2 | 450 μSv/h | - | - | - | - | | | | | | |
| | 20:10 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | SW | 0.3 | | | | | | |
| | 20:11 | MP-4 | 42.8 μSv/h | - | Fine | NW | 0.6 | | | | | | |
| | 20:13 | MP-4 | 42.7 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 20:15 | MP-4 | 42.7 μSv/h | - | Fine | SW | 0.4 | | | | ○ | | |
| | 20:17 | MP-4 | 42.7 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 20:19 | MP-4 | 42.6 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 20:20 | MP-2 | 450 μSv/h | - | - | - | - | | | | | | |
| | 20:20 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | NW | 0.2 | | | | | | |
| | 20:21 | MP-4 | 42.5 μSv/h | - | Fine | NNE | 0.3 | | | | | | |
| | 20:23 | MP-4 | 42.3 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 20:25 | MP-4 | 42.3 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 20:27 | MP-4 | 42.2 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 20:29 | MP-4 | 42.2 μSv/h | - | Fine | WNW | 0.4 | | | | ○ | | |
| | 20:30 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 20:30 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 20:31 | MP-4 | 42.6 μSv/h | - | Fine | WNW | 0.4 | | | | | | |
| | 20:33 | MP-4 | 45.9 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 20:35 | MP-4 | 44.6 μSv/h | - | Fine | SSW | 0.4 | | | | ○ | | |
| | 20:37 | MP-4 | 42.6 μSv/h | - | Fine | S | 0.4 | | | | ○ | | |
| | 20:39 | MP-4 | 42.2 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 20:40 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 20:40 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 20:41 | MP-4 | 42.0 μSv/h | - | Fine | N | 0.4 | | | | | | |
| | 20:43 | MP-4 | 41.9 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 20:45 | MP-4 | 41.8 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 20:47 | MP-4 | 41.7 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 20:49 | MP-4 | 41.7 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 20:50 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

: figure, place change
 : significant figure change
 : reflection amend
 : new additional data
 : change unit
 : reflection amend
 : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 20:50 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 20:51 | MP-4 | 41.7 μSv/h | - | Fine | NNE | 0.3 | | | | | | |
| | 20:53 | MP-4 | 41.6 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 20:55 | MP-4 | 41.5 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 20:57 | MP-4 | 41.5 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 20:59 | MP-4 | 41.3 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 21:00 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:00 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | NW | 0.8 | | | | | | |
| | 21:01 | MP-4 | 41.3 μSv/h | - | Fine | N | 0.4 | | | | | | |
| | 21:03 | MP-4 | 41.3 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 21:05 | MP-4 | 41.2 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | |
| | 21:07 | MP-4 | 41.1 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | |
| | 21:09 | MP-4 | 41.0 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 21:10 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:10 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | N | 0.5 | | | | | | |
| | 21:11 | MP-4 | 41.0 μSv/h | - | Fine | N | 0.4 | | | | | | |
| | 21:13 | MP-4 | 41.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:15 | MP-4 | 41.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:17 | MP-4 | 40.8 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:19 | MP-4 | 40.8 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:20 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:20 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | N | 0.5 | | | | | | |
| | 21:21 | MP-4 | 40.8 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| | 21:23 | MP-4 | 40.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:25 | MP-4 | 40.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:27 | MP-4 | 40.6 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:29 | MP-4 | 40.6 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 21:30 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:30 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 21:31 | MP-4 | 40.6 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 21:33 | MP-4 | 40.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 21:35 | MP-4 | 40.4 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 21:37 | MP-4 | 42.0 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 21:39 | MP-4 | 41.3 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 21:40 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:40 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | S | 0.3 | | | | | | |
| | 21:41 | MP-4 | 40.3 μSv/h | - | Fine | NW | 0.4 | | | | | | |
| | 21:43 | MP-4 | 40.2 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 21:45 | MP-4 | 40.2 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 21:47 | MP-4 | 40.1 μSv/h | - | Fine | ESE | 0.3 | | | | ○ | | |
| | 21:49 | MP-4 | 40.1 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 21:50 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 21:50 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | NW | 0.3 | | | | | | |
| | 21:51 | MP-4 | 40.1 μSv/h | - | Fine | N | 0.3 | | | | | | |
| | 21:53 | MP-4 | 40.0 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 21:55 | MP-4 | 40.0 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 21:57 | MP-4 | 39.9 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 21:59 | MP-4 | 39.9 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 22:00 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | |
| | 22:00 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | |
| | 22:01 | MP-4 | 39.8 μSv/h | - | Fine | NNE | 0.3 | | | | | | |
| | 22:03 | MP-4 | 39.8 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 22:05 | MP-4 | 39.7 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 22:07 | MP-4 | 39.7 μSv/h | - | Fine | SSW | 0.4 | | | | ○ | | |
| | 22:09 | MP-4 | 39.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 22:10 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | |
| | 22:10 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 22:11 | MP-4 | 39.7 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 22:13 | MP-4 | 39.6 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 22:15 | MP-4 | 39.6 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 22:17 | MP-4 | 39.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 22:19 | MP-4 | 41.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 22:20 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | |
| | 22:20 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | |
| | 22:21 | MP-4 | 40.4 μSv/h | - | Fine | NNW | 0.5 | | | | | | |
| | 22:23 | MP-4 | 39.4 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 22:25 | MP-4 | 39.3 μSv/h | - | Fine | E | 0.4 | | | | ○ | | |
| | 22:27 | MP-4 | 39.3 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 22:29 | MP-4 | 39.3 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 22:30 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | |
| | 22:30 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | ENE | 0.4 | | | | | | |
| | 22:31 | MP-4 | 39.3 μSv/h | - | Fine | ESE | 0.3 | | | | | | |
| | 22:33 | MP-4 | 39.2 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 22:35 | MP-4 | 39.2 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 22:37 | MP-4 | 39.2 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 22:39 | MP-4 | 39.1 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 22:40 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | |
| | 22:40 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | |
| | 22:41 | MP-4 | 39.1 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| | 22:43 | MP-4 | 39.0 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 22:45 | MP-4 | 39.0 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 22:47 | MP-4 | 39.0 μSv/h | - | Fine | SSW | 0.5 | | | | ○ | | |
| | 22:49 | MP-4 | 38.9 μSv/h | - | Fine | N | 0.5 | | | | ○ | | |
| | 22:50 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 22:50 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 22:51 | MP-4 | 38.9 μSv/h | - | Fine | N | 0.5 | | | | | | |
| | 22:53 | MP-4 | 38.9 μSv/h | - | Fine | NNE | 0.5 | | | | ○ | | |
| | 22:55 | MP-4 | 38.8 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 22:57 | MP-4 | 38.8 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 22:59 | MP-4 | 38.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:00 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 23:00 | Main Gate | 4.7 μSv/h | below 0.01μSv/h | - | N | 0.5 | | | | | | |
| | 23:01 | MP-4 | 38.7 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 23:03 | MP-4 | 38.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:05 | MP-4 | 39.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:07 | MP-4 | 40.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:09 | MP-4 | 40.6 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:10 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 23:10 | Main Gate | 4.7 μSv/h | below 0.01μSv/h | - | N | 0.7 | | | | | | |
| | 23:11 | MP-4 | 39.0 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 23:13 | MP-4 | 38.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:15 | MP-4 | 38.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:17 | MP-4 | 38.4 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | |
| | 23:19 | MP-4 | 38.3 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:20 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 23:20 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | |
| | 23:21 | MP-4 | 38.3 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| | 23:23 | MP-4 | 38.3 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 23:25 | MP-4 | 38.3 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 23:27 | MP-4 | 38.3 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 23:29 | MP-4 | 38.3 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 23:30 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 23:30 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | WSW | 0.6 | | | | | | |
| | 23:31 | MP-4 | 38.2 μSv/h | - | Fine | ENE | 0.4 | | | | | | |
| | 23:33 | MP-4 | 38.2 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | |
| | 23:35 | MP-4 | 38.2 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 23:37 | MP-4 | 38.2 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 23:39 | MP-4 | 38.1 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 23:40 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 23:40 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 23:41 | MP-4 | 38.1 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 23:43 | MP-4 | 38.1 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:45 | MP-4 | 38.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:47 | MP-4 | 38.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:49 | MP-4 | 38.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 23:50 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 23:50 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 23:51 | MP-4 | 37.9 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 23:53 | MP-4 | 37.9 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:55 | MP-4 | 37.9 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:57 | MP-4 | 37.9 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 23:59 | MP-4 | 37.8 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| 3/14 | 0:00 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:00 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 0:01 | MP-4 | 38.2 μSv/h | - | Fine | NW | 0.3 | | | | | | |
| | 0:03 | MP-4 | 39.0 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 0:05 | MP-4 | 39.2 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | |
| | 0:07 | MP-4 | 39.1 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | |
| | 0:09 | MP-4 | 39.1 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | |
| | 0:10 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:10 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 0:11 | MP-4 | 38.4 μSv/h | - | Fine | NW | 0.3 | | | | | | |
| | 0:13 | MP-4 | 37.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 0:15 | MP-4 | 37.8 μSv/h | - | Fine | SW | 0.3 | | | | ○ | | |
| | 0:17 | MP-4 | 37.7 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 0:19 | MP-4 | 37.7 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 0:20 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:20 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 0:21 | MP-4 | 37.7 μSv/h | - | Fine | N | 0.3 | | | | | | |
| | 0:23 | MP-4 | 37.6 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 0:25 | MP-4 | 37.7 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 0:27 | MP-4 | 37.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 0:29 | MP-4 | 37.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 0:30 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:30 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | N | 0.4 | | | | | | |
| | 0:31 | MP-4 | 37.5 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 0:33 | MP-4 | 37.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 0:35 | MP-4 | 37.4 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 0:37 | MP-4 | 37.4 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 0:39 | MP-4 | 37.4 μSv/h | - | Fine | N | 0.4 | | | | ○ | | |
| | 0:40 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:40 | Main Gate | 4.5 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 0:41 | MP-4 | 37.3 μSv/h | - | Fine | N | 0.5 | | | | | | |
| | 0:43 | MP-4 | 37.3 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 0:45 | MP-4 | 37.3 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 0:47 | MP-4 | 37.1 μSv/h | - | Fine | W | 0.4 | | | | ○ | | |
| | 0:49 | MP-4 | 37.0 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 0:50 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 0:50 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | S | 0.5 | | | | | | |
| | 0:51 | MP-4 | 37.0 μSv/h | - | Fine | SW | 0.3 | | | | | | |
| | 0:53 | MP-4 | 37.0 μSv/h | - | Fine | SW | 0.3 | | | | ○ | | |
| | 0:55 | MP-4 | 36.9 μSv/h | - | Fine | WSW | 0.3 | | | | ○ | | |
| | 0:57 | MP-4 | 38.7 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | |
| | 0:59 | MP-4 | 39.6 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 1:00 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:00 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | S | 0.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|----------------------|------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 1:01 | MP-4 | 38.0 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 1:03 | MP-4 | 37.1 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 1:05 | MP-4 | 36.9 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 1:07 | MP-4 | 36.8 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 1:09 | MP-4 | 36.8 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 1:10 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:10 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 1:11 | MP-4 | 36.9 μSv/h | - | Fine | NNE | 0.3 | | | | | | |
| | 1:13 | MP-4 | 36.8 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 1:15 | MP-4 | 36.8 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 1:17 | MP-4 | 36.7 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | |
| | 1:19 | MP-4 | 36.7 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | |
| | 1:20 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:20 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | S | 0.3 | | | | | | |
| | 1:21 | MP-4 | 36.7 μSv/h | - | Fine | SE | 0.3 | | | | | | |
| | 1:23 | MP-4 | 36.7 μSv/h | - | Fine | W | 0.3 | | | | ○ | | |
| | 1:25 | MP-4 | 36.7 μSv/h | - | Fine | W | 0.3 | | | | ○ | | |
| | 1:27 | MP-4 | 36.6 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |
| | 1:29 | MP-4 | 36.6 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 1:30 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:30 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 1:31 | MP-4 | 36.5 μSv/h | - | Fine | NW | 0.3 | | | | | | |
| | 1:33 | MP-4 | 36.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 1:35 | MP-4 | 36.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 1:37 | MP-4 | 36.5 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 1:39 | MP-4 | 36.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 1:40 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:40 | Main Gate | 4.3 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 1:41 | MP-4 | 36.4 μSv/h | - | Fine | NW | 0.6 | | | | | | |
| | 1:43 | MP-4 | 36.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 1:45 | MP-4 | 36.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 1:47 | MP-4 | 36.8 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 1:49 | MP-4 | 38.2 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 1:50 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 1:50 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 1:51 | MP-4 | 38.3 μSv/h | - | Fine | NNE | 0.5 | | | | | | |
| | 1:53 | MP-4 | 38.0 μSv/h | - | - | - | - | | | | ○ | | |
| | 1:55 | MP-4 | 38.0 μSv/h | - | - | - | - | | | | ○ | | |
| | 1:57 | MP-4 | 37.0 μSv/h | - | - | - | - | | | | ○ | | |
| | 1:58 | MP-4 | 36.5 μSv/h | - | Fine | NNE | 0.5 | | | | ○ | | |
| | 2:00 | MP-4 | 36.4 μSv/h | - | Fine | E | 0.4 | | | | | | |
| | 2:00 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 2:00 | Main Gate | 4.4 μSv/h | below 0.01μSv/h | - | SE | 0.7 | | | | | | |
| | 2:02 | MP-4 | 36.4 μSv/h | - | Fine | E | 0.4 | | | | ○ | | |
| | 2:04 | MP-4 | 36.3 μSv/h | - | Fine | ENE | 0.4 | | | | ○ | | |
| | 2:06 | MP-4 | 36.3 μSv/h | - | Fine | E | 0.3 | | | | ○ | | |
| | 2:08 | MP-4 | 36.3 μSv/h | - | Fine | ESE | 0.3 | | | | ○ | | |
| | 2:10 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 2:10 | MP-4 | 36.5 μSv/h | - | Fine | ESE | 0.4 | | | | | | |
| | 2:10 | Main Gate | 4.6 μSv/h | below 0.01μSv/h | - | NE | 0.7 | | | | | | |
| | 2:12 | MP-4 | 37.0 μSv/h | - | Fine | E | 0.3 | | | | ○ | | |
| | 2:14 | MP-4 | 37.8 μSv/h | - | Fine | E | 0.3 | | | | ○ | | |
| | 2:16 | MP-4 | 37.7 μSv/h | - | Fine | SSE | 0.3 | | | | ○ | | |
| | 2:18 | MP-4 | 39.3 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 2:20 | MP-2 | 410 μSv/h | - | - | - | - | | | | | | |
| | 2:20 | MP-4 | 44.6 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| Article 15-44 notice | 2:20 | Main Gate | 751.2 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | | | | | |
| | 2:22 | MP-4 | 70.1 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 2:24 | MP-4 | 227.9 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 2:26 | MP-4 | 267.0 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 2:28 | MP-4 | 308.2 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 2:30 | MP-2 | 440 μSv/h | - | - | - | - | | | | | | |
| | 2:30 | MP-4 | 319.3 μSv/h | - | Fine | NNW | 0.4 | | | | | | |
| | 2:30 | Main Gate | 433.0 μSv/h | below 0.01μSv/h | - | S | 0.4 | | | | | | |
| | 2:32 | MP-4 | 275.7 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 2:34 | MP-4 | 230.6 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 2:36 | MP-4 | 215.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 2:38 | MP-4 | 199.0 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 2:40 | MP-2 | 650 μSv/h | - | - | - | - | | | | | | |
| | 2:40 | MP-4 | 189.7 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 2:40 | Main Gate | 420.0 μSv/h | below 0.01μSv/h | - | SW | 0.5 | | | | | | |
| | 2:42 | MP-4 | 161.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 2:44 | MP-4 | 116.4 μSv/h | - | Fine | NNW | 0.2 | | | | ○ | | |
| | 2:46 | MP-4 | 96.0 μSv/h | - | Fine | NNW | 0.2 | | | | ○ | | |
| | 2:48 | MP-4 | 90.5 μSv/h | - | Fine | ENE | 0.2 | | | | ○ | | |
| | 2:50 | MP-2 | 490 μSv/h | - | - | - | - | | | | | | |
| | 2:50 | MP-4 | 86.9 μSv/h | - | Fine | N | 0.2 | | | | | | |
| | 2:50 | Main Gate | 66.3 μSv/h | below 0.01μSv/h | - | - | 0.7 | | | | | | |
| | 2:52 | MP-4 | 84.8 μSv/h | - | Fine | NNE | 0.2 | | | | ○ | | |
| | 2:54 | MP-4 | 100.3 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 2:56 | MP-4 | 106.1 μSv/h | - | Fine | NNE | 0.3 | | | | ○ | | |
| | 2:58 | MP-4 | 129.1 μSv/h | - | Fine | N | 0.3 | | | | ○ | | |
| | 3:00 | MP-2 | 480 μSv/h | - | - | - | - | | | | | | |
| | 3:00 | MP-4 | 144.2 μSv/h | - | Fine | N | 0.4 | | | | | | |
| | 3:00 | Main Gate | 65.5 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 3:02 | MP-4 | 140.3 μSv/h | - | Fine | ESE | 0.4 | | | | ○ | | |
| | 3:04 | MP-4 | 131.8 μSv/h | - | Fine | NNW | 0.4 | | | | ○ | | |
| | 3:06 | MP-4 | 114.3 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason | |
|-------------|-----------|------------|-----------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|--|
| 15条46notice | 3:08 | MP-4 | 124.1 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | | |
| | 3:10 | MP-2 | 650 μSv/h | - | - | - | - | | | | | | | |
| | 3:10 | MP-4 | 129.8 μSv/h | - | Fine | WNW | 0.3 | | | | | | | |
| | 3:10 | Main Gate | 45.5 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | | |
| | 3:12 | MP-4 | 137.8 μSv/h | - | Fine | WNW | 0.3 | | | | ○ | | | |
| | 3:14 | MP-4 | 129.5 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | | |
| | 3:16 | MP-4 | 138.3 μSv/h | - | Fine | WSW | 0.3 | | | | ○ | | | |
| | 3:18 | MP-4 | 135.7 μSv/h | - | Fine | N | 0.3 | | | | ○ | | | |
| | 3:20 | MP-2 | 650 μSv/h | - | - | - | - | | | | | | | |
| | 3:20 | MP-4 | 123.9 μSv/h | - | Fine | NNE | 0.4 | | | | | | | |
| | 3:20 | Main Gate | 15.4 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | | |
| | 3:22 | MP-4 | 110.2 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | | |
| | 3:24 | MP-4 | 107.3 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | | |
| | 3:26 | MP-4 | 113.8 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | | |
| | 3:28 | MP-4 | 110.0 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | | |
| | 3:30 | MP-2 | 720 μSv/h | - | - | - | - | | | | | | | |
| | 3:30 | MP-4 | 112.9 μSv/h | - | Fine | WNW | 0.3 | | | | | | | |
| | 3:30 | Main Gate | 19.0 μSv/h | below 0.01μSv/h | - | SE | 0.4 | | | | | | | |
| | 3:32 | MP-4 | 109.8 μSv/h | - | Fine | W | 0.3 | | | | ○ | | | |
| | 3:34 | MP-4 | 96.0 μSv/h | - | Fine | WSW | 0.3 | | | | ○ | | | |
| | 3:36 | MP-4 | 75.9 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | | |
| | 3:38 | MP-4 | 78.1 μSv/h | - | Fine | W | 0.4 | | | | ○ | | | |
| | 3:40 | MP-2 | 600 μSv/h | - | - | - | - | | | | | | | |
| | 3:40 | MP-4 | 73.6 μSv/h | - | Fine | W | 0.5 | | | | | | | |
| | 3:40 | Main Gate | 15.0 μSv/h | below 0.01μSv/h | - | S | 0.4 | | | | | | | |
| | 3:42 | MP-4 | 73.8 μSv/h | - | Fine | WNW | 0.4 | | | | ○ | | | |
| | 3:44 | MP-4 | 74.4 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | | |
| | 3:46 | MP-4 | 73.9 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | | |
| | 3:48 | MP-4 | 74.7 μSv/h | - | Fine | NW | 0.3 | | | | ○ | | | |
| | 3:50 | MP-2 | 680 μSv/h | - | - | - | - | | | | | | | |
| | 3:50 | MP-4 | 70.0 μSv/h | - | Fine | NW | 0.3 | | | | | | | |
| | 3:50 | Main Gate | 10.3 μSv/h | below 0.01μSv/h | - | S | 0.2 | | | | | | | |
| | 3:52 | MP-4 | 71.1 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | | |
| | 3:54 | MP-4 | 76.3 μSv/h | - | Fine | ENE | 0.4 | | | | ○ | | | |
| | 3:56 | MP-4 | 75.4 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | | |
| | 3:58 | MP-4 | 72.2 μSv/h | - | Fine | NE | 0.4 | | | | ○ | | | |
| | 4:00 | MP-2 | 820 μSv/h | - | - | - | - | | | | | | | |
| | 4:00 | MP-4 | 68.8 μSv/h | - | Fine | NNE | 0.4 | | | | | | | |
| | 4:00 | Main Gate | 10.1 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | | |
| | 4:02 | MP-4 | 63.9 μSv/h | - | Fine | NNE | 0.4 | | | | ○ | | | |
| | 4:04 | MP-4 | 60.6 μSv/h | - | Fine | N | 0.4 | | | | ○ | | | |
| | 4:06 | MP-4 | 56.8 μSv/h | - | Fine | WNW | 0.5 | | | | ○ | | | |
| | 4:08 | MP-4 | 56.4 μSv/h | - | Fine | NNW | 0.6 | | | | ○ | | | |
| | 4:10 | MP-2 | 450 μSv/h | - | - | - | - | | | | | | | |
| | 4:10 | MP-4 | 54.7 μSv/h | - | Fine | NNW | 0.5 | | | | | | | |
| | 4:10 | Main Gate | 6.7 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | | |
| | 4:12 | MP-4 | 53.5 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | | |
| | 4:14 | MP-4 | 52.0 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | | |
| | 4:16 | MP-4 | 50.6 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | | |
| | 4:18 | MP-4 | 49.0 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | | |
| 4:20 | MP-2 | 430 μSv/h | - | - | - | - | | | | | | | | |
| 4:20 | MP-4 | 47.6 μSv/h | - | Fine | NW | 0.5 | | | | | | | | |
| 4:20 | Main Gate | 7.7 μSv/h | below 0.01μSv/h | - | N | 0.9 | | | | | | | | |
| 4:22 | MP-4 | 46.7 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | | | |
| 4:24 | MP-4 | 45.8 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | | | |
| 4:26 | MP-4 | 53.0 μSv/h | - | - | - | - | | | | ○ | | | | |
| 4:28 | MP-4 | 52.0 μSv/h | - | - | - | - | | | | ○ | | | | |
| 4:30 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | | | |
| 4:30 | Main Gate | 7.7 μSv/h | below 0.01μSv/h | - | ESE | 0.6 | | | | | | | | |
| 4:30 | MP-4 | 50.0 μSv/h | - | - | - | - | | | | | | | | |
| 4:32 | MP-4 | 52.0 μSv/h | - | - | WSW | 0.4 | | | | ○ | | | | |
| 4:34 | MP-4 | 47.2 μSv/h | - | - | SW | 0.4 | | | | ○ | | | | |
| 4:36 | MP-4 | 44.0 μSv/h | - | - | WSW | 0.5 | | | | ○ | | | | |
| 4:38 | MP-4 | 44.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | | | |
| 4:40 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | | | |
| 4:40 | MP-4 | 42.9 μSv/h | - | Fine | NNW | 0.4 | | | | | | | | |
| 4:40 | Main Gate | 7.0 μSv/h | below 0.01μSv/h | - | NNW | 0.7 | | | | | | | | |
| 4:42 | MP-4 | 41.8 μSv/h | - | Fine | NNW | 0.4 | | | | | ○ | monicar trouble | | |
| 4:50 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | | | |
| 4:50 | Main Gate | 6.9 μSv/h | below 0.01μSv/h | - | N | 0.8 | | | | | | | | |
| 4:51 | MP-4 | 40.6 μSv/h | - | - | NNW | 0.6 | | | | | | | | |
| 4:53 | MP-4 | 40.3 μSv/h | - | - | NNW | 0.6 | | | | ○ | | | | |
| 4:55 | MP-4 | 40.3 μSv/h | - | - | NNW | 0.6 | | | | ○ | | | | |
| 4:57 | MP-4 | 40.1 μSv/h | - | - | NNW | 0.6 | | | | ○ | | | | |
| 4:59 | MP-4 | 39.9 μSv/h | - | - | NNW | 0.6 | | | | ○ | | | | |
| 5:00 | MP-2 | 400 μSv/h | - | - | - | - | | | | | | | | |
| 5:00 | Main Gate | 6.7 μSv/h | below 0.01μSv/h | - | SW | 0.5 | | | | | | | | |
| 5:01 | MP-4 | 39.9 μSv/h | - | - | NNW | 0.5 | | | | | | | | |
| 5:03 | MP-4 | 39.9 μSv/h | - | - | NNW | 0.5 | | | | ○ | | | | |
| 5:05 | MP-4 | 39.8 μSv/h | - | - | NNW | 0.4 | | | | ○ | | | | |
| 5:07 | MP-4 | 39.6 μSv/h | - | - | NNW | 0.4 | | | | ○ | | | | |
| 5:09 | MP-4 | 39.3 μSv/h | - | - | NNW | 0.3 | | | | ○ | | | | |
| 5:10 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | | | |
| 5:10 | Main Gate | 6.5 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | | | |
| 5:11 | MP-4 | 39.0 μSv/h | - | - | NW | 0.3 | | | | | | | | |
| 5:13 | MP-4 | 38.9 μSv/h | - | - | NNW | 0.3 | | | | ○ | | | | |
| 5:15 | MP-4 | 38.9 μSv/h | - | - | NNW | 0.3 | | | | ○ | | | | |
| 5:17 | MP-4 | 39.1 μSv/h | - | - | ENE | 0.3 | | | | ○ | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 5:19 | MP-4 | 39.2 μSv/h | - | - | NNE | 0.3 | | | | ○ | | |
| | 5:20 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 5:20 | Main Gate | 6.7 μSv/h | below 0.01μSv/h | - | SE | 0.5 | | | | | | |
| | 5:21 | MP-4 | 41.3 μSv/h | - | - | ENE | 0.3 | | | | | | |
| | 5:23 | MP-4 | 40.5 μSv/h | - | - | E | 0.3 | | | | ○ | | |
| | 5:25 | MP-4 | 40.3 μSv/h | - | - | W | 0.3 | | | | ○ | | |
| | 5:27 | MP-4 | 40.2 μSv/h | - | - | WNW | 0.4 | | | | ○ | | |
| | 5:29 | MP-4 | 41.3 μSv/h | - | - | WNW | 0.4 | | | | | | |
| | 5:30 | Main Gate | 6.5 μSv/h | below 0.01μSv/h | - | WSW | 0.4 | | | | | | |
| | 5:30 | MP-2 | 400 μSv/h | - | - | - | - | | | | | | |
| | 5:33 | MP-4 | 40.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 5:35 | MP-4 | 38.6 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 5:37 | MP-4 | 38.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 5:39 | MP-4 | 38.4 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 5:40 | Main Gate | 6.4 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 5:40 | MP-2 | 420 μSv/h | - | - | - | - | | | | | | |
| | 5:41 | MP-4 | 38.3 μSv/h | - | Fine | WNW | 0.5 | | | | | | |
| | 5:43 | MP-4 | 38.3 μSv/h | - | Fine | WNW | 0.5 | | | | ○ | | |
| | 5:45 | MP-4 | 38.2 μSv/h | - | Fine | NW | 0.5 | | | | ○ | | |
| | 5:47 | MP-4 | 38.2 μSv/h | - | Fine | NNW | 0.5 | | | | ○ | | |
| | 5:49 | MP-4 | 38.2 μSv/h | - | Fine | WSW | 0.5 | | | | ○ | | |
| | 5:50 | Main Gate | 6.3 μSv/h | below 0.01μSv/h | - | NW | 0.3 | | | | | | |
| | 5:50 | MP-2 | 400 μSv/h | - | - | - | - | | | | | | |
| | 5:51 | MP-4 | 38.1 μSv/h | - | Fine | N | 0.5 | | | | | | |
| | 5:53 | MP-4 | 38.1 μSv/h | - | Fine | N | 0.5 | | | | ○ | | |
| | 5:55 | MP-4 | 38.1 μSv/h | - | Fine | WSW | 0.5 | | | | ○ | | |
| | 5:57 | MP-4 | 38.0 μSv/h | - | Fine | ESE | 0.5 | | | | ○ | | |
| | 5:59 | MP-4 | 38.0 μSv/h | - | Fine | N | 0.5 | | | | ○ | | |
| | 6:00 | MP-2 | 400 μSv/h | - | - | - | - | | | | | | |
| | 6:00 | Main Gate | 5.1 μSv/h | below 0.01μSv/h | - | WNW | 0.5 | | | | | | |
| | 6:01 | MP-4 | 37.9 μSv/h | - | Fine | N | 0.6 | | | | | | |
| | 6:03 | MP-4 | 37.9 μSv/h | - | Fine | ESE | 0.5 | | | | ○ | | |
| | 6:05 | MP-4 | 37.8 μSv/h | - | Fine | E | 0.5 | | | | ○ | | |
| | 6:07 | MP-4 | 37.8 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 6:09 | MP-4 | 37.8 μSv/h | - | Fine | NW | 0.4 | | | | ○ | | |
| | 6:10 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 6:11 | MP-4 | 37.7 μSv/h | - | Fine | NNW | 0.3 | | | | | | |
| | 6:13 | MP-4 | 37.7 μSv/h | - | Fine | NNW | 0.3 | | | | ○ | | |
| | 6:15 | MP-4 | 37.6 μSv/h | - | Fine | WNW | 0.4 | | | | ○ | | |
| | 6:17 | MP-4 | 37.6 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 6:19 | MP-4 | 37.5 μSv/h | - | Fine | WSW | 0.4 | | | | ○ | | |
| | 6:20 | Main Gate | 5.0 μSv/h | below 0.01μSv/h | - | SW | 0.4 | | | | | | |
| | 6:21 | MP-4 | 37.4 μSv/h | - | Fine | WSW | 0.6 | | | | | | |
| | 6:23 | MP-4 | 37.8 μSv/h | - | Fine | W | 0.7 | | | | ○ | | |
| | 6:25 | MP-4 | 38.8 μSv/h | - | Fine | W | 0.6 | | | | | ○ | monicar trouble |
| | 6:27 | MP-4 | 38.7 μSv/h | - | Fine | WNW | 0.7 | | | | | ○ | monicar trouble |
| | 6:29 | MP-4 | 38.6 μSv/h | - | Fine | W | 0.7 | | | | | ○ | monicar trouble |
| | 6:30 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 6:31 | MP-4 | 38.6 μSv/h | - | Fine | WNW | 0.7 | ○ | | | | | monicar trouble |
| | 6:33 | MP-4 | 37.2 μSv/h | - | Fine | WNW | 0.8 | ○ | | | | | monicar trouble |
| | 6:35 | MP-4 | 37.2 μSv/h | - | Fine | WNW | 0.8 | ○ | | | | | monicar trouble |
| | 6:37 | MP-4 | 37.2 μSv/h | - | Fine | WNW | 0.8 | ○ | | | | | monicar trouble |
| | 6:39 | MP-4 | 37.1 μSv/h | - | Fine | NW | 0.8 | ○ | | | | | monicar trouble |
| | 6:40 | Main Gate | 4.9 μSv/h | below 0.01μSv/h | - | SW | 0.5 | ○ | | | | | Sec Team unsent |
| | 6:41 | MP-4 | 37.1 μSv/h | - | Fine | NW | 0.6 | ○ | | | | | monicar trouble |
| | 6:43 | MP-4 | 37.0 μSv/h | - | Fine | WNW | 0.4 | ○ | | | | | monicar trouble |
| | 6:45 | MP-4 | 37.0 μSv/h | - | Fine | NE | 0.4 | ○ | | | | | monicar trouble |
| | 6:47 | MP-4 | 37.0 μSv/h | - | Fine | ENE | 0.5 | ○ | | | | | monicar trouble |
| | 6:49 | MP-4 | 37.0 μSv/h | - | Fine | SSE | 0.4 | ○ | | | | | monicar trouble |
| | 6:50 | Main Gate | 4.8 μSv/h | below 0.01μSv/h | - | SW | 0.8 | ○ | | | | | Sec Team unsent |
| | 6:51 | MP-4 | 36.9 μSv/h | - | Fine | SSE | 0.4 | ○ | | | | | monicar trouble |
| | 6:53 | MP-4 | 36.9 μSv/h | - | Fine | SW | 0.4 | ○ | | | | | monicar trouble |
| | 6:55 | MP-4 | 36.8 μSv/h | - | Fine | W | 0.4 | ○ | | | | | monicar trouble |
| | 6:57 | MP-4 | 36.8 μSv/h | - | Fine | WNW | 0.4 | ○ | | | | | monicar trouble |
| | 6:59 | MP-4 | 36.8 μSv/h | - | Fine | WNW | 0.4 | ○ | | | | | monicar trouble |
| | 7:01 | MP-4 | 36.8 μSv/h | - | Fine | WNW | 0.5 | ○ | | | | | monicar trouble |
| | 7:03 | MP-4 | 36.8 μSv/h | - | Fine | W | 0.7 | ○ | | | | | monicar trouble |
| | 7:05 | MP-4 | 36.7 μSv/h | - | Fine | W | 0.9 | ○ | | | | | monicar trouble |
| | 7:07 | MP-4 | 36.7 μSv/h | - | Fine | W | 1.0 | ○ | | | | | monicar trouble |
| | 7:09 | MP-4 | 36.7 μSv/h | - | Fine | W | 1.3 | ○ | | | | | monicar trouble |
| | 7:11 | MP-4 | 36.6 μSv/h | - | Fine | W | 1.4 | ○ | | | | | monicar trouble |
| | 7:13 | MP-4 | 36.6 μSv/h | - | Fine | W | 1.3 | ○ | | | | | monicar trouble |
| | 7:15 | MP-4 | 36.6 μSv/h | - | Fine | W | 1.1 | ○ | | | | | monicar trouble |
| | 7:17 | MP-4 | 36.5 μSv/h | - | Fine | WNW | 0.9 | ○ | | | | | monicar trouble |
| | 7:19 | MP-4 | 36.5 μSv/h | - | Fine | WNW | 0.6 | ○ | | | | | monicar trouble |
| | 7:21 | MP-4 | 36.5 μSv/h | - | Fine | NW | 0.4 | ○ | | | | | monicar trouble |
| | 7:23 | MP-4 | 36.4 μSv/h | - | Fine | WNW | 0.4 | ○ | | | | | monicar trouble |
| | 7:25 | MP-4 | 39.1 μSv/h | - | Fine | W | 0.3 | ○ | | | | | monicar trouble |
| | 7:27 | MP-4 | 78.8 μSv/h | - | Fine | SSW | 0.4 | ○ | | | | | monicar trouble |
| | 7:29 | MP-4 | 73.3 μSv/h | - | Fine | SE | 0.4 | ○ | | | | | monicar trouble |
| | 7:31 | MP-4 | 78.3 μSv/h | - | Fine | SSW | 0.5 | ○ | | | | | monicar trouble |
| | 7:33 | MP-4 | 126.6 μSv/h | - | Fine | SW | 0.5 | ○ | | | | | monicar trouble |
| | 7:35 | MP-4 | 139.3 μSv/h | - | Fine | SSW | 0.5 | ○ | | | | | monicar trouble |
| | 7:37 | MP-4 | 133.5 μSv/h | - | Fine | SW | 0.4 | ○ | | | | | monicar trouble |
| | 7:39 | MP-4 | 128.3 μSv/h | - | Fine | WSW | 0.4 | ○ | | | | | monicar trouble |
| | 7:41 | MP-4 | 139.1 μSv/h | - | Fine | SW | 0.4 | ○ | | | | | monicar trouble |
| | 7:43 | MP-4 | 133.2 μSv/h | - | Fine | SW | 0.3 | ○ | | | | | monicar trouble |
| | 7:45 | MP-4 | 111.5 μSv/h | - | Fine | SW | 0.3 | ○ | | | | | monicar trouble |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|----------------------|-------|-------|-------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|-----------------|
| | 7:47 | MP-4 | 95.1 μSv/h | - | Fine | WSW | 0.3 | ○ | | | | | monicar trouble |
| | 7:49 | MP-4 | 85.8 μSv/h | - | Fine | WSW | 0.4 | ○ | | | | | monicar trouble |
| | 7:50 | MP-3 | 331.8 μSv/h | - | - | SW | 0.3 | ○ | | | | | Sec Team unsent |
| | 7:51 | MP-4 | 75.2 μSv/h | - | Fine | WSW | 0.4 | ○ | | | | | monicar trouble |
| | 7:53 | MP-4 | 69.4 μSv/h | - | Fine | W | 0.5 | | | | | | |
| | 7:55 | MP-4 | 55.0 μSv/h | - | Fine | W | 0.5 | ○ | | | | | monicar trouble |
| | 7:57 | MP-4 | 48.2 μSv/h | - | Fine | WNW | 0.7 | ○ | | | | | monicar trouble |
| | 7:59 | MP-4 | 43.9 μSv/h | - | Fine | WNW | 0.8 | ○ | | | | | monicar trouble |
| | 8:00 | MP-3 | 282.4 μSv/h | - | - | SSE | 0.6 | ○ | | | | | Sec Team unsent |
| | 8:01 | MP-4 | 41.5 μSv/h | - | Fine | WNW | 1.0 | ○ | | | | | monicar trouble |
| | 8:03 | MP-4 | 40.7 μSv/h | - | Fine | WNW | 1.2 | ○ | | | | | monicar trouble |
| | 8:05 | MP-4 | 40.2 μSv/h | - | Fine | WNW | 1.3 | ○ | | | | | monicar trouble |
| | 8:07 | MP-4 | 40.1 μSv/h | - | Fine | WNW | 1.3 | | | | | | |
| | 8:09 | MP-4 | 40.1 μSv/h | - | Fine | WNW | 1.2 | ○ | | | | | monicar trouble |
| | 8:10 | MP-3 | 262.9 μSv/h | - | - | SW | 0.9 | ○ | | | | | Sec Team unsent |
| | 8:11 | MP-4 | 39.6 μSv/h | - | Fine | WNW | 1.1 | ○ | | | | | monicar trouble |
| | 8:13 | MP-4 | 39.2 μSv/h | - | Fine | WNW | 0.9 | ○ | | | | | monicar trouble |
| | 8:15 | MP-4 | 39.0 μSv/h | - | Fine | WNW | 0.9 | ○ | | | | | monicar trouble |
| | 8:17 | MP-4 | 39.9 μSv/h | - | Fine | WNW | 1.0 | ○ | | | | | monicar trouble |
| | 8:19 | MP-4 | 38.9 μSv/h | - | Fine | WNW | 1.0 | | | | | | |
| | 8:20 | MP-3 | 261.3 μSv/h | - | - | SSE | 0.8 | ○ | | | | | Sec Team unsent |
| | 8:21 | MP-4 | 38.9 μSv/h | - | Fine | WNW | 1.1 | ○ | | | | | monicar trouble |
| | 8:23 | MP-4 | 39.4 μSv/h | - | Fine | WNW | 1.2 | ○ | | | | | monicar trouble |
| | 8:25 | MP-4 | 40.6 μSv/h | - | Fine | WNW | 1.3 | ○ | | | | | monicar trouble |
| | 8:27 | MP-4 | 44.1 μSv/h | - | Fine | WNW | 1.1 | ○ | | | | | monicar trouble |
| | 8:29 | MP-4 | 65.4 μSv/h | - | Fine | W | 1.0 | ○ | | | | | monicar trouble |
| | 8:30 | MP-3 | 287.2 μSv/h | - | - | W | 1.3 | | | | | | |
| | 8:31 | MP-4 | 75.4 μSv/h | - | Fine | W | 0.8 | | | | | | |
| | 8:33 | MP-4 | 59.2 μSv/h | - | Fine | W | 0.7 | ○ | | | | | monicar trouble |
| | 8:35 | MP-4 | 44.5 μSv/h | - | Fine | W | 0.7 | ○ | | | | | monicar trouble |
| | 8:37 | MP-4 | 44.6 μSv/h | - | Fine | WSW | 0.7 | ○ | | | | | monicar trouble |
| | 8:39 | MP-4 | 42.6 μSv/h | - | Fine | WSW | 0.7 | ○ | | | | | Sec Team unsent |
| | 8:40 | MP-3 | 274.0 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 8:41 | MP-4 | 39.7 μSv/h | - | Fine | W | 0.8 | | | | | | |
| | 8:43 | MP-4 | 39.0 μSv/h | - | Fine | W | 1.0 | ○ | | | | | monicar trouble |
| | 8:45 | MP-4 | 38.8 μSv/h | - | Fine | W | 1.1 | ○ | | | | | monicar trouble |
| | 8:47 | MP-4 | 38.9 μSv/h | - | Fine | W | 1.2 | ○ | | | | | monicar trouble |
| | 8:49 | MP-4 | 39.4 μSv/h | - | Fine | W | 1.5 | ○ | | | | | monicar trouble |
| | 8:50 | MP-3 | 268.0 μSv/h | below 0.01μSv/h | - | SSE | 0.8 | | | | | | |
| | 8:51 | MP-4 | 40.9 μSv/h | - | Fine | W | 1.6 | ○ | | | | | monicar trouble |
| | 8:53 | MP-4 | 41.4 μSv/h | - | Fine | W | 1.5 | ○ | | | | | monicar trouble |
| | 8:55 | MP-4 | 42.1 μSv/h | - | Fine | W | 1.4 | | | | | ○ | monicar trouble |
| | 8:57 | MP-4 | 50.8 μSv/h | - | Fine | W | 1.3 | | | | | ○ | monicar trouble |
| | 8:59 | MP-4 | 63.8 μSv/h | - | Fine | W | 1.0 | | | | | ○ | monicar trouble |
| | 9:00 | MP-3 | 304.8 μSv/h | below 0.01μSv/h | - | SSE | 1.2 | | | | | | |
| | 9:01 | MP-4 | 75.4 μSv/h | - | Fine | WSW | 0.8 | | | | | ○ | monicar trouble |
| | 9:03 | MP-4 | 88.3 μSv/h | - | Fine | WSW | 0.5 | | | | | ○ | monicar trouble |
| | 9:05 | MP-4 | 96.8 μSv/h | - | Fine | WSW | 0.5 | | | | | ○ | monicar trouble |
| | 9:07 | MP-4 | 178.3 μSv/h | - | Fine | SW | 0.5 | | | | | ○ | monicar trouble |
| | 9:09 | MP-4 | 198.8 μSv/h | - | Fine | SW | 0.5 | | | | | ○ | monicar trouble |
| | 9:10 | MP-3 | 443.7 μSv/h | below 0.01μSv/h | - | WNW | 1.1 | | | | | | |
| | 9:11 | MP-4 | 156.0 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| Article 15-51 notice | 9:12 | MP-3 | 518.7 μSv/h | below 0.01μSv/h | - | SE | 0.1 | | | | | | |
| | 9:13 | MP-4 | 107.8 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| | 9:15 | MP-4 | 96.8 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| | 9:17 | MP-4 | 102.3 μSv/h | - | Fine | SSW | 0.6 | | | | | ○ | monicar trouble |
| | 9:19 | MP-4 | 84.8 μSv/h | - | Fine | SSW | 0.6 | | | | | ○ | monicar trouble |
| | 9:20 | MP-3 | 481.0 μSv/h | below 0.01μSv/h | - | S | 0.8 | | | | | | |
| | 9:21 | MP-4 | 107.1 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| | 9:23 | MP-4 | 97.0 μSv/h | - | Fine | SSW | 0.5 | ○ | | | | | Sec Team unsent |
| | 9:25 | MP-4 | 87.1 μSv/h | - | Fine | SSW | 0.5 | | | | | | |
| | 9:27 | MP-4 | 67.6 μSv/h | - | Fine | SSW | 0.5 | | | | | ○ | monicar trouble |
| | 9:29 | MP-4 | 54.7 μSv/h | - | Fine | SSW | 0.5 | | | | | ○ | monicar trouble |
| | 9:30 | MP-3 | 339.4 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 9:31 | MP-4 | 53.5 μSv/h | - | Fine | SSW | 0.5 | | | | | ○ | monicar trouble |
| | 9:33 | MP-4 | 54.5 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| | 9:35 | MP-4 | 60.5 μSv/h | - | Fine | SW | 0.6 | | | | | ○ | monicar trouble |
| | 9:37 | MP-4 | 51.7 μSv/h | - | Fine | WSW | 0.6 | | | | | ○ | monicar trouble |
| | 9:39 | MP-4 | 48.2 μSv/h | - | Fine | W | 0.7 | | | | | ○ | monicar trouble |
| | 9:40 | MP-3 | 293.7 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 9:41 | MP-4 | 51.0 μSv/h | - | Fine | WSW | 0.8 | ○ | | | | | Sec Team unsent |
| | 9:43 | MP-4 | 48.9 μSv/h | - | Fine | SW | 0.8 | | | | | | |
| | 9:45 | MP-4 | 45.7 μSv/h | - | Fine | WSW | 0.8 | | | | | ○ | monicar trouble |
| | 9:47 | MP-4 | 44.1 μSv/h | - | Fine | W | 0.9 | | | | | ○ | monicar trouble |
| | 9:49 | MP-4 | 43.7 μSv/h | - | Fine | W | 1.1 | | | | | ○ | monicar trouble |
| | 9:50 | MP-3 | 274.9 μSv/h | below 0.01μSv/h | - | SSE | 1.2 | | | | | | |
| | 9:51 | MP-4 | 43.7 μSv/h | - | Fine | WNW | 1.1 | | | | | ○ | monicar trouble |
| | 9:53 | MP-3 | 268.0 μSv/h | below 0.01μSv/h | - | WNW | 0.8 | ○ | | | | | Sec Team unsent |
| | 9:53 | MP-4 | 43.3 μSv/h | - | Fine | WNW | 1.1 | | | | | | |
| | 9:55 | MP-4 | 42.8 μSv/h | - | v | WNW | 1.1 | | | | | ○ | monicar trouble |
| | 9:57 | MP-4 | 42.6 μSv/h | - | Fine | NW | 1.0 | | | | | ○ | monicar trouble |
| | 9:59 | MP-4 | 42.5 μSv/h | - | Fine | NNW | 1.0 | | | | | ○ | monicar trouble |
| | 10:00 | MP-3 | 269.4 μSv/h | below 0.01μSv/h | - | SW | 1.3 | | | | | | |
| | 10:01 | MP-4 | 42.2 μSv/h | - | Fine | NNW | 1.2 | | | | | ○ | monicar trouble |
| | 10:03 | MP-4 | 42.1 μSv/h | - | Fine | NW | 1.6 | | | | | ○ | monicar trouble |
| | 10:05 | MP-3 | 304.8 μSv/h | below 0.01μSv/h | - | NW | 1.2 | ○ | | | | | Sec Team unsent |
| | 10:05 | MP-4 | 42.0 μSv/h | - | Fine | NW | 1.8 | | | | | | |
| | 10:07 | MP-4 | 41.9 μSv/h | - | Fine | NW | 2.1 | | | | | ○ | monicar trouble |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 10:09 | MP-4 | 41.7 μSv/h | - | Fine | NNW | 2.2 | | | | | ○ | monicar trouble |
| | 10:10 | MP-3 | 266.8 μSv/h | below 0.01μSv/h | - | SW | 1.3 | | | | | | |
| | 10:11 | MP-4 | 41.5 μSv/h | - | Fine | NNW | 2.1 | | | | | | |
| | 10:13 | MP-4 | 41.4 μSv/h | - | Fine | NNW | 2.1 | | | | | ○ | monicar trouble |
| | 10:15 | MP-4 | 41.2 μSv/h | - | Fine | NNW | 2.3 | | | | | ○ | monicar trouble |
| | 10:17 | MP-4 | 41.1 μSv/h | - | Fine | NNW | 2.4 | | | | | ○ | monicar trouble |
| | 10:19 | MP-4 | 41.0 μSv/h | - | Fine | NW | 2.5 | | | | | ○ | monicar trouble |
| | 10:20 | MP-3 | 265.4 μSv/h | below 0.01μSv/h | - | SW | 1.2 | | | | | | |
| | 10:21 | MP-4 | 40.9 μSv/h | - | Fine | NW | 2.6 | | | | | ○ | monicar trouble |
| | 10:23 | MP-4 | 40.9 μSv/h | - | Fine | NW | 2.4 | | | | | ○ | monicar trouble |
| | 10:25 | MP-4 | 40.8 μSv/h | - | Fine | NW | 2.3 | | | | | ○ | monicar trouble |
| | 10:27 | MP-4 | 40.7 μSv/h | - | Fine | NW | 2.5 | | | | | | |
| | 10:29 | MP-4 | 39.4 μSv/h | - | Fine | NW | 2.7 | | | | | ○ | monicar trouble |
| | 10:30 | MP-3 | 261.6 μSv/h | below 0.01μSv/h | - | W | 1.2 | | | | | | |
| | 10:31 | MP-4 | 40.1 μSv/h | - | Fine | NW | 3.1 | | | | | ○ | monicar trouble |
| | 10:33 | MP-4 | 40.1 μSv/h | - | Fine | NW | 3.6 | | | | | ○ | monicar trouble |
| | 10:35 | MP-4 | 40.2 μSv/h | - | Fine | NW | 3.7 | | | | | | |
| | 10:37 | MP-4 | 39.9 μSv/h | - | Fine | NW | 3.4 | | | | | ○ | monicar trouble |
| | 10:39 | MP-4 | 39.8 μSv/h | - | Fine | NW | 3.2 | | | | | ○ | monicar trouble |
| | 10:40 | MP-3 | 261.9 μSv/h | below 0.01μSv/h | - | W | 1.1 | | | | | | |
| | 10:41 | MP-4 | 39.7 μSv/h | - | Fine | NW | 3.0 | | | | | | |
| | 10:43 | MP-4 | 39.6 μSv/h | - | Fine | NW | 2.9 | | | | | ○ | monicar trouble |
| | 10:45 | MP-4 | 39.5 μSv/h | - | Fine | NW | 2.7 | | | | | ○ | monicar trouble |
| | 10:47 | MP-4 | 39.4 μSv/h | - | Fine | NW | 3.0 | | | | | ○ | monicar trouble |
| | 10:49 | MP-4 | 39.4 μSv/h | - | Fine | NW | 3.0 | | | | | ○ | monicar trouble |
| | 10:50 | MP-3 | 261.0 μSv/h | below 0.01μSv/h | - | SSW | 0.8 | | | | | | |
| | 10:51 | MP-4 | 39.4 μSv/h | - | Fine | NNW | 2.9 | | | | | | |
| | 10:52 | MP-3 | 260.3 μSv/h | below 0.01μSv/h | - | S | 0.8 | ○ | | | | | Sec Team unsent |
| | 10:53 | MP-4 | 39.2 μSv/h | - | Fine | NW | 2.7 | | | | | ○ | monicar trouble |
| | 10:54 | MP-3 | 260.3 μSv/h | below 0.01μSv/h | - | W | 0.8 | ○ | | | | | Sec Team unsent |
| | 10:55 | MP-4 | 39.0 μSv/h | - | Fine | NW | 2.9 | | | | | ○ | monicar trouble |
| | 10:56 | MP-3 | 259.5 μSv/h | below 0.01μSv/h | - | W | 0.9 | ○ | | | | | Sec Team unsent |
| | 10:57 | MP-4 | 38.9 μSv/h | - | Fine | NW | 3.0 | | | | | ○ | monicar trouble |
| | 10:58 | MP-3 | 259.6 μSv/h | below 0.01μSv/h | - | NW | 1.0 | ○ | | | | | Sec Team unsent |
| | 10:59 | MP-4 | 38.9 μSv/h | - | Fine | NW | 3.0 | | | | | ○ | monicar trouble |
| | 11:00 | MP-3 | 259.4 μSv/h | below 0.01μSv/h | - | NE | 1.1 | | ○ | | | | HQ not received |
| | 11:01 | MP-4 | 38.8 μSv/h | - | Fine | NW | 3.0 | | | | | ○ | monicar trouble |
| | 11:02 | MP-3 | 259.1 μSv/h | below 0.01μSv/h | - | NW | 1.2 | ○ | | | | | Sec Team unsent |
| | 11:03 | MP-4 | 38.9 μSv/h | - | Fine | NW | 3.2 | | | | | ○ | monicar trouble |
| | 11:04 | MP-3 | 258.7 μSv/h | below 0.01μSv/h | - | NNE | 1.2 | ○ | | | | | Sec Team unsent |
| | 11:05 | MP-4 | 38.7 μSv/h | - | Fine | NW | 3.1 | | | | | ○ | monicar trouble |
| | 11:06 | MP-3 | 258.4 μSv/h | below 0.01μSv/h | - | MW | 1.3 | ○ | | | | | Sec Team unsent |
| | 11:07 | MP-4 | 38.6 μSv/h | - | Fine | WNW | 2.7 | | | | | ○ | monicar trouble |
| | 11:08 | MP-3 | 257.0 μSv/h | below 0.01μSv/h | - | W | 1.2 | ○ | | | | | Sec Team unsent |
| | 11:09 | MP-4 | 38.4 μSv/h | - | Fine | WNW | 2.4 | | | | | ○ | monicar trouble |
| | 11:10 | MP-3 | 258.3 μSv/h | below 0.01μSv/h | - | NE | 1.1 | ○ | | | | | Sec Team unsent |
| | 11:11 | MP-4 | 38.5 μSv/h | - | Fine | WNW | 2.4 | | | | | ○ | monicar trouble |
| | 11:13 | MP-4 | 40.9 μSv/h | - | Fine | WNW | 2.3 | | | | | ○ | monicar trouble |
| | 11:15 | MP-4 | 25.3 μSv/h | - | Fine | WNW | 2.8 | | | | | ○ | monicar trouble |
| | 11:17 | MP-4 | 8.8 μSv/h | - | Fine | W | 4.2 | | | | | ○ | monicar trouble |
| | 11:19 | MP-4 | 7.5 μSv/h | - | Fine | W | 4.5 | | | | | ○ | monicar trouble |
| | 11:21 | MP-4 | 6.2 μSv/h | - | Fine | W | 5.7 | | | | | ○ | monicar trouble |
| | 11:23 | MP-4 | 6.3 μSv/h | - | Fine | WSW | 6.0 | | | | | ○ | monicar trouble |
| | 11:25 | MP-4 | 6.3 μSv/h | - | Fine | WSW | 5.3 | | | | | ○ | monicar trouble |
| | 11:27 | MP-4 | 6.2 μSv/h | - | Fine | WSW | 4.1 | | | | | ○ | monicar trouble |
| | 11:29 | MP-4 | 6.2 μSv/h | - | Fine | WSW | 4.3 | | | | | ○ | monicar trouble |
| | 11:31 | MP-4 | 6.4 μSv/h | - | Fine | WSW | 3.7 | | | | | ○ | monicar trouble |
| | 11:33 | MP-4 | 7.2 μSv/h | - | Fine | W | 3.9 | | | | | ○ | monicar trouble |
| | 11:35 | MP-4 | 7.9 μSv/h | - | Fine | W | 4.5 | | | | | ○ | monicar trouble |
| | 11:37 | MP-4 | 7.4 μSv/h | - | Fine | W | 4.6 | | | | | ○ | monicar trouble |
| | 11:37 | Main Gate | 50.4 μSv/h | below 0.01μSv/h | - | - | - | | | | | | |
| | 11:39 | MP-4 | 7.4 μSv/h | - | Fine | NW | 4.1 | | | | | ○ | monicar trouble |
| | 11:41 | MP-4 | 7.7 μSv/h | - | Fine | NW | 3.3 | | | | | ○ | monicar trouble |
| | 11:43 | MP-4 | 8.0 μSv/h | - | Fine | NW | 2.6 | | | | | ○ | monicar trouble |
| | 11:44 | Main Gate | 19.6 μSv/h | below 0.01μSv/h | - | - | - | | | | | | |
| | 11:45 | MP-4 | 8.0 μSv/h | - | Fine | E | 2.1 | | | | | ○ | monicar trouble |
| | 11:47 | MP-4 | 7.7 μSv/h | - | Fine | N | 1.6 | | | | | ○ | monicar trouble |
| | 11:49 | MP-4 | 7.6 μSv/h | - | Fine | NNE | 1.6 | | | | | ○ | monicar trouble |
| | 11:51 | MP-4 | 8.4 μSv/h | - | Fine | E | 1.9 | | | | | ○ | monicar trouble |
| | 11:53 | MP-4 | 11.5 μSv/h | - | Fine | W | 1.7 | | | | | ○ | monicar trouble |
| | 0:04 | MP-7 | 6.2 μSv/h | below 0.01μSv/h | - | W | 2.3 | | ○ | | | | HQ not received |
| | 0:06 | MP-7 | 6.0 μSv/h | below 0.01μSv/h | - | - | - | | ○ | | | | HQ not received |
| | 0:06 | Main Gate | 10.8 μSv/h | below 0.01μSv/h | - | NNE | 1.9 | | | | | | |
| | 0:16 | MP-7 | 6.0 μSv/h | below 0.01μSv/h | - | NNW | 1.6 | | ○ | | | | HQ not received |
| | 0:21 | Main Gate | 10.7 μSv/h | below 0.01μSv/h | - | WNW | 0.9 | | | | | | |
| | 0:34 | MP-6 | 4.2 μSv/h | below 0.01μSv/h | - | NW | 3.1 | | | | | | |
| | 0:46 | MP-5 | 6.9 μSv/h | below 0.01μSv/h | - | N | 2.3 | | | | | | |
| | 0:52 | MP-4 | 31.5 μSv/h | below 0.01μSv/h | - | WSW | 3.2 | | | | | | |
| | 13:04 | MP-3 | 229.7 μSv/h | below 0.01μSv/h | - | SE | 3.1 | | | | | | |
| | 13:10 | Main Gate | 12.0 μSv/h | - | - | - | - | | | | | | |
| | 13:12 | MP-4 | 34.2 μSv/h | below 0.01μSv/h | - | SW | 2.4 | | | | | | |
| | 13:15 | Main Gate | 13.0 μSv/h | - | - | - | - | | | | | | |
| | 13:20 | Main Gate | 15.0 μSv/h | - | - | - | - | | | | | | |
| | 13:25 | Main Gate | 14.0 μSv/h | - | - | - | - | | | | | | |
| | 13:28 | MP-5 | 6.4 μSv/h | below 0.01μSv/h | - | N | 2.7 | | | | | | |
| | 13:30 | Main Gate | 13.0 μSv/h | - | - | - | - | | | | | | |
| | 13:35 | Main Gate | 13.0 μSv/h | - | - | - | - | | | | | | |
| | 13:40 | Main Gate | 11.0 μSv/h | - | - | - | - | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|--------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 13:40 | MP-6 | 3.7 μSv/h | below 0.01μSv/h | - | NNW | 1.0 | | | | | | |
| | 13:45 | Main Gate | 12.0 μSv/h | - | - | - | - | | | | | | |
| | 13:50 | Main Gate | 13.0 μSv/h | - | - | - | - | | | | | | |
| | 13:55 | Main Gate | 15.0 μSv/h | - | - | - | - | | | | | | |
| | 14:02 | MP-5 | 6.1 μSv/h | below 0.01μSv/h | - | N | 2.3 | | | | | | |
| | 14:14 | MP-4 | 29.8 μSv/h | below 0.01μSv/h | - | NW | 2.6 | | | | | | |
| | 14:30 | MP-3 | 231.1 μSv/h | below 0.01μSv/h | - | NW | 2.6 | | | | | | |
| | 14:46 | MP-4 | 31.3 μSv/h | below 0.01μSv/h | - | N | 2.2 | | | | | | |
| | 14:58 | MP-5 | 6.2 μSv/h | below 0.01μSv/h | - | N | 3.6 | | | | | | |
| | 15:09 | MP-6 | 3.9 μSv/h | below 0.01μSv/h | - | N | 2.2 | | | | | | |
| | 15:16 | MP-5 | 6.0 μSv/h | below 0.01μSv/h | - | NNE | 2.6 | | | | | | |
| | 15:23 | MP-4 | 29.6 μSv/h | below 0.01μSv/h | - | - | 3.2 | | | | | | |
| | 15:33 | MP-3 | 226.2 μSv/h | below 0.01μSv/h | - | NNW | 3.8 | | | | | | |
| | 15:38 | MP-4 | 30.4 μSv/h | below 0.01μSv/h | - | - | 3.6 | | | | | | |
| | 16:02 | MP-5 | 5.9 μSv/h | below 0.01μSv/h | - | WNW | 3.2 | | | | | | |
| | 16:10 | MP-6 | 3.7 μSv/h | below 0.01μSv/h | - | NNE | 2.1 | | | | | | |
| | 17:00 | Main Gate | 8.1 μSv/h | below 0.01μSv/h | - | WNW | 2.5 | | | | | | |
| | 17:10 | Main Gate | 8.1 μSv/h | below 0.01μSv/h | - | NW | 3.1 | | | | | | |
| | 17:20 | Main Gate | 7.3 μSv/h | below 0.01μSv/h | - | WNW | 2.7 | | | | | | |
| | 17:30 | Main Gate | 7.6 μSv/h | below 0.01μSv/h | - | W | 2.8 | | | | | | |
| | 17:40 | Main Gate | 7.6 μSv/h | below 0.01μSv/h | - | SW | 1.7 | | | | | | |
| | 17:50 | Main Gate | 8.0 μSv/h | below 0.01μSv/h | - | W | 1.9 | | | | | | |
| | 18:00 | Main Gate | 7.6 μSv/h | below 0.01μSv/h | - | W | 1.2 | | | | | | |
| | 18:10 | Main Gate | 7.0 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 18:20 | Main Gate | 7.2 μSv/h | below 0.01μSv/h | - | NW | 1.1 | | | | | | |
| | 18:30 | Main Gate | 8.0 μSv/h | below 0.01μSv/h | - | SSE | 1.2 | | | | | | |
| | 18:40 | Main Gate | 10.4 μSv/h | below 0.01μSv/h | - | E | 0.8 | | | | | | |
| | 18:46 | Main Gate | 10.1 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 19:00 | Main Gate | 7.7 μSv/h | below 0.01μSv/h | - | SE | 0.7 | | | | | | |
| | 19:10 | Main Gate | 7.8 μSv/h | below 0.01μSv/h | - | SE | 0.8 | | | | | | |
| | 19:20 | Main Gate | 7.7 μSv/h | below 0.01μSv/h | - | S | 0.6 | | | | | | |
| | 19:30 | Main Gate | 8.9 μSv/h | below 0.01μSv/h | - | N | 0.6 | | | | | | |
| | 19:40 | Main Gate | 7.6 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 19:50 | Main Gate | 5.5 μSv/h | below 0.01μSv/h | - | E | 0.8 | | | | | | |
| | 20:00 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | N | 0.7 | | | | | | |
| | 20:10 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | NW | 0.8 | | | | | | |
| | 20:20 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | WNW | 1.0 | | | | | | |
| | 20:30 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | NW | - | | | | | | |
| | 20:40 | Main Gate | 5.4 μSv/h | below 0.01μSv/h | - | WNW | - | | | | | | |
| | 20:50 | Main Gate | 5.8 μSv/h | below 0.01μSv/h | - | W | 0.9 | | | | | | |
| | 20:55 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 21:00 | Main Gate | 5.8 μSv/h | 0.01 μSv/h | - | N | 0.9 | | | | | | |
| | 21:05 | Main Gate | 5.8 μSv/h | below 0.01μSv/h | - | SW | 1.0 | | | | | | |
| | 21:10 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | SW | 1.0 | | | | | | |
| | 21:15 | Main Gate | 5.8 μSv/h | below 0.01μSv/h | - | N | 0.9 | | | | | | |
| | 21:20 | Main Gate | 6.0 μSv/h | below 0.01μSv/h | - | NW | 0.7 | | | | | | |
| | 21:25 | Main Gate | 6.8 μSv/h | below 0.01μSv/h | - | SW | 0.9 | | | | | | |
| | 21:30 | Main Gate | 29.7 μSv/h | below 0.01μSv/h | - | SE | 1.0 | | | | | | |
| | 21:35 | Main Gate | 760.0 μSv/h | below 0.01μSv/h | - | SE | 1.6 | | | | | | |
| | 21:37 | Main Gate | 3130.0 μSv/h | below 0.01μSv/h | - | S | 1.7 | | | | | | |
| | 22:15 | Main Gate | 431.7 μSv/h | below 0.01μSv/h | - | N | 1.2 | | | | | | |
| | 22:20 | Main Gate | 336.6 μSv/h | below 0.01μSv/h | - | N | 1.2 | | | | | | |
| | 22:25 | Main Gate | 301.9 μSv/h | below 0.01μSv/h | - | SW | 4.6 | | | | | | |
| | 22:35 | Main Gate | 326.2 μSv/h | below 0.01μSv/h | - | NE | 4.2 | | | | | | |
| | 22:40 | Main Gate | 293.7 μSv/h | below 0.01μSv/h | - | NNE | 4.4 | ○ | | | | | Sec Team unsent |
| | 22:45 | Main Gate | 271.7 μSv/h | below 0.01μSv/h | - | NNE | 4.4 | ○ | | | | | Sec Team unsent |
| | 22:50 | Main Gate | 267.0 μSv/h | below 0.01μSv/h | - | NNE | 4.4 | ○ | | | | | Sec Team unsent |
| | 22:55 | Main Gate | 263.0 μSv/h | below 0.01μSv/h | - | NNE | 4.4 | ○ | | | | | Sec Team unsent |
| | 23:00 | Main Gate | 252.7 μSv/h | below 0.01μSv/h | - | NNE | 4.8 | ○ | | | | | Sec Team unsent |
| | 23:05 | Main Gate | 242.8 μSv/h | below 0.01μSv/h | - | NE | 2.2 | ○ | | | | | Sec Team unsent |
| | 23:10 | Main Gate | 235.3 μSv/h | below 0.01μSv/h | - | NE | 2.1 | ○ | | | | | Sec Team unsent |
| | 23:15 | Main Gate | 231.4 μSv/h | below 0.01μSv/h | - | N | 2.2 | ○ | | | | | Sec Team unsent |
| | 23:20 | Main Gate | 227.0 μSv/h | 0.01 μSv/h | - | N | 2.2 | ○ | | | | | Sec Team unsent |
| | 23:25 | Main Gate | 216.0 μSv/h | below 0.01μSv/h | - | NNW | 1.8 | ○ | | | | | Sec Team unsent |
| | 23:30 | Main Gate | 216.0 μSv/h | below 0.01μSv/h | - | NNW | 1.8 | ○ | | | | | Sec Team unsent |
| | 23:35 | Main Gate | 211.3 μSv/h | below 0.01μSv/h | - | NNE | 1.8 | ○ | | | | | Sec Team unsent |
| | 23:40 | Main Gate | 205.6 μSv/h | below 0.01μSv/h | - | NNW | 1.1 | ○ | | | | | Sec Team unsent |
| | 23:45 | Main Gate | 201.7 μSv/h | below 0.01μSv/h | - | NW | 1.0 | ○ | | | | | Sec Team unsent |
| | 23:50 | Main Gate | 196.2 μSv/h | 0.01 μSv/h | - | WNW | 0.9 | ○ | | | | | Sec Team unsent |
| | 23:55 | Main Gate | 192.3 μSv/h | 0.02 μSv/h | - | W | 0.8 | ○ | | | | | Sec Team unsent |
| 3/15 | 0:00 | Main Gate | 188.9 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | ○ | | | | | Sec Team unsent |
| | 0:05 | Main Gate | 185.0 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | ○ | | | | | Sec Team unsent |
| | 0:10 | Main Gate | 181.0 μSv/h | 0.01 μSv/h | - | NNE | 0.6 | ○ | | | | | Sec Team unsent |
| | 0:15 | Main Gate | 177.3 μSv/h | 0.02 μSv/h | - | NE | 0.6 | ○ | | | | | Sec Team unsent |
| | 0:20 | Main Gate | 175.8 μSv/h | 0.01 μSv/h | - | NE | 0.5 | ○ | | | | | Sec Team unsent |
| | 0:25 | Main Gate | 173.3 μSv/h | below 0.01μSv/h | - | N | 0.5 | ○ | | | | | Sec Team unsent |
| | 0:30 | Main Gate | 168.0 μSv/h | below 0.01μSv/h | - | N | 0.6 | ○ | | | | | Sec Team unsent |
| | 0:35 | Main Gate | 164.9 μSv/h | below 0.01μSv/h | - | N | 0.7 | ○ | | | | | Sec Team unsent |
| | 0:40 | Main Gate | 164.4 μSv/h | below 0.01μSv/h | - | NNE | 0.8 | ○ | | | | | Sec Team unsent |
| | 0:45 | Main Gate | 167.6 μSv/h | below 0.01μSv/h | - | ENE | 0.8 | ○ | | | | | Sec Team unsent |
| | 0:50 | Main Gate | 164.3 μSv/h | 0.01 μSv/h | - | N | 0.6 | ○ | | | | | Sec Team unsent |
| | 0:55 | Main Gate | 151.7 μSv/h | below 0.01μSv/h | - | NW | 0.5 | ○ | | | | | Sec Team unsent |
| | 1:00 | Main Gate | 150.3 μSv/h | below 0.01μSv/h | - | NNW | 0.5 | ○ | | | | | Sec Team unsent |
| | 1:05 | Main Gate | 147.1 μSv/h | 0.01 μSv/h | - | NNE | 0.7 | ○ | | | | | Sec Team unsent |
| | 1:10 | Main Gate | 144.1 μSv/h | below 0.01μSv/h | - | N | 1.1 | ○ | | | | | Sec Team unsent |
| | 1:15 | Main Gate | 141.4 μSv/h | below 0.01μSv/h | - | N | 1.3 | ○ | | | | | Sec Team unsent |
| | 1:20 | Main Gate | 137.8 μSv/h | below 0.01μSv/h | - | NNW | 1.3 | | | | | | |
| | 1:30 | Main Gate | 135.5 μSv/h | 0.02 μSv/h | - | NNE | 1.1 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|----------------------|-------|-----------|---------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 1:40 | Main Gate | 130.4 μSv/h | 0.01 μSv/h | - | N | 1.0 | | | | | | |
| | 1:50 | Main Gate | 123.3 μSv/h | below 0.01μSv/h | - | NE | 2.8 | | | | | | |
| | 2:00 | Main Gate | 120.2 μSv/h | below 0.01μSv/h | - | NNE | 3.4 | | | | | | |
| | 2:10 | Main Gate | 114.1 μSv/h | below 0.01μSv/h | - | NNE | 3.2 | | | | | | |
| | 2:20 | Main Gate | 111.4 μSv/h | below 0.01μSv/h | - | N | 3.6 | | | | | | |
| | 2:30 | Main Gate | 109.6 μSv/h | below 0.01μSv/h | - | NE | 3.6 | | | | | | |
| | 2:40 | Main Gate | 105.4 μSv/h | below 0.01μSv/h | - | NNE | 3.4 | | | | | | |
| | 3:10 | Main Gate | 94.3 μSv/h | below 0.01μSv/h | - | N | 3.4 | | | | | | |
| | 3:20 | Main Gate | 92.8 μSv/h | below 0.01μSv/h | - | NE | 4.2 | | | | | | |
| | 3:40 | Main Gate | 87.0 μSv/h | below 0.01μSv/h | - | NNW | 2.0 | | | | | | |
| | 4:00 | Main Gate | 81.9 μSv/h | below 0.01μSv/h | - | N | 2.1 | | | | | | |
| | 4:20 | Main Gate | 77.6 μSv/h | below 0.01μSv/h | - | NE | 1.0 | | | | | | |
| | 4:40 | Main Gate | 73.6 μSv/h | below 0.01μSv/h | - | N | 0.8 | | | | | | |
| | 5:00 | Main Gate | 70.0 μSv/h | below 0.01μSv/h | - | NE | 0.9 | | | | | | |
| | 5:20 | Main Gate | 67.4 μSv/h | below 0.01μSv/h | - | NNW | 0.7 | | | | | | |
| | 5:40 | Main Gate | 65.7 μSv/h | below 0.01μSv/h | - | N | 0.7 | | | | | | |
| | 6:00 | Main Gate | 73.2 μSv/h | below 0.01μSv/h | - | N | 0.8 | | | | | | |
| Article 15-72 notice | 6:50 | Main Gate | 583.7 μSv/h | below 0.01μSv/h | - | NE | 2.9 | | ○ | | | | HQ not received |
| | 6:53 | Main Gate | 369.8 μSv/h | - | - | - | - | ○ | | | | | Sec Team unsent |
| | 6:55 | Main Gate | 456.5 μSv/h | below 0.01μSv/h | - | NE | 1.6 | ○ | | | | | Sec Team unsent |
| | 7:00 | Main Gate | 965.4 μSv/h | below 0.01μSv/h | - | NNE | 1.7 | ○ | | | | | Sec Team unsent |
| | 7:02 | Main Gate | 882.7 μSv/h | below 0.01μSv/h | - | NE | 1.9 | ○ | | | | | Sec Team unsent |
| | 7:10 | Main Gate | 431.8 μSv/h | below 0.01μSv/h | - | NE | 1.8 | ○ | | | | | Sec Team unsent |
| | 7:15 | Main Gate | 360.8 μSv/h | below 0.01μSv/h | - | NNE | 1.9 | ○ | | | | | Sec Team unsent |
| | 7:20 | Main Gate | 302.1 μSv/h | below 0.01μSv/h | - | N | 1.9 | ○ | | | | | Sec Team unsent |
| | 7:25 | Main Gate | 234.7 μSv/h | below 0.01μSv/h | - | NE | 2.0 | ○ | | | | | Sec Team unsent |
| | 7:30 | Main Gate | 250.8 μSv/h | below 0.01μSv/h | - | NNE | 2.1 | ○ | | | | | Sec Team unsent |
| | 7:38 | Main Gate | 1390.0 μSv/h | below 0.01μSv/h | - | NNW | 1.7 | ○ | | | | | Sec Team unsent |
| | 7:40 | Main Gate | 529.0 μSv/h | below 0.01μSv/h | - | N | 1.6 | ○ | | | | | Sec Team unsent |
| | 7:45 | Main Gate | 537.4 μSv/h | below 0.01μSv/h | - | E | 1.5 | ○ | | | | | Sec Team unsent |
| | 7:50 | Main Gate | 1941.0 μSv/h | below 0.01μSv/h | - | E | 1.7 | ○ | | | | | Sec Team unsent |
| | 7:55 | Main Gate | 1093.0 μSv/h | below 0.01μSv/h | - | N | 1.8 | ○ | | | | | Sec Team unsent |
| | 8:00 | Main Gate | 873.1 μSv/h | below 0.01μSv/h | - | NNE | 1.8 | ○ | | | | | Sec Team unsent |
| | 8:05 | Main Gate | 378.4 μSv/h | below 0.01μSv/h | - | NNE | 1.6 | ○ | | | | | Sec Team unsent |
| | 8:10 | Main Gate | 268.9 μSv/h | below 0.01μSv/h | - | NE | 1.6 | ○ | | | | | Sec Team unsent |
| | 8:15 | Main Gate | 735.9 μSv/h | below 0.01μSv/h | - | E | 1.7 | ○ | | | | | Sec Team unsent |
| | 8:20 | Main Gate | 807.7 μSv/h | below 0.01μSv/h | - | NE | 1.5 | | | | | | |
| | 8:25 | Main Gate | 1413.0 μSv/h | below 0.01μSv/h | - | N | 1.3 | | | | ○ | | |
| | 8:31 | Main Gate | 8217.0 μSv/h | below 0.01μSv/h | - | NE | 1.5 | | | | | | |
| | 8:35 | Main Gate | 2406.0 μSv/h | below 0.01μSv/h | - | N | 1.6 | | | | ○ | | |
| | 8:40 | Main Gate | 1726.0 μSv/h | below 0.01μSv/h | - | N | 1.6 | | | | | | |
| | 8:45 | Main Gate | 1811.0 μSv/h | below 0.01μSv/h | - | N | 1.6 | | | | ○ | | |
| | 8:50 | Main Gate | 2208.0 μSv/h | below 0.01μSv/h | - | N | 1.8 | | | | | | |
| | 8:55 | Main Gate | 3509.0 μSv/h | below 0.01μSv/h | - | NE | 1.5 | | | | ○ | | |
| | 9:00 | Main Gate | 11930.0 μSv/h | below 0.01μSv/h | - | NNE | 1.5 | | | | | | |
| | 9:15 | MP-4 | 58.0 μSv/h | - | - | - | - | | | | | | |
| | 9:20 | MP-4 | 50.0 μSv/h | - | - | - | - | | | | | | |
| | 9:35 | Main Gate | 7241.0 μSv/h | below 0.01μSv/h | - | NE | 5.3 | | | | | | |
| | 10:15 | Main Gate | 8837.0 μSv/h | - | - | - | - | | | | | | |
| | 10:25 | Main Gate | 3342.0 μSv/h | below 0.01μSv/h | - | NE | 3.0 | ○ | | | | | Sec Team unsent |
| | 11:40 | West Gate | 253.8 μSv/h | below 0.01μSv/h | - | - | - | | | | | | |
| | 11:45 | West Gate | 162.4 μSv/h | - | - | - | - | | | | | | |
| | 0:05 | West Gate | 2431.0 μSv/h | below 0.01μSv/h | - | SE | 1.2 | | | | | | |
| | 0:10 | West Gate | 2142.0 μSv/h | below 0.01μSv/h | - | SE | 1.3 | | | | ○ | | |
| | 0:15 | West Gate | 2434.0 μSv/h | below 0.01μSv/h | - | E | 1.3 | | | | | | |
| | 0:25 | Main Gate | 1407.0 μSv/h | below 0.01μSv/h | - | ESE | 3.4 | | | | | | |
| | 0:30 | Main Gate | 1362.0 μSv/h | below 0.01μSv/h | - | ESE | 1.6 | | | | ○ | | |
| | 0:35 | Main Gate | 1325.0 μSv/h | below 0.01μSv/h | - | SE | 1.3 | | | | | | |
| | 0:40 | Main Gate | 1300.0 μSv/h | below 0.01μSv/h | - | SE | 1.3 | | | | ○ | | |
| | 0:45 | Main Gate | 1267.0 μSv/h | below 0.01μSv/h | - | S | 1.4 | | | | | | |
| | 0:50 | Main Gate | 1242.0 μSv/h | below 0.01μSv/h | - | SSE | 1.6 | | | | ○ | | |
| | 0:55 | Main Gate | 1216.0 μSv/h | below 0.01μSv/h | - | S | 1.8 | | | | | | |
| | 13:00 | Main Gate | 1191.0 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 13:10 | Main Gate | 1148.0 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 13:20 | Main Gate | 1100.0 μSv/h | below 0.01μSv/h | - | SSE | 1.4 | | | | | | |
| | 13:30 | Main Gate | 1068.0 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 13:40 | Main Gate | 1014.0 μSv/h | below 0.01μSv/h | - | SSE | 1.5 | | | | | | |
| | 13:50 | Main Gate | 969.9 μSv/h | below 0.01μSv/h | - | S | 1.9 | | | | | | |
| | 14:00 | Main Gate | 928.2 μSv/h | below 0.01μSv/h | - | S | 1.6 | | | | | | |
| | 14:10 | Main Gate | 903.9 μSv/h | below 0.01μSv/h | - | S | 1.5 | | | | | | |
| | 14:20 | Main Gate | 874.4 μSv/h | below 0.01μSv/h | - | ESE | 1.4 | | | | | | |
| | 14:30 | Main Gate | 855.5 μSv/h | below 0.01μSv/h | - | S | 1.2 | | | | | | |
| | 14:40 | Main Gate | 821.3 μSv/h | below 0.01μSv/h | - | SSE | 1.2 | | | | | | |
| | 14:50 | Main Gate | 673.8 μSv/h | below 0.01μSv/h | - | E | 1.2 | | | | | | |
| | 15:00 | Main Gate | 649.0 μSv/h | below 0.01μSv/h | - | SE | 1.2 | | | | | | |
| | 15:10 | Main Gate | 628.5 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 15:20 | Main Gate | 613.8 μSv/h | below 0.01μSv/h | - | SE | 1.1 | | | | | | |
| | 15:30 | Main Gate | 596.4 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 15:40 | Main Gate | 566.9 μSv/h | below 0.01μSv/h | - | SE | 1.1 | | | | | | |
| | 15:50 | Main Gate | 544.9 μSv/h | below 0.01μSv/h | - | SSE | 1.3 | | | | | | |
| | 16:00 | Main Gate | 531.6 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 16:10 | Main Gate | 513.2 μSv/h | below 0.01μSv/h | - | SSE | 1.4 | | | | | | |
| | 16:20 | Main Gate | 502.6 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 16:30 | Main Gate | 489.8 μSv/h | below 0.01μSv/h | - | SSE | 1.1 | | | | | | |
| | 16:40 | Main Gate | 473.0 μSv/h | below 0.01μSv/h | - | SSE | 1.3 | | | | | | |
| | 16:50 | Main Gate | 460.3 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 17:00 | Main Gate | 449.4 μSv/h | below 0.01μSv/h | - | S | 1.6 | | | | | | |
| | 17:10 | Main Gate | 437.5 μSv/h | below 0.01μSv/h | - | SE | 1.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscom- munication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|--------------|-----------|---------------|-----------------|-----------------|-----------------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|-----------------|
| | | | | | | | | | | | | | |
| 15-82 notice | 17:30 | Main Gate | 423.5 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 18:00 | Main Gate | 401.7 μSv/h | below 0.01μSv/h | - | SE | 1.2 | | | | | | |
| | 18:30 | Main Gate | 403.0 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 19:00 | Main Gate | 353.8 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 19:30 | Main Gate | 343.3 μSv/h | below 0.01μSv/h | - | S | 1.1 | | | | | | |
| | 20:00 | Main Gate | 347.0 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 20:30 | Main Gate | 311.3 μSv/h | below 0.01μSv/h | - | SSE | 1.3 | | | | | | |
| | 21:00 | Main Gate | 298.8 μSv/h | below 0.01μSv/h | - | E | 1.4 | | | | | | |
| | 21:30 | Main Gate | 282.6 μSv/h | below 0.01μSv/h | - | SSE | 1.8 | | | | | | |
| | 22:00 | Main Gate | 313.2 μSv/h | below 0.01μSv/h | - | SE | 1.6 | | | | | | |
| | 22:30 | Main Gate | 431.8 μSv/h | below 0.01μSv/h | Rain | SE | 1.6 | | | | | | |
| | 23:00 | Main Gate | 4548.0 μSv/h | below 0.01μSv/h | Rain | W | 0.7 | | | | | | |
| | 23:10 | Main Gate | 6960.0 μSv/h | below 0.01μSv/h | Rain | N | 0.7 | | | | | | |
| | 23:15 | Main Gate | 2761.0 μSv/h | below 0.01μSv/h | Rain | S | 0.9 | | | | | | |
| | 23:20 | Main Gate | 3648.0 μSv/h | below 0.01μSv/h | Rain | E | 0.9 | | | | | | |
| | 23:25 | Main Gate | 4976.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.0 | | | | | | |
| | 23:30 | Main Gate | 8080.0 μSv/h | below 0.01μSv/h | Rain | NW | 3.7 | | | | | | |
| | 23:35 | Main Gate | 6308.0 μSv/h | below 0.01μSv/h | Rain | E | 5.6 | | | | | | |
| | 23:40 | Main Gate | 6592.0 μSv/h | below 0.01μSv/h | Rain | NE | 2.7 | | | | | | |
| | 23:45 | Main Gate | 6847.0 μSv/h | below 0.01μSv/h | Rain | NNE | 4.0 | | | | | | |
| | 23:50 | Main Gate | 6066.0 μSv/h | below 0.01μSv/h | Rain | E | 2.2 | | | | | | |
| | 23:55 | Main Gate | 7966.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.7 | | | | | | |
| | 3/16 | 0:00 | Main Gate | 4351.0 μSv/h | below 0.01μSv/h | | NNE | 2.5 | | | | | |
| 0:10 | | Main Gate | 3504.0 μSv/h | below 0.01μSv/h | | NW | 2.1 | | | | | | |
| 0:20 | | Main Gate | 3108.0 μSv/h | below 0.01μSv/h | | N | 2.4 | | | | | | |
| 0:30 | | Main Gate | 2609.0 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| 0:40 | | Main Gate | 2432.0 μSv/h | below 0.01μSv/h | | NW | 0.8 | ○ | | | | | Sec Team unsent |
| 0:50 | | Main Gate | 2257.0 μSv/h | below 0.01μSv/h | | W | 0.8 | ○ | | | | | Sec Team unsent |
| 1:00 | | Main Gate | 2159.0 μSv/h | below 0.01μSv/h | | NW | 0.6 | | | | | | |
| 1:10 | | Main Gate | 2021.0 μSv/h | below 0.01μSv/h | | NW | 0.6 | | | | | | |
| 1:20 | | Main Gate | 1937.0 μSv/h | below 0.01μSv/h | | NE | 3.8 | | | | | | |
| 1:30 | | Main Gate | 1805.0 μSv/h | below 0.01μSv/h | | N | 1.1 | | | | | | |
| 1:40 | | Main Gate | 1708.0 μSv/h | below 0.01μSv/h | | NW | 2.2 | | | | | | |
| 1:50 | | Main Gate | 1628.0 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| 2:00 | | Main Gate | 1552.0 μSv/h | below 0.01μSv/h | | NW | 0.9 | | | | | | |
| 2:10 | | Main Gate | 1522.0 μSv/h | below 0.01μSv/h | | NNW | 0.9 | | | | | | |
| 2:20 | | Main Gate | 1453.0 μSv/h | below 0.01μSv/h | | NW | 1.1 | | | | | | |
| 2:30 | | Main Gate | 1386.0 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| 2:40 | | Main Gate | 1357.0 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| 2:50 | | Main Gate | 1316.0 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| 3:00 | | Main Gate | 1267.0 μSv/h | below 0.01μSv/h | | NW | 1.3 | | | | | | |
| 3:30 | | Main Gate | 1159.0 μSv/h | below 0.01μSv/h | | NW | 5.0 | | | | | | |
| 4:00 | | Main Gate | 1047.0 μSv/h | below 0.01μSv/h | | N | 4.2 | | | | | | |
| 4:30 | | Main Gate | 975.3 μSv/h | below 0.01μSv/h | | NNW | 3.1 | | | | | | |
| 5:00 | | Main Gate | 918.2 μSv/h | below 0.01μSv/h | | NW | 2.9 | | | | | | |
| 5:30 | | Main Gate | 868.0 μSv/h | below 0.01μSv/h | | NNW | 2.6 | | | | | | |
| 6:00 | | Main Gate | 884.0 μSv/h | below 0.01μSv/h | | NW | 2.0 | | | | | | |
| 6:30 | | Main Gate | 848.4 μSv/h | below 0.01μSv/h | | W | 1.4 | | | | | | |
| 6:40 | | Main Gate | 837.0 μSv/h | below 0.01μSv/h | | WNW | 1.4 | | | | | | |
| 6:50 | | Main Gate | 815.9 μSv/h | below 0.01μSv/h | | WNW | 1.4 | | | | | | |
| 7:00 | | Main Gate | 808.8 μSv/h | below 0.01μSv/h | | NW | 1.4 | | | | | | |
| 7:10 | | Main Gate | 670.3 μSv/h | below 0.01μSv/h | | NW | 1.4 | | | | | | |
| 7:20 | | Main Gate | 661.8 μSv/h | below 0.01μSv/h | | NW | 1.2 | | | | | | |
| 7:30 | | Main Gate | 651.1 μSv/h | below 0.01μSv/h | | NW | 1.3 | | | | | | |
| 7:40 | | Main Gate | 644.0 μSv/h | below 0.01μSv/h | | W | 1.2 | | | | | | |
| 7:50 | | Main Gate | 636.8 μSv/h | below 0.01μSv/h | | W | 1.2 | | | | | | |
| 8:00 | | Main Gate | 627.5 μSv/h | below 0.01μSv/h | | NNW | 1.2 | | | | | | |
| 8:10 | | Main Gate | 620.6 μSv/h | below 0.01μSv/h | | WNW | 1.3 | | | | | | |
| 8:20 | | Main Gate | 613.9 μSv/h | below 0.01μSv/h | | NNW | 1.4 | | | | | | |
| 8:30 | | Main Gate | 606.6 μSv/h | below 0.01μSv/h | | NNW | 1.4 | | | | | | |
| 8:40 | | Main Gate | 600.4 μSv/h | below 0.01μSv/h | | N | 1.7 | | | | | | |
| 8:50 | | Main Gate | 593.4 μSv/h | below 0.01μSv/h | | NNW | 2.2 | | | | | | |
| 9:00 | | Main Gate | 587.6 μSv/h | below 0.01μSv/h | | NW | 1.7 | | | | | | |
| 9:10 | | Main Gate | 582.2 μSv/h | below 0.01μSv/h | | N | 2.3 | | | | | | |
| 9:20 | | Main Gate | 582.4 μSv/h | below 0.01μSv/h | | NW | 1.8 | | | | | | |
| 9:30 | | Main Gate | 582.3 μSv/h | below 0.01μSv/h | | NW | 1.9 | | | | | | |
| 9:40 | | Main Gate | 641.8 μSv/h | below 0.01μSv/h | | W | 1.6 | | | | | | |
| 9:50 | | Main Gate | 700.6 μSv/h | below 0.01μSv/h | | NNW | 1.5 | | | | | | |
| 10:00 | | Main Gate | 810.3 μSv/h | below 0.01μSv/h | | ENE | 1.8 | | | | | | |
| 10:10 | | Main Gate | 908.5 μSv/h | below 0.01μSv/h | | NE | 1.5 | | | | | | |
| 10:20 | | Main Gate | 2399.0 μSv/h | below 0.01μSv/h | | ENE | 1.4 | | | | | | |
| 10:30 | | Main Gate | 1361.0 μSv/h | below 0.01μSv/h | | E | 2.2 | | | | | | |
| 10:45 | | Main Gate | 6400.0 μSv/h | below 0.01μSv/h | | ENE | 4.9 | | | | | | |
| 10:54 | | Main Gate | 2300.0 μSv/h | below 0.01μSv/h | | NE | - | | | | | | |
| 10:55 | | Main Gate | 2900.0 μSv/h | below 0.01μSv/h | | - | - | | | | | | |
| 11:00 | | Main Gate | 3391.0 μSv/h | below 0.01μSv/h | | NE | 2.0 | | | | | | |
| 11:10 | | Main Gate | 2720.0 μSv/h | below 0.01μSv/h | | NNE | 1.9 | | | | | | |
| 11:20 | | Main Gate | 1900.0 μSv/h | below 0.01μSv/h | | ENE | 2.3 | | | | | | |
| 11:30 | | Main Gate | 5350.0 μSv/h | below 0.01μSv/h | | NE | 1.6 | | | | | | |
| 11:40 | | Main Gate | 2633.0 μSv/h | below 0.01μSv/h | | E | 1.8 | | | | | | |
| 11:50 | | Main Gate | 2578.0 μSv/h | below 0.01μSv/h | | N | 1.8 | | | | | | |
| 0:00 | | Main Gate | 4418.0 μSv/h | below 0.01μSv/h | | ESE | 1.6 | | | | | | |
| 0:10 | | Main Gate | 3138.0 μSv/h | below 0.01μSv/h | | E | 0.9 | | | | | | |
| 0:20 | Main Gate | 3261.0 μSv/h | below 0.01μSv/h | | N | 1.8 | | | | | | | |
| 0:30 | Main Gate | 10850.0 μSv/h | below 0.01μSv/h | | ENE | 1.4 | | | | | | | |
| 0:40 | Main Gate | 8234.0 μSv/h | below 0.01μSv/h | | W | 1.4 | | | | | | | |
| 0:50 | Main Gate | 2851.0 μSv/h | below 0.01μSv/h | | NW | 4.1 | | | | | | | |
| 13:00 | Main Gate | 2672.0 μSv/h | below 0.01μSv/h | | WSW | 3.0 | | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|------------------|
| | 13:10 | Main Gate | 2538.0 μSv/h | below 0.01μSv/h | | WSW | 1.0 | | | | | | |
| | 13:20 | Main Gate | 2430.0 μSv/h | below 0.01μSv/h | | WSW | 1.2 | | | | | | |
| | 13:30 | Main Gate | 2331.0 μSv/h | below 0.01μSv/h | | N | 2.4 | | | | | | |
| | 13:40 | Main Gate | 2257.0 μSv/h | below 0.01μSv/h | | NW | 2.7 | | | | | | |
| | 13:50 | Main Gate | 2182.0 μSv/h | below 0.01μSv/h | | NW | 2.1 | | | | | | |
| | 14:00 | Main Gate | 2122.0 μSv/h | below 0.01μSv/h | | ENE | 1.7 | | | | | | |
| | 14:10 | Main Gate | 2059.0 μSv/h | below 0.01μSv/h | | SSW | 1.9 | | | | | | |
| | 14:20 | Main Gate | 2022.0 μSv/h | below 0.01μSv/h | | SSW | 2.3 | | | | | | |
| | 14:30 | Main Gate | 1937.0 μSv/h | below 0.01μSv/h | | W | 2.1 | | | | | | |
| | 14:40 | Main Gate | 1888.0 μSv/h | below 0.01μSv/h | | WNW | 2.1 | | | | | | |
| | 14:50 | Main Gate | 1835.0 μSv/h | below 0.01μSv/h | | WSW | 3.1 | | | | | | |
| | 15:00 | Main Gate | 1788.0 μSv/h | below 0.01μSv/h | | NW | 2.3 | | | | | | |
| | 15:10 | Main Gate | 1752.0 μSv/h | below 0.01μSv/h | | NW | 3.4 | | | | | | |
| | 15:20 | Main Gate | 1697.0 μSv/h | below 0.01μSv/h | | NNW | 3.0 | | | | | | |
| | 15:30 | Main Gate | 1664.0 μSv/h | below 0.01μSv/h | | N | 2.7 | | | | | | |
| | 15:40 | Main Gate | 1629.0 μSv/h | below 0.01μSv/h | | NNW | 2.6 | | | | | | |
| | 15:50 | Main Gate | 1591.0 μSv/h | below 0.01μSv/h | | W | 2.6 | | | | | | |
| | 16:00 | Main Gate | 1556.0 μSv/h | below 0.01μSv/h | | W | 1.9 | ○ | | | | | Sec Team unsent |
| | 16:10 | Main Gate | 1530.0 μSv/h | below 0.01μSv/h | | SW | 2.4 | ○ | | | | | Sec Team unsent |
| | 16:20 | Main Gate | 1472.0 μSv/h | below 0.01μSv/h | | NW | 2.1 | ○ | | | | | Sec Team unsent |
| | 17:03 | Gym Hall side | 752.0 μSv/h | below 0.01μSv/h | | — | — | | | ○ | | | HQ disclosed but |
| | 17:05 | Gym Hall side | 751.0 μSv/h | below 0.01μSv/h | | — | — | | | ○ | | | HQ disclosed but |
| | 17:10 | Gym Hall side | 749.3 μSv/h | below 0.01μSv/h | | N | 3.6 | | | ○ | | | HQ disclosed but |
| | 17:20 | Gym Hall side | 745.6 μSv/h | below 0.01μSv/h | | NW | 3.5 | | | ○ | | | HQ disclosed but |
| | 17:30 | Gym Hall side | 741.3 μSv/h | below 0.01μSv/h | | WNW | 3.5 | | | ○ | | | HQ disclosed but |
| | 17:40 | Gym Hall side | 738.2 μSv/h | below 0.01μSv/h | | NNW | 4.0 | | | ○ | | | HQ disclosed but |
| | 17:50 | Gym Hall side | 735.0 μSv/h | below 0.01μSv/h | | NNW | 4.0 | | | ○ | | | HQ disclosed but |
| | 18:00 | Gym Hall side | 731.0 μSv/h | below 0.01μSv/h | | WNW | 4.3 | | | ○ | | | HQ disclosed but |
| | 18:10 | Gym Hall side | 728.0 μSv/h | below 0.01μSv/h | | NW | 3.8 | | | ○ | | | HQ disclosed but |
| | 18:20 | Gym Hall side | 725.9 μSv/h | below 0.01μSv/h | | W | 3.5 | | | ○ | | | HQ disclosed but |
| | 18:30 | Gym Hall side | 723.3 μSv/h | below 0.01μSv/h | | NW | 3.6 | | | ○ | | | HQ disclosed but |
| | 19:00 | West Gate | 385.4 μSv/h | below 0.01μSv/h | | NW | 2.1 | | | ○ | | | HQ disclosed but |
| | 19:30 | West Gate | 380.7 μSv/h | below 0.01μSv/h | | NW | 2.0 | | | ○ | | | HQ disclosed but |
| | 20:00 | West Gate | 375.5 μSv/h | below 0.01μSv/h | | NNW | 2.1 | | | ○ | | | HQ disclosed but |
| | 20:30 | West Gate | 373.6 μSv/h | below 0.01μSv/h | | NNW | 1.9 | | | ○ | | | HQ disclosed but |
| | 21:00 | West Gate | 370.2 μSv/h | below 0.01μSv/h | | NNW | 1.2 | | | ○ | | | HQ disclosed but |
| | 21:30 | West Gate | 366.5 μSv/h | below 0.01μSv/h | | NNW | 1.0 | | | ○ | | | HQ disclosed but |
| | 22:00 | West Gate | 363.7 μSv/h | below 0.01μSv/h | | NW | 1.2 | | | ○ | | | HQ disclosed but |
| | 22:30 | West Gate | 361.2 μSv/h | below 0.01μSv/h | | ESE | 0.4 | | | ○ | | | HQ disclosed but |
| | 23:00 | West Gate | 358.8 μSv/h | below 0.01μSv/h | | NNE | 0.5 | | | ○ | | | HQ disclosed but |
| | 23:30 | West Gate | 355.7 μSv/h | below 0.01μSv/h | | NNE | 0.8 | | | ○ | | | HQ disclosed but |
| 3/17 | 0:30 | West Gate | 351.4 μSv/h | below 0.01μSv/h | | NE | 1.1 | | | | | | |
| | 0:50 | West Gate | 350.1 μSv/h | below 0.01μSv/h | | SSW | 0.4 | | | | | | |
| | 1:00 | West Gate | 350.0 μSv/h | below 0.01μSv/h | | NNW | 0.6 | | | | | | |
| | 1:30 | West Gate | 348.2 μSv/h | below 0.01μSv/h | | E | 0.9 | | | | | | |
| | 2:00 | West Gate | 345.9 μSv/h | below 0.01μSv/h | | W | 0.5 | | | | | | |
| | 2:30 | West Gate | 344.8 μSv/h | below 0.01μSv/h | | NW | 1.5 | | | | | | |
| | 3:00 | West Gate | 344.6 μSv/h | below 0.01μSv/h | | N | 1.5 | | | | | | |
| | 3:30 | West Gate | 341.7 μSv/h | below 0.01μSv/h | | W | 1.8 | | | | | | |
| | 4:00 | West Gate | 340.8 μSv/h | below 0.01μSv/h | | W | 1.8 | | | | | | |
| | 4:30 | West Gate | 339.4 μSv/h | below 0.01μSv/h | | NW | 1.0 | | | | | | |
| | 5:00 | West Gate | 338.3 μSv/h | below 0.01μSv/h | | W | 1.3 | | | | | | |
| | 5:30 | West Gate | 336.1 μSv/h | below 0.01μSv/h | | W | 2.3 | | | | | | |
| | 6:00 | West Gate | 334.7 μSv/h | below 0.01μSv/h | | W | 3.1 | | | | | | |
| | 6:30 | West Gate | 333.8 μSv/h | below 0.01μSv/h | | W | 3.6 | | | | | | |
| | 7:00 | West Gate | 314.5 μSv/h | below 0.01μSv/h | | W | 3.7 | | | | | | |
| | 7:30 | West Gate | 313.5 μSv/h | below 0.01μSv/h | | W | 3.8 | | | | | | |
| | 7:50 | Gym Hall side | 381.3 μSv/h | below 0.01μSv/h | | W | 3.7 | | | | | | |
| | 8:00 | Gym Hall side | 379.0 μSv/h | below 0.01μSv/h | | SW | 3.7 | | | | | | |
| | 8:30 | Gym Hall side | 373.0 μSv/h | below 0.01μSv/h | | WSW | 3.2 | | | | | | |
| | 8:40 | Gym Hall side | 372.5 μSv/h | below 0.01μSv/h | | SW | 3.8 | | | | | | |
| | 8:50 | Gym Hall side | 372.7 μSv/h | below 0.01μSv/h | | SW | 3.4 | | | | | | |
| | 9:00 | Gym Hall side | 373.7 μSv/h | below 0.01μSv/h | | SW | 3.7 | | | | | | |
| | 9:10 | Gym Hall side | 371.9 μSv/h | below 0.01μSv/h | | SW | 3.0 | | | | | | |
| | 9:30 | Main Build North | 3786.0 μSv/h | below 0.01μSv/h | | W | 5.1 | | | | | | |
| | 9:40 | Main Build North | 3782.0 μSv/h | below 0.01μSv/h | | WSW | 5.0 | | | | | | |
| | 9:50 | Main Build North | 3763.0 μSv/h | below 0.01μSv/h | | W | 6.8 | | | | | | |
| | 10:00 | Main Build North | 3759.0 μSv/h | below 0.01μSv/h | | NW | 5.2 | | | | | | |
| | 10:10 | Main Build North | 3755.0 μSv/h | below 0.01μSv/h | | NW | 5.6 | | | | | | |
| | 10:20 | Main Build North | 3754.0 μSv/h | below 0.01μSv/h | | W | 5.2 | | | | | | |
| | 10:30 | Main Build North | 3750.0 μSv/h | below 0.01μSv/h | | W | 7.0 | | | | | | |
| | 10:40 | Main Build North | 3753.0 μSv/h | below 0.01μSv/h | | WSW | 4.5 | | | | | | |
| | 10:50 | Main Build North | 3743.0 μSv/h | below 0.01μSv/h | | SW | 2.2 | | | | | | |
| | 11:00 | Main Gate | 647.3 μSv/h | below 0.01μSv/h | | NW | 4.8 | | | | | | |
| | 11:10 | Main Gate | 646.2 μSv/h | below 0.01μSv/h | | NNW | 2.3 | | | | | | |
| | 11:15 | West Gate | 313.1 μSv/h | below 0.01μSv/h | | NW | 4.7 | | | | | | |
| | 11:20 | West Gate | 312.5 μSv/h | below 0.01μSv/h | | W | 4.4 | | | | | | |
| | 11:30 | West Gate | 312.3 μSv/h | below 0.01μSv/h | | WNW | 2.9 | | | | | | |
| | 0:00 | West Gate | 311.0 μSv/h | below 0.01μSv/h | | W | 3.5 | | | | | | |
| | 0:30 | West Gate | 310.7 μSv/h | below 0.01μSv/h | | W | 3.5 | | | | | | |
| | 13:00 | West Gate | 309.7 μSv/h | below 0.01μSv/h | | W | 3.8 | | | | | | |
| | 13:10 | West Gate | 309.3 μSv/h | below 0.01μSv/h | | W | 3.5 | | | | | | |
| | 13:20 | West Gate | 309.1 μSv/h | below 0.01μSv/h | | W | 3.1 | | | | | | |
| | 13:30 | Main Build North | 4175.0 μSv/h | below 0.01μSv/h | | NW | 4.5 | | | | | | |
| | 13:40 | Main Build North | 4165.0 μSv/h | below 0.01μSv/h | | W | 4.7 | | | | | | |
| | 14:00 | Main Build North | 3810.0 μSv/h | below 0.01μSv/h | | W | 5.2 | | | | | | |
| | 14:10 | West Gate | 311.1 μSv/h | below 0.01μSv/h | | NW | 5.8 | | | | | | |
| | 14:30 | West Gate | 310.3 μSv/h | below 0.01μSv/h | | W | 3.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|-----------------|
| | 15:00 | West Gate | 309.1 μSv/h | below 0.01μSv/h | | W | 3.2 | | | | | | |
| | 15:30 | West Gate | 309.7 μSv/h | below 0.01μSv/h | | W | 3.1 | | | | | | |
| | 15:50 | Main Build North | 3700.0 μSv/h | below 0.01μSv/h | | W | 5.2 | | | | | | |
| | 15:55 | Main Build North | 3699.0 μSv/h | below 0.01μSv/h | | W | 4.7 | | | | ○ | | |
| | 16:00 | Main Build North | 3698.0 μSv/h | below 0.01μSv/h | | W | 4.3 | | | | | | |
| | 16:05 | Main Build North | 3695.0 μSv/h | below 0.01μSv/h | | W | 4.1 | | | | ○ | | |
| | 16:10 | Main Build North | 3695.0 μSv/h | below 0.01μSv/h | | W | 4.3 | | | | | | |
| | 16:15 | Main Build North | 3691.0 μSv/h | below 0.01μSv/h | | W | 4.1 | | | | | | |
| | 17:00 | Main Build North | 3676.0 μSv/h | below 0.01μSv/h | | W | 3.1 | | | | | | |
| | 17:05 | Main Build North | 3676.0 μSv/h | below 0.01μSv/h | | NW | 3.3 | | | | ○ | | |
| | 17:10 | Main Build North | 3675.0 μSv/h | below 0.01μSv/h | | NW | 2.8 | | | | | | |
| | 17:15 | Main Build North | 3675.0 μSv/h | below 0.01μSv/h | | NW | 2.7 | | | | ○ | | |
| | 17:20 | Main Build North | 3672.0 μSv/h | below 0.01μSv/h | | NW | 3.3 | | | | | | |
| | 17:25 | Main Build North | 3670.0 μSv/h | below 0.01μSv/h | | W | 3.2 | | | | ○ | | |
| | 17:30 | Main Build North | 3667.0 μSv/h | below 0.01μSv/h | | NW | 3.4 | | | | | | |
| | 17:35 | Main Build North | 3665.0 μSv/h | below 0.01μSv/h | | NW | 3.7 | | | | ○ | | |
| | 17:40 | Main Build North | 3639.0 μSv/h | below 0.01μSv/h | | WNW | 3.6 | | | | | | |
| | 17:45 | Main Build North | 3653.0 μSv/h | below 0.01μSv/h | | W | 3.3 | | | | ○ | | |
| | 17:50 | Main Build North | 3650.0 μSv/h | below 0.01μSv/h | | W | 2.7 | | | | | | |
| | 17:55 | Main Build North | 3649.0 μSv/h | below 0.01μSv/h | | W | 2.4 | | | | ○ | | |
| | 18:00 | Main Build North | 3649.0 μSv/h | below 0.01μSv/h | | WNW | 2.1 | | | | | | |
| | 18:05 | Main Build North | 3645.0 μSv/h | below 0.01μSv/h | | W | 2.2 | | | | ○ | | |
| | 18:10 | Main Build North | 3641.0 μSv/h | below 0.01μSv/h | | NW | 2.4 | | | | | | |
| | 18:15 | Main Build North | 3641.0 μSv/h | below 0.01μSv/h | | W | 2.4 | | | | ○ | | |
| | 18:20 | Main Build North | 3645.0 μSv/h | below 0.01μSv/h | | W | 2.6 | | | | | | |
| | 18:25 | Main Build North | 3643.0 μSv/h | below 0.01μSv/h | | W | 2.8 | | | | ○ | | |
| | 18:30 | Main Build North | 3643.0 μSv/h | below 0.01μSv/h | | WNW | 2.7 | | | | | | |
| | 18:35 | Main Build North | 3637.0 μSv/h | below 0.01μSv/h | | NW | 2.7 | | | | ○ | | |
| | 18:40 | Main Build North | 3638.0 μSv/h | below 0.01μSv/h | | NW | 2.9 | | | | | | |
| | 18:50 | Main Build North | 3638.0 μSv/h | below 0.01μSv/h | Fine | WNW | 2.4 | | | | | | |
| | 19:00 | Main Build North | 3630.0 μSv/h | below 0.01μSv/h | Fine | WSW | 2.7 | | | | | | |
| | 19:10 | Main Build North | 3626.0 μSv/h | below 0.01μSv/h | Fine | WNW | 2.7 | | | | | | |
| | 19:15 | Main Build North | 3625.0 μSv/h | below 0.01μSv/h | Fine | NW | 2.6 | | ○ | | | | HQ not received |
| | 19:20 | Main Build North | 3623.0 μSv/h | below 0.01μSv/h | Fine | W | 2.3 | | ○ | | | | HQ not received |
| | 19:50 | Main Build North | 3599.0 μSv/h | below 0.01μSv/h | Fine | NW | 4.8 | | ○ | | | | HQ not received |
| | 20:00 | Main Build North | 3601.0 μSv/h | below 0.01μSv/h | Fine | NE | 1.5 | | ○ | | | | HQ not received |
| | 20:10 | Main Build North | 3586.0 μSv/h | below 0.01μSv/h | Fine | WNW | 1.4 | | ○ | | | | HQ not received |
| | 20:40 | West Gate | 292.2 μSv/h | below 0.01μSv/h | - | WNW | 1.2 | | | | | | |
| | 21:00 | West Gate | 291.9 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 21:10 | West Gate | 291.7 μSv/h | below 0.01μSv/h | - | NW | 1.6 | | | | | | |
| | 21:20 | West Gate | 291.3 μSv/h | below 0.01μSv/h | - | W | 1.7 | | | | | | |
| | 21:30 | West Gate | 291.2 μSv/h | below 0.01μSv/h | - | NW | 1.8 | | | | | | |
| | 21:40 | West Gate | 291.1 μSv/h | below 0.01μSv/h | - | NW | 1.5 | | | | | | |
| | 21:50 | West Gate | 290.9 μSv/h | below 0.01μSv/h | - | NW | 1.5 | | | | | | |
| | 22:00 | West Gate | 290.4 μSv/h | below 0.01μSv/h | - | NW | 1.4 | | | | | | |
| | 22:10 | West Gate | 290.4 μSv/h | below 0.01μSv/h | - | NW | 1.5 | | | | | | |
| | 22:20 | West Gate | 289.9 μSv/h | below 0.01μSv/h | - | WNW | 1.3 | | | | | | |
| | 22:30 | West Gate | 289.7 μSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | |
| | 22:40 | West Gate | 289.6 μSv/h | below 0.01μSv/h | - | NW | 1.3 | | | | | | |
| | 22:50 | West Gate | 289.5 μSv/h | below 0.01μSv/h | - | NNW | 1.2 | | | | | | |
| | 23:00 | West Gate | 289.0 μSv/h | below 0.01μSv/h | - | NE | 0.9 | | | | | | |
| | 23:10 | West Gate | 289.0 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 23:20 | West Gate | 288.8 μSv/h | below 0.01μSv/h | - | NNW | 0.7 | | | | | | |
| | 23:30 | West Gate | 288.7 μSv/h | below 0.01μSv/h | - | NW | 1.2 | | | | | | |
| | 23:40 | West Gate | 287.8 μSv/h | below 0.01μSv/h | - | NW | 1.3 | | | | | | |
| | 23:50 | West Gate | 288.9 μSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | |
| 3/18 | 0:00 | West Gate | 287.0 μSv/h | below 0.01μSv/h | - | W | 1.4 | | | | | | |
| | 0:10 | West Gate | 287.3 μSv/h | below 0.01μSv/h | - | W | 1.0 | | | | | | |
| | 0:20 | West Gate | 286.6 μSv/h | below 0.01μSv/h | - | W | 1.0 | | | | | | |
| | 0:30 | West Gate | 286.4 μSv/h | below 0.01μSv/h | - | W | 0.8 | | | | | | |
| | 0:40 | West Gate | 286.3 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 0:50 | West Gate | 286.0 μSv/h | below 0.01μSv/h | - | WNW | 1.0 | | | | | | |
| | 1:00 | West Gate | 285.6 μSv/h | below 0.01μSv/h | - | NW | 1.6 | | | | | | |
| | 1:10 | West Gate | 285.5 μSv/h | below 0.01μSv/h | - | NW | 1.5 | | | | | | |
| | 1:20 | West Gate | 285.2 μSv/h | below 0.01μSv/h | - | NW | 1.7 | | | | | | |
| | 1:30 | West Gate | 284.9 μSv/h | below 0.01μSv/h | - | NW | 1.4 | | | | | | |
| | 1:40 | West Gate | 284.6 μSv/h | below 0.01μSv/h | - | N | 0.9 | | | | | | |
| | 1:50 | West Gate | 284.4 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | |
| | 2:00 | West Gate | 284.0 μSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | |
| | 2:10 | West Gate | 283.7 μSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | |
| | 2:20 | West Gate | 283.7 μSv/h | below 0.01μSv/h | - | NE | 0.2 | | | | | | |
| | 2:30 | West Gate | 283.5 μSv/h | below 0.01μSv/h | - | NE | 0.2 | | | | | | |
| | 2:40 | West Gate | 283.0 μSv/h | below 0.01μSv/h | - | NNE | 0.2 | | | | | | |
| | 2:50 | West Gate | 282.9 μSv/h | below 0.01μSv/h | - | NW | 0.2 | | | | | | |
| | 3:00 | West Gate | 282.6 μSv/h | below 0.01μSv/h | - | W | 0.2 | | | | | | |
| | 3:10 | West Gate | 282.0 μSv/h | below 0.01μSv/h | - | WNW | 0.3 | | | | | | |
| | 3:20 | West Gate | 282.0 μSv/h | below 0.01μSv/h | - | WNW | 0.4 | | | | | | |
| | 3:30 | West Gate | 281.6 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 3:40 | West Gate | 281.5 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | |
| | 3:50 | West Gate | 281.2 μSv/h | below 0.01μSv/h | - | E | 0.4 | | | | | | |
| | 4:00 | West Gate | 281.1 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 4:10 | West Gate | 280.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 4:20 | West Gate | 280.7 μSv/h | below 0.01μSv/h | - | N | 0.4 | | | | | | |
| | 4:30 | West Gate | 280.2 μSv/h | below 0.01μSv/h | - | NW | 0.2 | | | | | | |
| | 4:40 | West Gate | 280.0 μSv/h | below 0.01μSv/h | - | N | 0.6 | | | | | | |
| | 4:50 | West Gate | 279.8 μSv/h | below 0.01μSv/h | - | NE | 0.5 | | | | | | |
| | 5:00 | West Gate | 279.4 μSv/h | below 0.01μSv/h | - | NNE | 0.5 | | | | | | |
| | 5:10 | West Gate | 279.3 μSv/h | below 0.01μSv/h | - | NNW | 0.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommu- nication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 5:20 | West Gate | 279.0 μSv/h | below 0.01μSv/h | - | N | 0.6 | | | | | | |
| | 5:30 | West Gate | 278.9 μSv/h | below 0.01μSv/h | - | NW | 0.7 | | | | | | |
| | 5:40 | West Gate | 278.9 μSv/h | below 0.01μSv/h | - | NW | 1.0 | | | | | | |
| | 5:50 | West Gate | 277.1 μSv/h | below 0.01μSv/h | - | N | 1.0 | | | | | | |
| | 6:00 | West Gate | 274.0 μSv/h | below 0.01μSv/h | - | NE | 1.3 | | | | | | |
| | 6:10 | West Gate | 274.0 μSv/h | below 0.01μSv/h | Fine | W | 1.6 | | | | | | |
| | 6:20 | West Gate | 273.8 μSv/h | below 0.01μSv/h | Fine | N | 1.4 | | | | | | |
| | 6:30 | West Gate | 274.1 μSv/h | below 0.01μSv/h | Fine | W | 1.2 | | | | | | |
| | 6:40 | West Gate | 272.7 μSv/h | below 0.01μSv/h | Fine | NW | 1.5 | | | | | | |
| | 6:50 | West Gate | 273.4 μSv/h | below 0.01μSv/h | Fine | W | 1.6 | | | | | | |
| | 7:00 | West Gate | 272.4 μSv/h | below 0.01μSv/h | Fine | W | 2.3 | | | | | | |
| | 7:10 | West Gate | 271.7 μSv/h | below 0.01μSv/h | Fine | N | 2.1 | | | | | | |
| | 7:20 | West Gate | 271.6 μSv/h | below 0.01μSv/h | Fine | N | 1.9 | | | | | | |
| | 7:30 | West Gate | 271.4 μSv/h | below 0.01μSv/h | Fine | W | 2.0 | | | | | | |
| | 7:40 | West Gate | 271.1 μSv/h | below 0.01μSv/h | Fine | NW | 2.9 | | | | | | |
| | 7:50 | West Gate | 271.2 μSv/h | below 0.01μSv/h | Fine | N | 3.0 | | | | | | |
| | 8:00 | West Gate | 270.5 μSv/h | below 0.01μSv/h | Fine | NW | 2.7 | | | | | | |
| | 8:10 | West Gate | 270.3 μSv/h | below 0.01μSv/h | Fine | NW | 2.9 | | | | | | |
| | 8:20 | West Gate | 269.9 μSv/h | below 0.01μSv/h | Fine | W | 3.4 | | | | | | |
| | 8:30 | West Gate | 269.9 μSv/h | below 0.01μSv/h | Fine | W | 3.7 | | | | | | |
| | 8:40 | West Gate | 269.8 μSv/h | below 0.01μSv/h | Fine | W | 3.3 | | | | | | |
| | 8:50 | West Gate | 269.2 μSv/h | below 0.01μSv/h | Fine | NW | 2.5 | | | | | | |
| | 9:00 | West Gate | 268.7 μSv/h | below 0.01μSv/h | Fine | WNW | 2.6 | | | | | | |
| | 9:10 | West Gate | 267.6 μSv/h | below 0.01μSv/h | Fine | WNW | 2.8 | | | | | | |
| | 9:20 | West Gate | 268.9 μSv/h | below 0.01μSv/h | Fine | W | 2.3 | | | | | | |
| | 9:30 | West Gate | 267.5 μSv/h | below 0.01μSv/h | Fine | W | 3.3 | | | | | | |
| | 9:40 | West Gate | 267.0 μSv/h | below 0.01μSv/h | Fine | W | 2.9 | | | | | | |
| | 9:50 | West Gate | 266.9 μSv/h | below 0.01μSv/h | Fine | WNW | 3.1 | | | | | | |
| | 10:00 | West Gate | 266.7 μSv/h | below 0.01μSv/h | Fine | NNW | 2.0 | | | | | | |
| | 10:10 | West Gate | 266.4 μSv/h | below 0.01μSv/h | Fine | W | 1.8 | | | | | | |
| | 10:20 | West Gate | 266.1 μSv/h | below 0.01μSv/h | Fine | NW | 2.2 | | | | | | |
| | 10:30 | West Gate | 265.7 μSv/h | below 0.01μSv/h | Fine | NW | 2.5 | | | | | | |
| | 10:40 | West Gate | 265.4 μSv/h | below 0.01μSv/h | Fine | N | 2.3 | | | | | | |
| | 10:50 | West Gate | 264.8 μSv/h | below 0.01μSv/h | Fine | SW | 1.8 | | | | | | |
| | 11:00 | West Gate | 265.0 μSv/h | below 0.01μSv/h | Fine | W | 1.9 | | | | | | |
| | 11:10 | West Gate | 264.4 μSv/h | below 0.01μSv/h | Fine | N | 1.5 | | | | | | |
| | 11:20 | West Gate | 264.5 μSv/h | below 0.01μSv/h | Fine | NW | 1.3 | | | | | | |
| | 11:30 | West Gate | 264.1 μSv/h | below 0.01μSv/h | Fine | SW | 1.5 | | | | | | |
| | 11:40 | West Gate | 264.4 μSv/h | below 0.01μSv/h | Fine | SW | 1.7 | | | | | | |
| | 11:50 | West Gate | 263.4 μSv/h | below 0.01μSv/h | Fine | WNW | 1.6 | | | | | | |
| | 0:00 | West Gate | 263.5 μSv/h | below 0.01μSv/h | Fine | N | 1.7 | | | | | | |
| | 0:10 | West Gate | 263.1 μSv/h | below 0.01μSv/h | Fine | W | 1.3 | | | | | | |
| | 0:20 | West Gate | 262.9 μSv/h | below 0.01μSv/h | Fine | SE | 1.2 | | | | | | |
| | 0:30 | West Gate | 263.3 μSv/h | below 0.01μSv/h | Fine | E | 1.1 | | | | | | |
| | 0:40 | West Gate | 264.3 μSv/h | below 0.01μSv/h | Fine | S | 1.8 | | | | | | |
| | 0:50 | West Gate | 261.3 μSv/h | below 0.01μSv/h | Fine | SE | 2.7 | | | | | | |
| | 13:00 | West Gate | 262.0 μSv/h | below 0.01μSv/h | Fine | S | 3.0 | | | | | | |
| | 13:10 | West Gate | 261.9 μSv/h | below 0.01μSv/h | Fine | ESE | 2.6 | | | | | | |
| | 13:20 | West Gate | 262.7 μSv/h | below 0.01μSv/h | Fine | SE | 2.5 | | | | | | |
| | 13:30 | West Gate | 264.1 μSv/h | below 0.01μSv/h | Fine | E | 2.0 | | | | | | |
| | 13:50 | Main Build North | 3484.0 μSv/h | below 0.01μSv/h | Fine | ESE | 1.8 | | | | | | |
| | 14:00 | Main Build North | 3414.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.0 | | | | | | |
| | 14:10 | Main Build North | 3382.0 μSv/h | below 0.01μSv/h | Fine | SE | 1.7 | | | | | | |
| | 14:15 | Main Build North | 3371.0 μSv/h | below 0.01μSv/h | Fine | ESE | 1.6 | | | | | | |
| | 14:20 | Main Build North | 3362.0 μSv/h | below 0.01μSv/h | Fine | S | 1.7 | | | | | | |
| | 14:25 | Main Build North | 3357.0 μSv/h | below 0.01μSv/h | Fine | ESE | 1.9 | | | | | | |
| | 14:30 | Main Build North | 3352.0 μSv/h | below 0.01μSv/h | Fine | SE | 1.9 | | | | | | |
| | 14:35 | Main Build North | 3342.0 μSv/h | below 0.01μSv/h | Fine | SSE | 1.7 | | | | | | |
| | 14:40 | Main Build North | 3348.0 μSv/h | below 0.01μSv/h | Fine | SSE | 1.8 | | | | | | |
| | 14:45 | Main Build North | 3357.0 μSv/h | below 0.01μSv/h | Fine | SSE | 1.6 | | | | | | |
| | 14:50 | Main Build North | 3339.0 μSv/h | below 0.01μSv/h | Fine | ESE | 1.5 | | | | | | |
| | 14:55 | Main Build North | 3346.0 μSv/h | below 0.01μSv/h | Fine | S | 1.5 | | | | | | |
| | 15:00 | Main Build North | 3345.0 μSv/h | below 0.01μSv/h | Fine | SE | 1.4 | | | | | | |
| | 15:10 | Main Build North | 3368.0 μSv/h | below 0.01μSv/h | Fine | S | 1.7 | | | | | | |
| | 15:20 | Main Build North | 3582.0 μSv/h | below 0.01μSv/h | Fine | SSE | 1.9 | | | | | | |
| | 15:30 | Main Build North | 4075.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.3 | | | | | | |
| | 15:40 | Main Build North | 3823.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.1 | | | | | | |
| | 15:50 | Main Build North | 4396.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.2 | | | | | | |
| | 16:00 | Main Build North | 4485.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.4 | | | | | | |
| | 16:10 | Main Build North | 4352.0 μSv/h | below 0.01μSv/h | Fine | ESE | 2.0 | | | | | | |
| | 16:20 | Main Build North | 4535.0 μSv/h | below 0.01μSv/h | Fine | S | 2.1 | | | | | | |
| | 16:30 | Main Build North | 4419.0 μSv/h | below 0.01μSv/h | Fine | SSE | 1.8 | | | | | | |
| | 16:40 | Main Build North | 4277.0 μSv/h | below 0.01μSv/h | Fine | E | 2.1 | | | | | | |
| | 16:50 | Main Build North | 4735.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.1 | | | | | | |
| | 17:00 | Main Build North | 5055.0 μSv/h | below 0.01μSv/h | Fine | S | 2.0 | | | | | | |
| | 17:10 | Main Build North | 5033.0 μSv/h | below 0.01μSv/h | Fine | SSE | 2.1 | | | | | | |
| | 17:20 | Main Build North | 4952.0 μSv/h | below 0.01μSv/h | Fine | SSE | 3.1 | | | | | | |
| | 17:30 | Main Build North | 4251.0 μSv/h | below 0.01μSv/h | Fine | S | 2.3 | | | | | | |
| | 17:40 | Main Build North | 4182.0 μSv/h | below 0.01μSv/h | Fine | S | 1.8 | | | | | | |
| | 17:50 | Main Build North | 4090.0 μSv/h | below 0.01μSv/h | Fine | SSW | 1.8 | | | | | | |
| | 18:00 | Main Build North | 4084.0 μSv/h | below 0.01μSv/h | Fine | SSW | 1.2 | | | | | | |
| | 18:10 | Main Build North | 4069.0 μSv/h | below 0.01μSv/h | Fine | S | 1.2 | | | | | | |
| | 18:20 | Main Build North | 4069.0 μSv/h | below 0.01μSv/h | Fine | S | 1.2 | | | | | | |
| | 18:30 | Main Build North | 3922.0 μSv/h | below 0.01μSv/h | Fine | SSW | 1.5 | | | | | | |
| | 18:40 | Main Build North | 3885.0 μSv/h | below 0.01μSv/h | Fine | SSW | 1.5 | | | | | | |
| | 18:50 | Main Build North | 3832.0 μSv/h | below 0.01μSv/h | Fine | SSW | 1.4 | | | | | | |
| | 19:00 | Main Build North | 3788.0 μSv/h | below 0.01μSv/h | Fine | W | 1.5 | | | | | | |
| | 19:10 | Main Build North | 3745.0 μSv/h | below 0.01μSv/h | - | SW | 1.3 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|---------------------|-------|------------------|--------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 19:20 | Main Build North | 3728.0 μSv/h | below 0.01μSv/h | - | SW | 1.4 | | | | | | |
| | 19:30 | Main Build North | 3699.0 μSv/h | below 0.01μSv/h | - | SSW | 1.4 | | | | | | |
| | 19:40 | Main Build North | 3669.0 μSv/h | below 0.01μSv/h | - | S | 1.3 | | | | | | |
| | 19:50 | Main Build North | 3634.0 μSv/h | below 0.01μSv/h | - | WSW | 1.5 | | | | | | |
| | 20:00 | Main Build North | 3611.0 μSv/h | below 0.01μSv/h | - | WSW | 1.3 | | | | | | |
| | 20:10 | West Gate | 447.6 μSv/h | below 0.01μSv/h | - | S | 3.0 | | | | | | |
| | 20:20 | West Gate | 441.2 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 20:30 | West Gate | 434.5 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 20:40 | West Gate | 429.2 μSv/h | below 0.01μSv/h | - | SW | 0.8 | | | | | | |
| | 20:50 | West Gate | 423.9 μSv/h | below 0.01μSv/h | - | WSW | 0.6 | | | | | | |
| | 21:00 | West Gate | 419.1 μSv/h | below 0.01μSv/h | - | SSW | 0.5 | | | | | | |
| | 21:10 | West Gate | 414.2 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 21:20 | West Gate | 409.4 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 21:30 | West Gate | 405.2 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 21:40 | West Gate | 401.6 μSv/h | below 0.01μSv/h | - | NNW | 0.4 | | | | | | |
| | 21:50 | West Gate | 397.8 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 22:00 | West Gate | 393.9 μSv/h | below 0.01μSv/h | - | SW | 0.5 | | | | | | |
| | 22:10 | West Gate | 389.2 μSv/h | below 0.01μSv/h | - | SW | 0.7 | | | | | | |
| | 22:20 | West Gate | 385.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 22:30 | West Gate | 382.9 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 22:40 | West Gate | 379.6 μSv/h | below 0.01μSv/h | - | SW | 0.4 | | | | | | |
| | 22:50 | West Gate | 375.9 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 23:00 | West Gate | 373.6 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | |
| | 23:10 | West Gate | 371.2 μSv/h | below 0.01μSv/h | - | NW | 0.4 | | | | | | |
| | 23:20 | West Gate | 368.9 μSv/h | below 0.01μSv/h | - | WSW | 0.3 | | | | | | |
| | 23:30 | Main Build North | 3254.0 μSv/h | below 0.01μSv/h | - | WSW | 2.8 | | | | | | |
| | 23:40 | Main Build North | 3256.0 μSv/h | below 0.01μSv/h | - | SW | 1.2 | | | | | | |
| | 23:50 | Main Build North | 3244.0 μSv/h | below 0.01μSv/h | - | WSW | 1.2 | | | | | | |
| 3/19 | 0:00 | Main Build North | 3229.0 μSv/h | below 0.01μSv/h | - | WSW | 1.4 | | | | | | |
| | 0:10 | Main Build North | 3224.0 μSv/h | below 0.01μSv/h | - | WSW | 1.4 | | | | | | |
| | 0:20 | Main Build North | 3219.0 μSv/h | below 0.01μSv/h | - | SW | 1.2 | | | | | | |
| | 0:30 | Main Build North | 3231.0 μSv/h | below 0.01μSv/h | - | SW | 1.1 | | | | | | |
| | 0:40 | Main Build North | 3342.0 μSv/h | below 0.01μSv/h | - | WSW | 0.9 | | | | | | |
| | 0:50 | Main Build North | 3284.0 μSv/h | below 0.01μSv/h | - | W | 1.4 | | | | | | |
| | 1:00 | Main Build North | 3248.0 μSv/h | below 0.01μSv/h | - | WSW | 1.3 | | | | | | |
| | 1:10 | Main Build North | 3279.0 μSv/h | below 0.01μSv/h | - | WSW | 1.3 | | | | | | |
| | 1:20 | Main Build North | 3247.0 μSv/h | below 0.01μSv/h | - | WSW | 1.3 | | | | | | |
| | 1:30 | Main Build North | 3195.0 μSv/h | below 0.01μSv/h | - | WSW | 1.4 | | | | | | |
| | 1:40 | Main Build North | 3188.0 μSv/h | below 0.01μSv/h | - | SW | 1.6 | | | | | | |
| | 1:50 | Main Build North | 3181.0 μSv/h | below 0.01μSv/h | - | WSW | 1.3 | | | | | | |
| | 2:00 | West Gate | 313.7 μSv/h | below 0.01μSv/h | - | N | 3.0 | | | | | | |
| | 2:10 | West Gate | 312.2 μSv/h | below 0.01μSv/h | - | N | 0.3 | | | | | | |
| | 2:20 | West Gate | 311.1 μSv/h | below 0.01μSv/h | - | S | 0.3 | | | | | | |
| | 2:30 | West Gate | 310.0 μSv/h | below 0.01μSv/h | - | WSW | 0.6 | | | | | | |
| | 2:40 | West Gate | 309.1 μSv/h | below 0.01μSv/h | - | WSW | 0.3 | | | | | | |
| | 2:50 | West Gate | 308.6 μSv/h | below 0.01μSv/h | - | NNE | 0.4 | | | | | | |
| | 3:00 | West Gate | 306.9 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 3:10 | West Gate | 306.0 μSv/h | below 0.01μSv/h | - | SW | 0.7 | | | | | | |
| | 3:20 | West Gate | 305.1 μSv/h | below 0.01μSv/h | - | SSE | 0.7 | | | | | | |
| | 3:30 | West Gate | 304.3 μSv/h | below 0.01μSv/h | - | E | 0.7 | | | | | | |
| | 3:40 | West Gate | 303.6 μSv/h | below 0.01μSv/h | - | SSE | 0.9 | | | | | | |
| | 3:50 | West Gate | 303.1 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 4:00 | West Gate | 301.7 μSv/h | below 0.01μSv/h | - | E | 0.6 | | | | | | |
| | 4:10 | West Gate | 301.3 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 4:20 | West Gate | 300.5 μSv/h | below 0.01μSv/h | - | WNW | 0.4 | | | | | | |
| | 4:30 | West Gate | 299.2 μSv/h | below 0.01μSv/h | - | SE | 0.6 | | | | | | |
| | 4:40 | West Gate | 299.2 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 4:50 | West Gate | 298.5 μSv/h | below 0.01μSv/h | - | S | 0.4 | | | | | | |
| | 5:00 | West Gate | 297.5 μSv/h | below 0.01μSv/h | - | S | 0.5 | | | | | | |
| | 5:10 | West Gate | 296.4 μSv/h | below 0.01μSv/h | - | S | 0.5 | | | | | | |
| | 5:20 | West Gate | 295.8 μSv/h | below 0.01μSv/h | - | E | 0.9 | | | | | | |
| | 5:30 | West Gate | 295.1 μSv/h | below 0.01μSv/h | - | NW | 0.9 | | | | | | |
| | 5:40 | West Gate | 295.4 μSv/h | below 0.01μSv/h | - | E | 0.9 | | | | | | |
| | 5:50 | West Gate | 294.3 μSv/h | below 0.01μSv/h | - | SE | 0.6 | | | | | | |
| | 6:00 | West Gate | 293.8 μSv/h | below 0.01μSv/h | - | W | 0.9 | | | | | | |
| | 6:10 | West Gate | 293.6 μSv/h | below 0.01μSv/h | - | SE | 0.7 | | | | | | |
| | 6:20 | West Gate | 292.6 μSv/h | below 0.01μSv/h | - | ENE | 0.5 | | | | | | |
| | 6:30 | West Gate | 292.3 μSv/h | below 0.01μSv/h | - | ESE | 0.4 | | | | | | |
| | 6:40 | West Gate | 291.5 μSv/h | below 0.01μSv/h | - | SSE | 0.3 | | | | | | |
| | 6:50 | West Gate | 290.9 μSv/h | below 0.01μSv/h | - | E | 0.4 | | | | | | |
| | 7:00 | West Gate | 290.6 μSv/h | below 0.01μSv/h | Fine | NW | 0.7 | | | | | | |
| | 7:10 | West Gate | 289.8 μSv/h | below 0.01μSv/h | Fine | W | 0.3 | | | | | | |
| | 7:20 | West Gate | 289.1 μSv/h | below 0.01μSv/h | Fine | W | 0.7 | | | | | | |
| | 7:30 | West Gate | 288.9 μSv/h | below 0.01μSv/h | Fine | WSW | 0.8 | | | | | | |
| | 7:40 | West Gate | 288.6 μSv/h | below 0.01μSv/h | Fine | SW | 0.6 | | | | | | |
| | 7:50 | West Gate | 287.2 μSv/h | below 0.01μSv/h | Fine | SE | 0.6 | | | | | | |
| | 8:00 | West Gate | 399.0 μSv/h | below 0.01μSv/h | Fine | NNE | 0.3 | | | | | | |
| article15-103notice | 8:10 | West Gate | 830.8 μSv/h | below 0.01μSv/h | Fine | WNW | 0.5 | | | | | | |
| | 8:20 | West Gate | 670.6 μSv/h | below 0.01μSv/h | Fine | WSW | 0.3 | | | | | | |
| | 8:30 | West Gate | 431.9 μSv/h | below 0.01μSv/h | Fine | E | 0.4 | | | | | | |
| | 8:40 | West Gate | 390.5 μSv/h | below 0.01μSv/h | Fine | ENE | 0.6 | | | | | | |
| | 8:50 | West Gate | 522.5 μSv/h | below 0.01μSv/h | Fine | ENE | 0.6 | | | | | | |
| | 9:00 | West Gate | 364.5 μSv/h | below 0.01μSv/h | Fine | NE | 0.9 | | | | | | |
| | 9:10 | West Gate | 336.5 μSv/h | below 0.01μSv/h | Fine | E | 1.6 | | | | | | |
| | 9:20 | West Gate | 323.8 μSv/h | below 0.01μSv/h | Fine | E | 2.1 | | | | | | |
| | 9:30 | West Gate | 425.2 μSv/h | below 0.01μSv/h | Fine | E | 2.0 | | | | | | |
| | 9:40 | West Gate | 657.3 μSv/h | below 0.01μSv/h | Fine | E | 1.5 | | | | | | |
| | 9:50 | West Gate | 358.3 μSv/h | below 0.01μSv/h | Fine | SE | 1.8 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscom- munication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | | | | | | | | | | | | | |
| | 10:00 | West Gate | 346.1 μSv/h | below 0.01μSv/h | Fine | SE | 1.8 | | | | | | |
| | 10:10 | West Gate | 341.2 μSv/h | below 0.01μSv/h | Fine | S | 1.9 | | | | | | |
| | 10:20 | West Gate | 338.4 μSv/h | below 0.01μSv/h | Fine | SE | 1.9 | | | | | | |
| | 10:30 | West Gate | 334.3 μSv/h | below 0.01μSv/h | Fine | E | 1.7 | | | | | | |
| | 10:40 | West Gate | 330.2 μSv/h | below 0.01μSv/h | Fine | SSE | 1.5 | | | | | | |
| | 10:50 | West Gate | 327.1 μSv/h | below 0.01μSv/h | Fine | SSE | 1.5 | | | | | | |
| | 11:00 | West Gate | 322.6 μSv/h | below 0.01μSv/h | Fine | SW | 1.6 | | | | | | |
| | 11:10 | West Gate | 319.8 μSv/h | below 0.01μSv/h | Fine | W | 2.2 | | | | | | |
| | 11:20 | West Gate | 315.1 μSv/h | below 0.01μSv/h | Fine | WNW | 2.9 | | | | | | |
| | 11:30 | West Gate | 313.1 μSv/h | below 0.01μSv/h | Fine | SW | 3.4 | | | | | | |
| | 11:40 | Main Build North | 3954.0 μSv/h | below 0.01μSv/h | Fine | WNW | 4.0 | | | | | | |
| | 11:50 | Main Build North | 3901.0 μSv/h | below 0.01μSv/h | Fine | W | 4.7 | | | | | | |
| | 0:00 | Main Build North | 3882.0 μSv/h | below 0.01μSv/h | Fine | W | 6.8 | | | | | | |
| | 0:10 | Main Build North | 3828.0 μSv/h | below 0.01μSv/h | Fine | W | 5.7 | | | | | | |
| | 0:20 | Main Build North | 3802.0 μSv/h | below 0.01μSv/h | Fine | WNW | 5.6 | | | | | | |
| | 0:30 | Main Build North | 3749.0 μSv/h | below 0.01μSv/h | Fine | W | 5.7 | | | | | | |
| | 0:40 | Main Build North | 3704.0 μSv/h | below 0.01μSv/h | Fine | WSW | 5.9 | | | | | | |
| | 0:50 | Main Build North | 3655.0 μSv/h | below 0.01μSv/h | Fine | WSW | 6.1 | | | | | | |
| | 13:00 | Main Build North | 3629.0 μSv/h | below 0.01μSv/h | Fine | NW | 4.2 | | | | | | |
| | 13:10 | Main Build North | 3594.0 μSv/h | below 0.01μSv/h | Fine | W | 3.7 | | | | | | |
| | 13:20 | Main Build North | 3565.0 μSv/h | below 0.01μSv/h | Fine | NW | 5.3 | | | | | | |
| | 13:30 | Main Build North | 3529.0 μSv/h | below 0.01μSv/h | Fine | W | 4.3 | | | | | | |
| | 13:40 | Main Build North | 3491.0 μSv/h | below 0.01μSv/h | Fine | W | 5.1 | | | | | | |
| | 13:50 | Main Build North | 3473.0 μSv/h | below 0.01μSv/h | Fine | SSW | 4.9 | | | | | | |
| | 14:00 | Main Build North | 3443.0 μSv/h | below 0.01μSv/h | Fine | W | 5.8 | | | | | | |
| | 14:10 | Main Build North | 3417.0 μSv/h | below 0.01μSv/h | Fine | NE | 3.4 | | | | | | |
| | 14:20 | Main Build North | 3396.0 μSv/h | below 0.01μSv/h | Fine | W | 4.6 | | | | | | |
| | 14:30 | Main Build North | 3375.0 μSv/h | below 0.01μSv/h | Fine | N | 4.9 | | | | | | |
| | 14:40 | Main Build North | 3348.0 μSv/h | below 0.01μSv/h | Fine | SSW | 3.1 | | | | | | |
| | 14:50 | Main Build North | 3340.0 μSv/h | below 0.01μSv/h | Fine | SE | 2.6 | | | | | | |
| | 15:00 | Main Build North | 3279.0 μSv/h | below 0.01μSv/h | Fine | W | 4.9 | | | | | | |
| | 15:10 | Main Build North | 3281.0 μSv/h | below 0.01μSv/h | Fine | W | 4.6 | | | | | | |
| | 15:20 | Main Build North | 3229.0 μSv/h | below 0.01μSv/h | Fine | W | 3.4 | | | | | | |
| | 15:30 | Main Build North | 3194.0 μSv/h | below 0.01μSv/h | Fine | SW | 3.8 | | | | | | |
| | 15:40 | Main Build North | 3474.0 μSv/h | below 0.01μSv/h | Fine | SW | 4.6 | | | | | | |
| | 15:50 | Main Build North | 3167.0 μSv/h | below 0.01μSv/h | Fine | S | 3.9 | | | | | | |
| | 16:00 | Main Build North | 3165.0 μSv/h | below 0.01μSv/h | Fine | NW | 2.4 | | | | | | |
| | 16:10 | Main Build North | 3137.0 μSv/h | below 0.01μSv/h | Fine | W | 4.8 | | | | | | |
| | 16:20 | Main Build North | 3135.0 μSv/h | below 0.01μSv/h | Fine | W | 5.0 | | | | | | |
| | 16:30 | Main Build North | 3126.0 μSv/h | below 0.01μSv/h | Fine | WSW | 4.5 | | | | | | |
| | 16:40 | Main Build North | 3111.0 μSv/h | below 0.01μSv/h | Fine | WSW | 6.1 | | | | | | |
| | 16:50 | Main Build North | 3089.0 μSv/h | below 0.01μSv/h | Fine | W | 5.1 | | | | | | |
| | 17:00 | Main Build North | 3078.0 μSv/h | below 0.01μSv/h | Fine | W | 5.7 | | | | | | |
| | 17:10 | Main Build North | 3071.0 μSv/h | below 0.01μSv/h | Fine | W | 4.5 | | | | | | |
| | 17:20 | Main Build North | 3058.0 μSv/h | below 0.01μSv/h | Fine | NW | 4.1 | | | | | | |
| | 17:30 | Main Build North | 3051.0 μSv/h | below 0.01μSv/h | Fine | W | 3.3 | | | | | | |
| | 17:40 | Main Build North | 3033.0 μSv/h | below 0.01μSv/h | Fine | W | 3.8 | | | | | | |
| | 17:50 | Main Build North | 3024.0 μSv/h | below 0.01μSv/h | Fine | W | 3.5 | | | | | | |
| | 18:00 | Main Build North | 3020.0 μSv/h | below 0.01μSv/h | Fine | W | 3.6 | | | | | | |
| | 18:10 | Main Build North | 3007.0 μSv/h | below 0.01μSv/h | Fine | W | 2.7 | | | | | | |
| | 18:20 | Main Build North | 3002.0 μSv/h | below 0.01μSv/h | Fine | W | 2.8 | | | | | | |
| | 18:30 | Main Build North | 2998.0 μSv/h | below 0.01μSv/h | Fine | W | 4.1 | | | | | | |
| | 18:40 | Main Build North | 2992.0 μSv/h | below 0.01μSv/h | Fine | W | 3.5 | | | | | | |
| | 18:50 | Main Build North | 2978.0 μSv/h | below 0.01μSv/h | Fine | W | 4.4 | | | | | | |
| | 19:00 | Main Build North | 2972.0 μSv/h | below 0.01μSv/h | Fine | WSW | 4.1 | | | | | | |
| | 19:10 | Main Build North | 2965.0 μSv/h | below 0.01μSv/h | - | WSW | 3.2 | | | | | | |
| | 19:20 | Main Build North | 2961.0 μSv/h | below 0.01μSv/h | - | WSW | 2.7 | | | | | | |
| | 19:30 | Main Build North | 2957.0 μSv/h | below 0.01μSv/h | - | W | 2.8 | | | | | | |
| | 19:40 | Main Build North | 2946.0 μSv/h | below 0.01μSv/h | - | W | 2.7 | | | | | | |
| | 19:50 | Main Build North | 2941.0 μSv/h | below 0.01μSv/h | - | W | 2.2 | | | | | | |
| | 20:00 | Main Build North | 2937.0 μSv/h | below 0.01μSv/h | - | W | 2.6 | | | | | | |
| | 20:10 | Main Build North | 2931.0 μSv/h | below 0.01μSv/h | - | W | 3.1 | | | | | | |
| | 20:20 | Main Build North | 2924.0 μSv/h | below 0.01μSv/h | - | W | 2.6 | | | | | | |
| | 20:30 | Main Build North | 2917.0 μSv/h | below 0.01μSv/h | - | W | 2.5 | | | | | | |
| | 20:40 | Main Build North | 2912.0 μSv/h | below 0.01μSv/h | - | W | 2.6 | | | | | | |
| | 20:50 | Main Build North | 2909.0 μSv/h | below 0.01μSv/h | - | W | 3.1 | | | | | | |
| | 21:00 | Main Build North | 2906.0 μSv/h | below 0.01μSv/h | - | W | 3.4 | | | | | | |
| | 21:10 | Main Build North | 2900.0 μSv/h | below 0.01μSv/h | - | W | 3.3 | | | | | | |
| | 21:20 | Main Build North | 2895.0 μSv/h | below 0.01μSv/h | - | W | 2.3 | | | | | | |
| | 21:30 | Main Build North | 2891.0 μSv/h | below 0.01μSv/h | - | W | 1.8 | | | | | | |
| | 21:40 | Main Build North | 2883.0 μSv/h | below 0.01μSv/h | - | W | 2.0 | | | | | | |
| | 21:50 | Main Build North | 2880.0 μSv/h | below 0.01μSv/h | - | WNW | 2.2 | | | | | | |
| | 22:00 | Main Build North | 2880.0 μSv/h | below 0.01μSv/h | - | ENE | 1.2 | | | | | | |
| | 22:10 | Main Build North | 2876.0 μSv/h | below 0.01μSv/h | - | WSW | 0.8 | | | | | | |
| | 22:20 | Main Build North | 2855.0 μSv/h | below 0.01μSv/h | - | W | 1.0 | | | | | | |
| | 22:30 | Main Build North | 2854.0 μSv/h | below 0.01μSv/h | - | W | 2.0 | | | | | | |
| | 22:40 | Main Build North | 2847.0 μSv/h | below 0.01μSv/h | - | WNW | 1.4 | | | | | | |
| | 22:50 | Main Build North | 2844.0 μSv/h | below 0.01μSv/h | - | W | 1.8 | | | | | | |
| | 23:00 | Main Build North | 2841.0 μSv/h | below 0.01μSv/h | - | W | 2.5 | | | | | | |
| | 22:40 | Main Build North | 2847.0 μSv/h | below 0.01μSv/h | - | WNW | 1.4 | | | | | | |
| | 22:50 | Main Build North | 2844.0 μSv/h | below 0.01μSv/h | - | W | 1.8 | | | | | | |
| | 23:00 | Main Build North | 2841.0 μSv/h | below 0.01μSv/h | - | W | 2.5 | | | | | | |
| | 23:10 | Main Build North | 2836.0 μSv/h | below 0.01μSv/h | - | WNW | 2.4 | | | | | | |
| | 23:20 | Main Build North | 2828.0 μSv/h | below 0.01μSv/h | - | W | 2.4 | | | | | | |
| | 23:30 | Main Build North | 2828.0 μSv/h | below 0.01μSv/h | - | WNW | 2.9 | | | | | | |
| | 23:40 | Main Build North | 2826.0 μSv/h | below 0.01μSv/h | - | WNW | 2.5 | | | | | | |
| | 23:50 | Main Build North | 2823.0 μSv/h | below 0.01μSv/h | - | W | 2.8 | | | | | | |
| 3/20 | 0:00 | Main Build North | 2821.0 μSv/h | below 0.01μSv/h | - | SW | 4.5 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change
 ■ : significant figure change
 ■ : reflection amend
■ : new additional data
 ■ : change unit
 press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscom- munication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 0:10 | Main Build North | 2814.0 μSv/h | below 0.01μSv/h | - | SW | 3.7 | | | | | | |
| | 0:20 | Main Build North | 2808.0 μSv/h | below 0.01μSv/h | - | W | 2.8 | | | | | | |
| | 0:30 | Main Build North | 2805.0 μSv/h | below 0.01μSv/h | - | SW | 3.5 | | | | | | |
| | 0:40 | Main Build North | 2803.0 μSv/h | below 0.01μSv/h | - | WSW | 3.0 | | | | | | |
| | 0:50 | Main Build North | 2791.0 μSv/h | below 0.01μSv/h | - | WSW | 3.4 | | | | | | |
| | 1:00 | Main Build North | 2797.0 μSv/h | below 0.01μSv/h | - | NW | 4.6 | | | | | | |
| | 1:10 | Main Build North | 2794.0 μSv/h | below 0.01μSv/h | - | NW | 3.2 | | | | | | |
| | 1:20 | Main Build North | 2793.0 μSv/h | below 0.01μSv/h | - | W | 3.0 | | | | | | |
| | 1:30 | Main Build North | 2788.0 μSv/h | below 0.01μSv/h | - | NE | 2.9 | | | | | | |
| | 1:40 | Main Build North | 2785.0 μSv/h | below 0.01μSv/h | - | SW | 2.1 | | | | | | |
| | 1:50 | Main Build North | 2781.0 μSv/h | below 0.01μSv/h | - | W | 2.5 | | | | | | |
| | 2:00 | Main Build North | 2778.0 μSv/h | below 0.01μSv/h | - | SW | 1.8 | | | | | | |
| | 2:10 | Main Build North | 2773.0 μSv/h | below 0.01μSv/h | - | WNW | 2.1 | | | | | | |
| | 2:20 | Main Build North | 2771.0 μSv/h | below 0.01μSv/h | - | W | 1.6 | | | | | | |
| | 2:30 | Main Build North | 2767.0 μSv/h | below 0.01μSv/h | - | W | 1.8 | | | | | | |
| | 2:40 | Main Build North | 2764.0 μSv/h | below 0.01μSv/h | - | NW | 1.5 | | | | | | |
| | 2:50 | Main Build North | 2761.0 μSv/h | below 0.01μSv/h | - | NW | 2.3 | | | | | | |
| | 3:00 | Main Build North | 2759.0 μSv/h | below 0.01μSv/h | - | WNW | 2.1 | | | | | | |
| | 3:10 | Main Build North | 2745.0 μSv/h | below 0.01μSv/h | - | WSW | 1.0 | | | | | | |
| | 3:20 | Main Build North | 2745.0 μSv/h | below 0.01μSv/h | - | NE | 1.1 | | | | | | |
| | 3:30 | Main Build North | 2741.0 μSv/h | below 0.01μSv/h | - | NNE | 1.0 | | | | | | |
| | 3:40 | Main Build North | 2758.0 μSv/h | below 0.01μSv/h | - | W | 1.1 | | | | | | |
| | 3:50 | Main Build North | 3185.0 μSv/h | below 0.01μSv/h | - | S | 1.0 | | | | | | |
| | 4:00 | Main Build North | 2939.0 μSv/h | below 0.01μSv/h | - | W | 0.9 | | | | | | |
| | 4:10 | Main Build North | 2771.0 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | | | | | |
| | 4:20 | Main Build North | 2743.0 μSv/h | below 0.01μSv/h | - | S | 0.8 | | | | | | |
| | 4:30 | Main Build North | 2739.0 μSv/h | below 0.01μSv/h | - | SW | 0.8 | | | | | | |
| | 4:40 | West Gate | 273.2 μSv/h | below 0.01μSv/h | - | NNW | 3.5 | | | | | | |
| | 4:50 | West Gate | 271.8 μSv/h | below 0.01μSv/h | - | N | 1.6 | | | | | | |
| | 5:00 | West Gate | 271.2 μSv/h | below 0.01μSv/h | - | NNW | 1.5 | | | | | | |
| | 5:10 | West Gate | 270.9 μSv/h | below 0.01μSv/h | - | WNW | 1.5 | | | | | | |
| | 5:20 | West Gate | 270.4 μSv/h | below 0.01μSv/h | - | N | 0.7 | | | | | | |
| | 5:30 | West Gate | 269.8 μSv/h | below 0.01μSv/h | - | NNE | 0.6 | | | | | | |
| | 5:40 | West Gate | 269.5 μSv/h | below 0.01μSv/h | - | NE | 0.6 | | | | | | |
| | 5:50 | Main Build North | 2683.0 μSv/h | below 0.01μSv/h | - | N | 2.2 | | | | | | |
| | 6:00 | Main Build North | 2679.0 μSv/h | below 0.01μSv/h | Claudy | NE | 0.6 | | | | | | |
| | 6:10 | Main Build North | 2679.0 μSv/h | below 0.01μSv/h | Claudy | NE | 0.7 | | | | | | |
| | 6:20 | Main Build North | 2677.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 0.9 | | | | | | |
| | 6:30 | Main Build North | 2670.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 0.8 | | | | | | |
| | 6:40 | Main Build North | 2654.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 0.6 | | | | | | |
| | 6:50 | Main Build North | 2664.0 μSv/h | below 0.01μSv/h | Claudy | E | 0.9 | | | | | | |
| | 7:00 | Main Build North | 2661.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.1 | | | | | | |
| | 7:10 | Main Build North | 2661.0 μSv/h | below 0.01μSv/h | Claudy | ESE | 0.6 | | | | | | |
| | 7:20 | Main Build North | 2659.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 0.6 | | | | | | |
| | 7:30 | Main Build North | 2652.0 μSv/h | below 0.01μSv/h | Claudy | NE | 0.6 | | | | | | |
| | 7:40 | Main Build North | 2653.0 μSv/h | below 0.01μSv/h | Claudy | NE | 0.8 | | | | | | |
| | 7:50 | Main Build North | 2637.0 μSv/h | below 0.01μSv/h | Claudy | N | 0.9 | | | | | | |
| | 8:00 | Main Build North | 2630.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.3 | | | | | | |
| | 8:10 | Main Build North | 2629.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.3 | | | | | | |
| | 8:20 | Main Build North | 2627.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.5 | | | | | | |
| | 8:30 | Main Build North | 2625.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.3 | | | | | | |
| | 8:40 | Main Build North | 2619.0 μSv/h | below 0.01μSv/h | Claudy | NNE | 1.5 | | | | | | |
| | 8:50 | Main Build North | 2617.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.4 | | | | | | |
| | 9:00 | Main Build North | 2614.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.2 | | | | | | |
| | 9:10 | Main Build North | 2614.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.2 | | | | | | |
| | 9:20 | Main Build North | 2608.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.0 | | | | | | |
| | 9:30 | Main Build North | 2623.0 μSv/h | below 0.01μSv/h | Claudy | ESE | 1.0 | | | | | | |
| | 9:40 | Main Build North | 2661.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 1.5 | | | | | | |
| | 9:50 | Main Build North | 2742.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.2 | | | | | | |
| | 10:00 | Main Build North | 2726.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 1.2 | | | | | | |
| | 10:10 | Main Build North | 2608.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.1 | | | | | | |
| | 10:20 | Main Build North | 2605.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.2 | | | | | | |
| | 10:30 | Main Build North | 2596.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.3 | | | | | | |
| | 10:40 | Main Build North | 2589.0 μSv/h | below 0.01μSv/h | Claudy | E | 0.7 | | | | | | |
| | 10:50 | Main Build North | 2583.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.3 | | | | | | |
| | 11:00 | Main Build North | 2579.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.4 | | | | | | |
| | 11:10 | Main Build North | 2578.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.8 | | | | | | |
| | 11:20 | Main Build North | 2569.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.5 | | | | | | |
| | 11:30 | Main Build North | 2571.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 1.4 | | | | | | |
| | 11:40 | Main Build North | 2562.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.2 | | | | | | |
| | 11:50 | Main Build North | 2564.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.3 | | | | | | |
| | 0:00 | Main Build North | 2559.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.3 | | | | | | |
| | 0:10 | Main Build North | 2558.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.1 | | | | | | |
| | 0:20 | Main Build North | 2552.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.2 | | | | | | |
| | 0:30 | Main Build North | 2551.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.0 | | | | | | |
| | 0:40 | Main Build North | 2551.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.1 | | | | | | |
| | 0:50 | Main Build North | 2550.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.3 | | | | | | |
| | 13:00 | Main Build North | 2567.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.5 | | | | | | |
| | 13:10 | Main Build North | 2588.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.4 | | | | | | |
| | 13:20 | Main Build North | 2660.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.6 | | | | | | |
| | 13:30 | Main Build North | 2593.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.7 | | | | | | |
| | 13:40 | Main Build North | 2654.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.8 | | | | | | |
| | 13:50 | Main Build North | 2741.0 μSv/h | below 0.01μSv/h | Claudy | SE | 2.0 | | | | | | |
| | 14:00 | Main Build North | 2768.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.6 | | | | | | |
| | 14:10 | Main Build North | 2999.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.7 | | | | | | |
| | 14:20 | Main Build North | 2923.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.8 | | | | | | |
| | 14:30 | Main Build North | 3056.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.9 | | | | | | |
| | 14:40 | Main Build North | 3202.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 2.3 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change
 ■ : significant figure change
 ■ : reflection amend
■ : new additional data
 ■ : change unit
 : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscom- munication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 14:50 | Main Build North | 3346.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.1 | | | | | | |
| | 15:00 | Main Build North | 3054.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 2.0 | | | | | | |
| | 15:10 | Main Build North | 3071.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.9 | | | | | | |
| | 15:20 | Main Build North | 3342.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.9 | | | | | | |
| | 15:30 | Main Build North | 3337.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.7 | | | | | | |
| | 15:40 | Main Build North | 3003.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.9 | | | | | | |
| | 15:50 | Main Build North | 3046.0 μSv/h | below 0.01μSv/h | Claudy | SSE | 2.1 | | | | | | |
| | 16:00 | Main Build North | 3171.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.8 | | | | | | |
| | 16:10 | Main Build North | 2940.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.0 | | | | | | |
| | 16:20 | Main Build North | 2851.0 μSv/h | below 0.01μSv/h | Claudy | S | 1.9 | | | | | | |
| | 16:30 | Main Build North | 2830.0 μSv/h | below 0.01μSv/h | Claudy | SSW | 2.2 | | | | | | |
| | 16:40 | Main Build North | 2960.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.0 | | | | | | |
| | 16:50 | Main Build North | 2839.0 μSv/h | below 0.01μSv/h | Claudy | SSW | 2.1 | | | | | | |
| | 17:00 | Main Build North | 2773.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.1 | | | | | | |
| | 17:10 | Main Build North | 2763.0 μSv/h | below 0.01μSv/h | Claudy | SW | 1.8 | | | | | | |
| | 17:20 | Main Build North | 2758.0 μSv/h | below 0.01μSv/h | Claudy | SSW | 2.0 | | | | | | |
| | 17:30 | Main Build North | 2729.0 μSv/h | below 0.01μSv/h | Claudy | SE | 1.7 | | | | | | |
| | 17:40 | Main Build North | 2715.0 μSv/h | below 0.01μSv/h | Claudy | SSW | 2.1 | | | | | | |
| | 17:50 | Main Build North | 2707.0 μSv/h | below 0.01μSv/h | Claudy | SW | 1.7 | | | | | | |
| | 18:00 | Main Build North | 2693.0 μSv/h | below 0.01μSv/h | Claudy | SSW | 1.6 | | | | | | |
| | 18:10 | Main Build North | 2680.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.6 | | | | | | |
| | 18:20 | Main Build North | 2673.0 μSv/h | below 0.01μSv/h | Claudy | S | 2.6 | | | | | | |
| | 18:30 | Main Build North | 2658.0 μSv/h | below 0.01μSv/h | Claudy | SW | 2.4 | | | | | | |
| | 18:40 | Main Build North | 2651.0 μSv/h | below 0.01μSv/h | Claudy | WSW | 1.8 | | | | | | |
| | 18:50 | Main Build North | 2658.0 μSv/h | below 0.01μSv/h | Claudy | NNE | 1.0 | | | | | | |
| | 19:00 | Main Build North | 2623.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.4 | | | | | | |
| | 19:10 | Main Build North | 2683.0 μSv/h | below 0.01μSv/h | Claudy | WSW | 1.0 | | | | | | |
| | 19:20 | Main Build North | 2614.0 μSv/h | below 0.01μSv/h | Claudy | SW | 2.0 | | | | | | |
| | 19:30 | Main Build North | 2602.0 μSv/h | below 0.01μSv/h | Claudy | SW | 1.8 | | | | | | |
| | 19:40 | Main Build North | 2595.0 μSv/h | below 0.01μSv/h | Claudy | NNW | 0.8 | | | | | | |
| | 19:50 | Main Build North | 2632.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.2 | | | | | | |
| | 20:00 | Main Build North | 2828.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.2 | | | | | | |
| | 20:10 | Main Build North | 2704.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.4 | | | | | | |
| | 20:20 | Main Build North | 2682.0 μSv/h | below 0.01μSv/h | Claudy | NW | 1.0 | | | | | | |
| | 20:30 | Main Build North | 2586.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.6 | | | | | | |
| | 20:40 | Main Build North | 2552.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.2 | | | | | | |
| | 20:50 | Main Build North | 2550.0 μSv/h | below 0.01μSv/h | Claudy | NW | 1.0 | | | | | | |
| | 21:00 | Main Build North | 2542.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 2.0 | | | | | | |
| | 21:10 | Main Build North | 2537.0 μSv/h | below 0.01μSv/h | Claudy | W | 2.2 | | | | | | |
| | 21:20 | Main Build North | 2532.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 2.4 | | | | | | |
| | 21:30 | Main Build North | 2518.0 μSv/h | below 0.01μSv/h | Claudy | W | 2.4 | | | | | | |
| | 21:40 | Main Build North | 2517.0 μSv/h | below 0.01μSv/h | Claudy | W | 2.0 | | | | | | |
| | 21:50 | Main Build North | 2510.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 2.0 | | | | | | |
| | 22:00 | Main Build North | 2506.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 2.2 | | | | | | |
| | 22:10 | Main Build North | 2503.0 μSv/h | below 0.01μSv/h | Claudy | NW | 1.6 | | | | | | |
| | 22:20 | Main Build North | 2492.0 μSv/h | below 0.01μSv/h | Claudy | NW | 2.2 | | | | | | |
| | 22:30 | Main Build North | 2487.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 2.6 | | | | | | |
| | 22:40 | Main Build North | 2485.0 μSv/h | below 0.01μSv/h | Claudy | NW | 3.2 | | | | | | |
| | 22:50 | Main Build North | 2483.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.2 | | | | | | |
| | 23:00 | Main Build North | 2475.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.3 | | | | | | |
| | 23:10 | Main Build North | 2469.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 0.8 | | | | | | |
| | 23:20 | Main Build North | 2462.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.0 | | | | | | |
| | 23:30 | Main Build North | 2455.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.2 | | | | | | |
| | 23:40 | Main Build North | 2457.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.0 | | | | | | |
| | 23:50 | Main Build North | 2453.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.8 | | | | | | |
| 3/21 | 0:00 | Main Build North | 2452.0 μSv/h | below 0.01μSv/h | Claudy | W | 1.0 | | | | | | |
| | 0:10 | Main Build North | 2449.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.3 | | | | | | |
| | 0:20 | Main Build North | 2444.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.9 | | | | | | |
| | 0:30 | Main Build North | 2439.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.8 | | | | | | |
| | 0:40 | Main Build North | 2438.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 0.9 | | | | | | |
| | 0:50 | Main Build North | 2433.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.0 | | | | | | |
| | 1:00 | Main Build North | 2431.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.0 | | | | | | |
| | 1:10 | Main Build North | 2429.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.8 | | | | | | |
| | 1:20 | Main Build North | 2426.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.6 | | | | | | |
| | 1:30 | Main Build North | 2421.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.5 | | | | | | |
| | 1:40 | Main Build North | 2401.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.7 | | | | | | |
| | 1:50 | Main Build North | 2398.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.8 | | | | | | |
| | 2:00 | Main Build North | 2396.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.5 | | | | | | |
| | 2:10 | Main Build North | 2392.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.9 | | | | | | |
| | 2:20 | Main Build North | 2389.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.8 | | | | | | |
| | 2:30 | Main Build North | 2385.0 μSv/h | below 0.01μSv/h | Claudy | NW | 1.0 | | | | | | |
| | 2:40 | Main Build North | 2383.0 μSv/h | below 0.01μSv/h | Claudy | N | 1.0 | | | | | | |
| | 2:50 | Main Build North | 2380.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.6 | | | | | | |
| | 3:00 | Main Build North | 2378.0 μSv/h | below 0.01μSv/h | Claudy | ESE | 0.5 | | | | | | |
| | 3:10 | Main Build North | 2375.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 0.8 | | | | | | |
| | 3:20 | Main Build North | 2372.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.8 | | | | | | |
| | 3:30 | Main Build North | 2370.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.7 | | | | | | |
| | 3:40 | Main Build North | 2366.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.7 | | | | | | |
| | 3:50 | Main Build North | 2364.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.1 | | | | | | |
| | 4:00 | Main Build North | 2362.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 0.8 | | | | | | |
| | 4:10 | Main Build North | 2356.0 μSv/h | below 0.01μSv/h | Claudy | NW | 0.6 | | | | | | |
| | 4:20 | Main Build North | 2351.0 μSv/h | below 0.01μSv/h | Claudy | NW | 1.1 | | | | | | |
| | 4:30 | Main Build North | 2350.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.3 | | | | | | |
| | 4:40 | Main Build North | 2347.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 1.6 | | | | | | |
| | 4:50 | Main Build North | 2345.0 μSv/h | below 0.01μSv/h | Claudy | WNW | 0.9 | | | | | | |
| | 5:00 | Main Build North | 2343.0 μSv/h | below 0.01μSv/h | Claudy | W | 0.7 | | | | | | |
| | 5:10 | Main Build North | 2341.0 μSv/h | below 0.01μSv/h | Claudy | E | 0.7 | | | | | | |
| | 5:20 | Main Build North | 2339.0 μSv/h | below 0.01μSv/h | Claudy | E | 0.8 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit ■ : reflection amend press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscom- munication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|------------------|--------------|-----------------|--------|------|------------------|---|---------------------------------|------------------------------------|--------------------------|---|--------|
| | 5:30 | Main Build North | 2336.0 μSv/h | below 0.01μSv/h | Claudy | ENE | 0.7 | | | | | | |
| | 5:40 | Main Build North | 2333.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.0 | | | | | | |
| | 5:50 | Main Build North | 2330.0 μSv/h | below 0.01μSv/h | Claudy | E | 1.4 | | | | | | |
| | 6:00 | Main Build North | 2324.0 μSv/h | below 0.01μSv/h | Claudy | NE | 1.2 | | | | | | |
| | 6:10 | Main Build North | 2326.0 μSv/h | below 0.01μSv/h | Claudy | SW | 1.1 | | | | | | |
| | 6:20 | Main Build North | 2325.0 μSv/h | below 0.01μSv/h | Claudy | SW | 0.9 | | | | | | |
| | 6:30 | Main Build North | 2319.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.6 | | | | | | |
| | 6:40 | Main Build North | 2312.0 μSv/h | below 0.01μSv/h | Rain | E | 1.4 | | | | | | |
| | 6:50 | Main Build North | 2293.0 μSv/h | below 0.01μSv/h | Rain | E | 1.2 | | | | | | |
| | 7:00 | Main Build North | 2283.0 μSv/h | below 0.01μSv/h | Rain | NNE | 1.0 | | | | | | |
| | 7:10 | Main Build North | 2271.0 μSv/h | below 0.01μSv/h | Rain | NNE | 0.8 | | | | | | |
| | 7:20 | Main Build North | 2251.0 μSv/h | below 0.01μSv/h | Rain | WNW | 0.7 | | | | | | |
| | 7:30 | Main Build North | 2232.0 μSv/h | below 0.01μSv/h | Rain | NE | 0.8 | | | | | | |
| | 7:40 | Main Build North | 2215.0 μSv/h | below 0.01μSv/h | Rain | NW | 0.8 | | | | | | |
| | 7:50 | Main Build North | 2200.0 μSv/h | below 0.01μSv/h | Rain | WSW | 0.9 | | | | | | |
| | 8:00 | Main Build North | 2168.0 μSv/h | below 0.01μSv/h | Rain | W | 1.2 | | | | | | |
| | 8:10 | Main Build North | 2161.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.0 | | | | | | |
| | 8:20 | Main Build North | 2147.0 μSv/h | below 0.01μSv/h | Rain | NW | 0.8 | | | | | | |
| | 8:30 | Main Build North | 2140.0 μSv/h | below 0.01μSv/h | Rain | NW | 0.7 | | | | | | |
| | 8:40 | Main Build North | 2128.0 μSv/h | below 0.01μSv/h | Rain | W | 0.7 | | | | | | |
| | 8:50 | Main Build North | 2126.0 μSv/h | below 0.01μSv/h | Rain | W | 1.7 | | | | | | |
| | 9:00 | Main Build North | 2122.0 μSv/h | below 0.01μSv/h | Rain | N | 4.6 | | | | | | |
| | 9:10 | Main Build North | 2120.0 μSv/h | below 0.01μSv/h | Rain | NE | 5.0 | | | | | | |
| | 9:20 | Main Build North | 2127.0 μSv/h | below 0.01μSv/h | Rain | W | 3.0 | | | | | | |
| | 9:30 | Main Build North | 2114.0 μSv/h | below 0.01μSv/h | Rain | W | 2.0 | | | | | | |
| | 9:40 | Main Build North | 2111.0 μSv/h | below 0.01μSv/h | Rain | NW | 4.4 | | | | | | |
| | 9:50 | Main Build North | 2108.0 μSv/h | below 0.01μSv/h | Rain | NW | 4.1 | | | | | | |
| | 10:00 | Main Build North | 2098.0 μSv/h | below 0.01μSv/h | Rain | NW | 2.1 | | | | | | |
| | 10:10 | Main Build North | 2100.0 μSv/h | below 0.01μSv/h | Rain | NW | 2.6 | | | | | | |
| | 10:20 | Main Build North | 2100.0 μSv/h | below 0.01μSv/h | Rain | W | 2.0 | | | | | | |
| | 10:30 | Main Build North | 2100.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.4 | | | | | | |
| | 10:40 | Main Build North | 2102.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.5 | | | | | | |
| | 10:50 | Main Build North | 2105.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.0 | | | | | | |
| | 11:00 | Main Build North | 2107.0 μSv/h | below 0.01μSv/h | Rain | NW | 0.9 | | | | | | |
| | 11:10 | Main Build North | 2107.0 μSv/h | below 0.01μSv/h | Rain | N | 0.8 | | | | | | |
| | 11:20 | Main Build North | 2108.0 μSv/h | below 0.01μSv/h | Rain | SW | 1.2 | | | | | | |
| | 11:30 | Main Build North | 2110.0 μSv/h | below 0.01μSv/h | Rain | N | 1.5 | | | | | | |
| | 11:40 | Main Build North | 2112.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.7 | | | | | | |
| | 11:50 | Main Build North | 2113.0 μSv/h | below 0.01μSv/h | Rain | E | 1.5 | | | | | | |
| | 12:00 | Main Build North | 2108.0 μSv/h | below 0.01μSv/h | Rain | NNE | 1.1 | | | | | | |
| | 12:10 | Main Build North | 2112.0 μSv/h | below 0.01μSv/h | Rain | SE | 0.9 | | | | | | |
| | 12:20 | Main Build North | 2107.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.9 | | | | | | |
| | 12:30 | Main Build North | 2111.0 μSv/h | below 0.01μSv/h | Rain | NW | 1.1 | | | | | | |
| | 12:40 | Main Build North | 2112.0 μSv/h | below 0.01μSv/h | Rain | NW | 0.9 | | | | | | |
| | 12:50 | Main Build North | 2110.0 μSv/h | below 0.01μSv/h | Rain | N | 0.7 | | | | | | |
| | 13:00 | Main Build North | 2105.0 μSv/h | below 0.01μSv/h | Rain | SW | 0.6 | | | | | | |
| | 13:10 | Main Build North | 2103.0 μSv/h | below 0.01μSv/h | Rain | E | 0.8 | | | | | | |
| | 13:20 | Main Build North | 2098.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.0 | | | | | | |
| | 13:30 | Main Build North | 2092.0 μSv/h | below 0.01μSv/h | Rain | E | 0.8 | | | | | | |
| | 13:40 | Main Build North | 2089.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.5 | | | | | | |
| | 13:50 | Main Build North | 2068.0 μSv/h | below 0.01μSv/h | Rain | NE | 4.3 | | | | | | |
| | 14:00 | Main Build North | 2064.0 μSv/h | below 0.01μSv/h | Rain | NE | 4.0 | | | | | | |
| | 14:10 | Main Build North | 2053.0 μSv/h | below 0.01μSv/h | Rain | N | 3.7 | | | | | | |
| | 14:20 | Main Build North | 2043.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.1 | | | | | | |
| | 14:30 | Main Build North | 2039.0 μSv/h | below 0.01μSv/h | Rain | NE | 1.2 | | | | | | |
| | 14:40 | Main Build North | 2035.0 μSv/h | below 0.01μSv/h | Rain | N | 1.3 | | | | | | |
| | 14:50 | Main Build North | 2029.0 μSv/h | below 0.01μSv/h | Rain | NE | 3.8 | | | | | | |
| | 15:00 | Main Build North | 2019.0 μSv/h | below 0.01μSv/h | Rain | N | 2.1 | | | | | | |
| | 15:10 | Main Build North | 2019.0 μSv/h | below 0.01μSv/h | Rain | N | 3.8 | | | | | | |
| | 15:20 | Main Build North | 2013.0 μSv/h | below 0.01μSv/h | Rain | NE | 5.7 | | | | | | |
| | 15:30 | Main Build North | 2013.0 μSv/h | below 0.01μSv/h | Rain | NE | 6.8 | | | | | | |
| | 15:40 | Main Build North | 2012.0 μSv/h | below 0.01μSv/h | Rain | NE | 5.8 | | | | | | |
| | 15:50 | Main Build North | 2013.0 μSv/h | below 0.01μSv/h | Rain | NE | 6.3 | | | | | | |
| | 16:00 | Main Build North | 2016.0 μSv/h | below 0.01μSv/h | Rain | N | 4.9 | | | | | | |
| | 16:10 | Main Build North | 2013.0 μSv/h | below 0.01μSv/h | Rain | NE | 5.9 | | | | | | |
| | 16:20 | Main Build North | 2011.0 μSv/h | below 0.01μSv/h | Rain | N | 5.7 | | | | | | |
| | 16:30 | Main Build North | 2015.0 μSv/h | below 0.01μSv/h | Rain | NE | 4.8 | | | | | | |
| | 16:42 | Main Gate | 1140.0 μSv/h | below 0.01μSv/h | Rain | E | 4.9 | | | | | | |
| | 16:50 | Main Gate | 508.0 μSv/h | below 0.01μSv/h | Rain | S | 0.7 | | | | | | |
| | 17:06 | MP7 | 1292.0 μSv/h | below 0.01μSv/h | Claudy | SW | 2.5 | | | | | | |
| | 17:30 | Main Gate | 729.0 μSv/h | below 0.01μSv/h | Claudy | E | 3.5 | | | | | | |
| | 17:40 | Main Gate | 494.3 μSv/h | below 0.01μSv/h | Claudy | SE | 0.9 | | | | | | |
| | 17:50 | Main Gate | 1383.0 μSv/h | below 0.01μSv/h | Claudy | ESE | 0.7 | | | | | | |
| | 18:00 | Main Gate | 1757.0 μSv/h | below 0.01μSv/h | - | ENE | 0.5 | | | | | | |
| | 18:10 | Main Gate | 1256.0 μSv/h | below 0.01μSv/h | - | ENE | 0.7 | | | | | | |
| | 18:20 | Main Gate | 1428.0 μSv/h | below 0.01μSv/h | - | NNW | 0.5 | | | | | | |
| | 18:30 | Main Gate | 1932.0 μSv/h | below 0.01μSv/h | - | SE | 0.3 | | | | | | |
| | 18:40 | Main Gate | 1499.0 μSv/h | below 0.01μSv/h | - | SSE | 0.4 | | | | | | |
| | 18:50 | Main Gate | 1105.0 μSv/h | below 0.01μSv/h | - | WSW | 0.3 | | | | | | |
| | 19:00 | Main Gate | 1201.0 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 19:10 | Main Gate | 823.6 μSv/h | below 0.01μSv/h | - | W | 0.4 | | | | | | |
| | 19:20 | Main Gate | 700.1 μSv/h | below 0.01μSv/h | - | WNW | 0.2 | | | | | | |
| | 19:30 | Main Gate | 587.3 μSv/h | below 0.01μSv/h | - | W | 0.5 | | | | | | |
| | 19:40 | Main Gate | 503.9 μSv/h | below 0.01μSv/h | - | WSW | 0.7 | | | | | | |
| | 19:50 | Main Gate | 496.2 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 20:00 | Main Gate | 493.5 μSv/h | below 0.01μSv/h | - | SW | 0.7 | | | | | | |
| | 20:10 | Main Gate | 529.3 μSv/h | below 0.01μSv/h | - | S | 0.3 | | | | | | |
| | 20:20 | Main Gate | 471.2 μSv/h | below 0.01μSv/h | - | WSW | 0.4 | | | | | | |

Monitoring result of Fukushima Daiichi Nuclear Power Station

■ : figure, place change ■ : significant figure change ■ : reflection amend
■ : new additional data ■ : change unit press release

| Date | Time | Place | γ ray | Neutron ray | wather | wind | wind speed (m/s) | miscommunication at Power Station (1)①③ | not reached to HQ (1)② | not disclosed by HQ (2)①② | not 10min data (3) | confirmed in May instrument trouble (4) | reason |
|------|-------|-----------|-------------|-----------------|--------|------|------------------|---|------------------------|---------------------------|--------------------|---|--------|
| | 20:30 | Main Gate | 442.2 μSv/h | below 0.01μSv/h | - | WNW | 0.4 | | | | | | |
| | 20:40 | Main Gate | 432.4 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 20:50 | Main Gate | 424.5 μSv/h | below 0.01μSv/h | - | WNW | 0.8 | | | | | | |
| | 21:00 | Main Gate | 417.1 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 21:10 | Main Gate | 410.4 μSv/h | below 0.01μSv/h | - | WSW | 0.7 | | | | | | |
| | 21:20 | Main Gate | 403.8 μSv/h | below 0.01μSv/h | - | WNW | 0.7 | | | | | | |
| | 21:30 | Main Gate | 398.0 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 21:40 | Main Gate | 390.6 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |
| | 21:50 | Main Gate | 384.9 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 22:00 | Main Gate | 380.0 μSv/h | below 0.01μSv/h | - | WNW | 0.6 | | | | | | |
| | 22:10 | Main Gate | 374.5 μSv/h | below 0.01μSv/h | - | W | 0.6 | | | | | | |
| | 22:20 | Main Gate | 369.6 μSv/h | below 0.01μSv/h | - | WNW | 0.5 | | | | | | |
| | 22:30 | Main Gate | 365.0 μSv/h | below 0.01μSv/h | - | NW | 0.6 | | | | | | |
| | 22:40 | Main Gate | 360.9 μSv/h | below 0.01μSv/h | - | SSW | 0.6 | | | | | | |
| | 22:50 | Main Gate | 356.0 μSv/h | below 0.01μSv/h | - | SW | 0.3 | | | | | | |
| | 23:00 | Main Gate | 352.7 μSv/h | below 0.01μSv/h | - | S | 0.2 | | | | | | |
| | 23:10 | Main Gate | 348.5 μSv/h | below 0.01μSv/h | - | W | 0.3 | | | | | | |
| | 23:20 | Main Gate | 344.6 μSv/h | below 0.01μSv/h | - | WNW | 0.4 | | | | | | |
| | 23:30 | Main Gate | 341.5 μSv/h | below 0.01μSv/h | - | NW | 0.5 | | | | | | |
| | 23:40 | Main Gate | 338.5 μSv/h | below 0.01μSv/h | - | WSW | 0.5 | | | | | | |
| | 23:50 | Main Gate | 334.1 μSv/h | below 0.01μSv/h | - | W | 0.7 | | | | | | |