

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 9)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/6/8 11:35	2011/6/8 11:30	2011/6/8 12:25	2011/6/8 11:42	2011/6/8 11:43	2011/6/8 11:47	2011/6/8 9:55
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	5.0E-01	1.3E+00	8.4E-01	1.2E-02	ND	ND	ND
Cs-134 (about 2 years)	1.1E+01	1.1E+01	4.4E-01	2.9E-02	6.7E-03	1.2E-02	ND
Cs-137 (about 30 years)	1.4E+01	1.3E+01	4.6E-01	3.5E-02	ND	9.1E-03	ND

. E - means . ×10.

Data of other nuclides are under evaluation.

ND: when the detected amount is below the detection limit in this analysis (I-131: approx. 5E-3Bq/cm³, Cs-134: approx. 7E-2Bq/cm³, Cs-137: approx. 7E-2Bq/cm³) Materials may be detected even below such limit depending on the measurement device and status of sample