

Result of Nuclide Analysis of Radioactive Materials in the Air
at the Site of Fukushima Nuclear Power Stations

Reference

(data summarized on June 18)

Place of sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm ³) ※2
Date and time of sampling	June 17, 2011 11:30am - 11:50am		June 17, 2011 9:08am - 9:18am		June 17, 2011 15:47pm - 15:57pm		
Detected nuclide (half-life)	①Radioactivity density※1 (Bq/cm ³)	Scaling factor (①/②)	①Radioactivity density※1 (Bq/cm ³)	Scaling factor (①/②)	①Radioactivity density※1 (Bq/cm ³)	Scaling factor (①/②)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	
Cs-134 (approx. 2 years)	2.8E-06	0.00	1.1E-05	0.01	4.7E-06	0.00	2E-03
Cs-137 (approx. 30 years)	3.0E-06	0.00	8.2E-06	0.00	ND	-	3E-03

※1 The value of Radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density

0.0E-0 means 0.0×10^{-0}

Data of other nuclides are under examination.

※2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.