

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

( Data summarized on June 19)

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/18 6:23 AM		2011/6/18 6:41 AM		2011/6/18 6:48 AM		2011/6/18 6:48 AM		2011/6/18 6:57 AM		
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	150	3.8	130	3.3	110	2.8	100	2.5	40
Cs-134 (about 2 years)	160	2.7	490	8.2	460	7.7	410	6.8	460	7.7	60
Cs-137 (about 30 years)	180	2.0	540	6.0	520	5.8	480	5.3	410	4.6	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

"ND" is stated in the case that density is below detectable threshold.

Detecable thresholds of the main nuclides are as follows: I-131: approx. 7Bq/L.

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

( Data summarized on June 19)

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/18 6:57 AM		2011/6/18 7:10 AM		2011/6/18 7:15 AM		2011/6/18 7:10 AM		2011/6/18 7:15 AM		
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	560	14	130	3.3	98	2.5	100	2.5	30	0.75	40
Cs-134 (about 2 years)	1,900	32	460	7.7	3,300	55	430	7.2	820	14	60
Cs-137 (about 30 years)	1,900	21	510	5.7	3,500	39	470	5.2	940	10	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

( Data summarized on June 19)

Place of Collection	Inside the south of 1F's Unit 1-4 Water Intake Canal										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/18 7:23 AM										
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-									40
Cs-134 (about 2 years)	400	6.7									60
Cs-137 (about 30 years)	470	5.2									90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1