

Result of Nuclide Analysis of Radioactive Materials in the Air  
at the Site of Fukushima Nuclear Power Stations

Reference

(data summarized on June 21)

Place of sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm <sup>3</sup> ) ※2
	Date and time of sampling	11:30 ~ 11:50 June 20, 2011	9:05 ~ 9:19 June 20, 2011	15:03 ~ 15:17 June 20, 2011	①Radioactivity density※1 (Bq/cm <sup>3</sup> )	Scaling factor (①/②)	
Detected nuclide (half-life)	①Radioactivity density※1 (Bq/cm <sup>3</sup> )	Scaling factor (①/②)	①Radioactivity density※1 (Bq/cm <sup>3</sup> )	Scaling factor (①/②)	①Radioactivity density※1 (Bq/cm <sup>3</sup> )	Scaling factor (①/②)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	1.2E-05	0.01	2.4E-05	0.01	1.7E-05	0.01	2E-03
Cs-137 (approx. 30 years)	1.0E-05	0.00	2.4E-05	0.01	1.9E-05	0.01	3E-03

※1 The value of Radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density

○.○E-○ means ○.○ x 10<sup>-○</sup>

Data of other nuclides are under examination.

※2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.