

Periodic measurement results of radioactive materials at Kashiwazaki Kariwa Nuclear Power Station

Sampling period : from May 1 to May 31, 2011
 Measurement & evaluation date : June 23rd, 2011

<Suspended dust in May>

Place of sampling		Nuclide	(1) Density (Bq/cm ³)	(2) Detectable lower limit (Bq/cm ³)	(3) Density limit in the air (Bq/cm ³) <announcement density>
Dust radiation monitor	Side of monitoring post No.1	Cesium-134	2.4×10^{-10}	4.9×10^{-12}	2×10^{-5}
		Cesium-137	2.4×10^{-10}	3.8×10^{-12}	3×10^{-5}
	Side of monitoring post No.5	Cesium-134	2.4×10^{-10}	4.6×10^{-12}	2×10^{-5}
		Cesium-137	2.3×10^{-10}	3.9×10^{-12}	3×10^{-5}
		Niobium-95	8.3×10^{-12}	5.3×10^{-12}	7×10^{-5}
	Side of monitoring post No.8	Cesium-134	2.3×10^{-10}	4.7×10^{-12}	2×10^{-5}
Cesium-137		2.3×10^{-10}	3.7×10^{-12}	3×10^{-5}	