

Fukushima Daiichi Nuclear Power Station  
Result of the measurement of Pu in the air

1. Sampling Place: West Gate, Fukushima Daiichi Nuclear Power Station
2. Institution: Japan Chemical Analysis Center
3. Results:

(Unit : mBq/m<sup>3</sup>)

Sample Type	Sample Date	Pu-238	Pu-239, Pu-240
Volatile	6/6	N. D.	N. D.
Particulate		N. D.	N. D.

4. Valuation:

Pu-238, Pu-239 and Pu-240 were not detected from samples collected this time.

End