

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 29)

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/28 6:40		2011/6/28 6:56		2011/6/28 7:00		2011/6/28 7:02		2011/6/28 7:05		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	ND	-	24	0.60	24	0.60	50	1.3	100	2.5	40
Cs-134 (about 2 years)	81	1.4	160	2.7	160	2.7	470	7.8	230	3.8	60
Cs-137 (about 30 years)	90	1.0	180	2.0	190	2.1	520	5.8	270	3.0	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

"ND" is stated in the case that density is below detectable threshold.

Detectable thresholds of the main 3 nuclides are as follows: I-131: approx. 11Bq/L.

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 29)

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	2011/6/28 7:09		2011/6/28 7:12		2011/6/28 7:15		2011/6/28 7:17		2011/6/28 7:21	
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	390	9.8	29	0.73	81	2.0	27	0.68	50	1.3	40
Cs-134 (about 2 years)	1,500	25	160	2.7	4,500	75	230	3.8	1,800	30	60
Cs-137 (about 30 years)	1,600	18	190	2.1	4,800	53	240	2.7	2,000	22	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 29)

Place of Collection	Inside the south of 1F's Unit 1-4 Water Intake Canal										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/28 7:26										
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	23	0.58									40
Cs-134 (about 2 years)	350	5.8									60
Cs-137 (about 30 years)	390	4.3									90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1