

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on July 2)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	July 1, 2011 11:45	July 1, 2011 12:00	July 1, 2011 12:15	July 1, 2011 11:38	July 1, 2011 11:30	July 1, 2011 11:25	July 1, 2011 10:25
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	ND	2.5E-01	1.0E-01	ND	ND	ND	ND
Cs-134 (about 2 years)	5.9E+00	9.6E+00	2.5E-01	ND	ND	ND	ND
Cs-137 (about 30 years)	7.1E+00	1.1E+01	3.3E-01	ND	ND	ND	ND

. E - means . ×10.

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 5E-2Bq/cm³, Cs-134: approx. 3E-2Bq/cm³, Cs-137: approx.4E-2Bq/cm³). However, nuclides below limits might be detected since detection limits depend on detector and condition of sample.