

## Results of Nuclide Analysis of Seawater <Coast>

Reference

( Data summarized on : July 21 )

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)	Around South Discharge Channel of 1F ( approx. 330m south of 1-4u Discharge Channel)				Around North Discharge Channel of 2F ( Around 3,4u Discharge Channel) ( approx. 10 km from 1F )	Around Iwasawa Shore of 2F ( approx. 7 km south of 1,2u Discharge Channel) ( approx. 16 km from 1F )		Density limit by the announcement of Reactor Regulation (Bq/L)		
Time and Date of Sample Collection	Cancel July 20, 2011	Cancel July 20, 2011		N/A		8:25 July 20, 2011		8:00 July 20, 2011		(the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)		Scaling Factor ( / )
I-131 (about 8 days)	/	/	/	/	/	/	ND	-	ND		-
Cs-134 (about 2 years)	/	/	/	/	/	/	4.5	0.08	ND	-	60
Cs-137 (about 30 years)	/	/	/	/	/	/	6.1	0.07	ND	-	90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm<sup>3</sup> to Bq/L.

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit, "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 3Bq/L, Cs-134: approx. 4Bq/L, Cs-137: approx. 4Bq/L.

However, detection limits differs depending on the detectors and samples types, and therefore may be detected, under figures below.