

Results of Nuclide Analysis of Radioactive Materials in the Air
at the Sites of Fukushima Nuclear Power Stations

Reference

(Data Summarized on July 23)

Place of sampling	South-southwest Boundary of Site, Fukushima Daiichi (Additional monitoring at the time of nitrogen injection)		West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2) 2
	Date and time of sampling	2011/07/22 9:30 ~ 9:50	2011/07/22 11:30 ~ 11:50	2011/07/22 9:30 ~ 9:40	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	
Detected nuclide (half-life)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	6.8E-06	0.00	ND	-	ND	-	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	3E-03

1 The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

. E - means . x 10⁻

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.

3 * In this analysis, "ND" means that the results fall below the measurable threshold.

(Volatile: I-131: approx. 4E-6Bq/cm³, Cs-134: approx. 1E-5Bq/cm³, and Cs-137: approx. 1E-5Bq/cm³)

(Particulate: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 6E-6Bq/cm³, and Cs-137: approx. 7E-6Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.