

(Attachment)

Analysis Results of Pu in Seawater at Fukushima Daiichi Nuclear Power Station

1. Sampling Point: North of Discharge Channel of Unit 5 and 6
Near South Discharge Channel
2. Analytical Body : Japan Chemical Analysis Center
3. Measurement Results:

(Unit: Bq/L)

Sampling Point	Date of Sampling	Pu-238	Pu-239, Pu-240
North of Discharge Channel of Unit 5 and 6, 1F	7/11	N.D. [$<5.1 \times 10^{-1}$]	N.D. [$<5.1 \times 10^{-1}$]
Near South Discharge Channel, 1F		N.D. [$<4.9 \times 10^{-1}$]	N.D. [$<4.9 \times 10^{-1}$]

Values in [] show the detectable limits.

4. Evaluation:

From the samples of this measurement, no Pu-238, Pu-239 and Pu-240 were detected

END