

Nuclide Analysis Results of Sub-drains

Reference

(Data summarized on July 28)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/07/27 11:50	2011/07/27 11:54	2011/07/27 12:01	2011/07/27 11:29	2011/07/27 11:41	2011/07/27 11:34	2011/07/27 9:35
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	ND	ND	1.5E-02	ND	ND	ND	ND
Cs-134 (about 2 years)	1.2E+00	2.9E+00	1.6E-01	6.7E-02	ND	ND	ND
Cs-137 (about 30 years)	1.5E+00	3.6E+00	1.8E-01	8.1E-02	ND	ND	ND

. E± means . ×10[±] .

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 4E-2Bq/cm³, Cs-134: approx. 3E-2Bq/cm³, Cs-137: approx.4E-2Bq/cm³).

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.