

Nuclide Analysis Results of Radioactive Materials in the Air
at the Sites of Fukushima Nuclear Power Stations <1/2>

Reference

(Data Summarized on August 3)

Place of sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation (Bq/cm3) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2) 2
Date and time of sampling	8/2/2011 11:30am - 12:10pm		8/2/2011 9:35am - 9:45am				
Detected nuclide (half-life)	Radioactivity density 1 (Bq/cm3)	Scaling factor (/)	Radioactivity density 1 (Bq/cm3)	Scaling factor (/)	Radioactivity density 1 (Bq/cm3)	Scaling factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	/	/	1E-03
Cs-134 (approx. 2 years)	ND	-	ND	-	/	/	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	/	/	3E-03

1 The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

E - means $\times 10^E$

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.

3 In this analysis, "ND" means that the results fall below detection limits.

(Volatile: I-131: approx. 2E-6Bq/cm3, Cs-134: approx. 3E-6Bq/cm3, and Cs-137: approx. 3E-6Bq/cm3)

(Particulate: I-131: approx. 1E-6Bq/cm3, Cs-134: approx. 2E-6Bq/cm3, and Cs-137: approx. 2E-6Bq/cm3)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Nuclide Analysis Results of Radioactive Materials in the Air
at the Sites of Fukushima Nuclear Power Stations <2/2>

Reference

(Data Summarized on August 3)

Place of sampling	MP-1, Fukushima Daiichi		MP-3, Fukushima Daiichi		MP-8, Fukushima Daiichi		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2) 2
Date and time of sampling	8/2/2011 9:54am - 2:54pm		8/2/2011 10:09am - 3:09pm		8/2/2011 10:16am - 3:16pm		
Detected nuclide (half-life)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	ND	-	ND	-	2.6E-06	0.00	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	3E-03

1 The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

E - means $\times 10^{\text{E}}$

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.

3 In this analysis, "ND" means that the results fall below detection limits.

(Volatile: I-131: approx. 1E-6Bq/cm³, Cs-134: approx. 3E-6Bq/cm³, and Cs-137: approx. 4E-6Bq/cm³)

(Particulate: I-131: approx. 8E-7Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, and Cs-137: approx. 2E-6Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.