

Nuclide Analysis Results of Sub-drains

Attachment

(Data summarized on August 5)

Place of sampling	Sub-drain of Unit3 Fukushima Daiichi
Date of Sample Collection	July 18, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)
I-131 (about 8 days)	ND
Cs-134 (about 2 years)	4.8E-02
Cs-137 (about 30 years)	ND
Sr-89 (about 51 days)	1.4E-04
Sr-90 (about 29 years)	7.3E-05

. E - means . ×10.

Data for I-131, Cs-134 and Cs-137 were published on July 19.

Evaluation Body: Japan Chemical Analysis Center (Sr-89,90), TEPCO(I-131, Cs-134, Cs-137)

(Comment)

Sr-89 and Sr-90 were detected. This is considered as effects of the accident.