

TEPCO Plant Status of Fukushima Daini Nuclear Power Station (as of 3:00 pm August 5, 2011)

Appendix

	Unit 1	Unit 2	Unit 3	Unit 4
Shutdown	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted
Cooling	Residual heat removal system (B) is in operation (From March 14th)  Residual heat removal system (A) was disabled due to tsunami  Reactor Coolant Filtering System is in operation (From July 16th) [Securing alternative heat removal function in cold shutdown]  Cold shutdown * (From March 14th)	Residual heat removal system (B) is in operation (From March 14th)  Residual heat removal system (A) was disabled due to tsunami  Reactor Coolant Filtering System is in operation (From July 17th) [Securing alternative heat removal function in cold shutdown]  Cold shutdown * (From March 14th)	Residual heat removal system (B) is in operation (From March 12th)  Residual heat removal system (A) was disabled due to tsunami  Reactor Coolant Filtering System is in operation (From June 6th) [Securing alternative heat removal function in cold shutdown]  Cold shutdown * (From March 12th)	Residual heat removal system (A) is in operation (From August 3rd)  <u>Although Residual heat removal system (B) had operated from March 14th, currently it is not standby condition from August 4 after switch to the system (A).</u>  Reactor Coolant Filtering System is in operation (From June 4th) [Securing alternative heat removal function in cold shutdown]  Cold shutdown * (From March 15th)
Containment	No reactor coolant is leaked in the primary containment vessel  Water temperature in the suppression chamber is stable (generally 30 ). (On March 14th, achieved below 100 )  Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the primary containment vessel  Water temperature in the suppression chamber is stable (generally 30 ). (On March 14th, achieved below 100 )  Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the primary containment vessel  Water temperature in the suppression chamber is stable (generally 30 ). (Maintain below 100 as before the earthquake occurred)  Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the primary containment vessel  Water temperature in the suppression chamber is stable (generally 30 ). (On March 14th, achieved below 100 )  Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented
Offsite power	Functioning	Functioning	Functioning	Functioning
Emergency power supply sources	Emergency diesel generator (B) Receiving electricity from the bus of emergency diesel generator (B) of Unit 2 Receiving electricity from the bus of emergency diesel generator (B) of Unit 3	Emergency diesel generator (B)(H)	Emergency diesel generator (B)(H)	Emergency diesel generator (A) (B)(H)
Others, any reports regarding abnormal matters	At 5:35 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( reactor coolant is leaked (pressure in the reactor containment vessel increased) ) At 6:33 pm o			
	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant is lost) At 1:24 am on March 14th, Residual heat removal system (B)	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant is lost) At 7:13 am on March 14th, Residual heat removal system (B)		At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant is lost) At 3:42 pm on March 14th, Residual heat removal system (B)
	At 5:22 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber is lost) At 10:15 am on March 14th, restored with the water	At 5:32 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber is lost) At 3:52 pm on March 14th, restored with the water		At 6:07 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber is lost) At 7:15 am on March 15th, restored with the water
	At 10:07 pm on March 14th at the MP 1 and 12:12 am on March 15th at the MP 3, Occurance of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (increase in radioactive material at the boundary) due to the influence by Fukushima Daiichi Nuclear Power Station. After 9:30 am, April 3, radiation dose at the boundary of the site at Fukushima Daini Nuclear Power Station measured by MP remains below 5 μSv/h Regarding the result of measurement, please refer to TEPCO website at <a href="http://www.tepco.co.jp/en/nu/fukushima-np/f2/index-e.html">http://www.tepco.co.jp/en/nu/fukushima-np/f2/index-e.html</a>			

\* : Cold shutdown . . . Achieved shutdown and maintain average water temperature below 100 in the Pressure Suppression Chamber.