## Nuclide Analysis Results of Radioactive Materials in the Air at Site of Power Station

(Data Summarized on August 7)

Reference

Place of sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation ( Bq/cm3 ) (Density limit in the air to which radiation workers breathe in the
Date and time of sampling	7:00 - 12:00 August 6, 2011		9:39 - 9:49 August 6, 2011				
Detected nuclide (half-life)	Radioactivity density 1 3 ( Bq/cm3)	Scaling factor	Radioactivity density 1 3 ( Bq/cm3)	Scaling factor	Radioactivity density 1 3 ( Bq/cm3)	Scaling factor	section 4 of the appendix 2) 2
I-131 (approx. 8 days)	ND	-	ND	-			1E-03
Cs-134 (approx. 2 years)	1.7E-06	0.00	ND	-			2E-03
Cs-137 (approx. 30 years)	1.7E-06	0.00	ND	ı			3E-03

<sup>1</sup> The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

. E - means .  $x 10^{-3}$ 

Data of other nuclides are under examination.

- 2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.
- 3 In this analysis, "ND" means that the results fall bellow detection limits.

Detection limits of 3 nuclides are as follows;

Volatile I-131: approx. 2E-6Bq/cm3, Cs-134: approx. 3E-6Bq/cm3, and Cs-137: approx. 3E-6Bq/cm3 Particle I-131: approx. 1E-6Bq/cm3, Cs-134: approx. 2E-6Bq/cm3, and Cs-137: approx. 2E-6Bq/cm3

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on detectors or samples. <Reference>

From August 6, as the reault of reduction of detection limit, the detection limits on the West Gate of Fukushima Daiichi are as follows Volatile I-131: approx. 1E-7Bq/cm3, Cs-134: approx. 3E-7Bq/cm3, and Cs-137: approx. 4E-7Bq/cm3

Particle I-131: approx. 1E-7Bq/cm3, Cs-134: approx. 2E-7Bq/cm3, and Cs-137: approx. 2E-7Bq/cm3