

Exhibit

Nuclide Analysis Results of Radioactive Materials in Seawater  
< Inside of water intake for Unit 1-4, Fukushima Daiichi Nuclear Power Station >

( Data summarized on August 16 )

Place of Sampling	Inside the north of 1F's Units 1-4 Water Intake Canal		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Date of Sampling	July 11, 2011		
Detected nuclide (half-life)	Density of sample ( Bq/L )	Scaling factor ( / )	
I-131 (approx. 8 days)	ND		40
Cs-134 (approx. 2 years)	410	6.8	60
Cs-137 (approx. 30 years)	450	5.0	90
H-3 (approx. 12 years)	580	0.01	60,000
all	ND		
all	650		

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/L" converted from the value originally in "Bq/cm<sup>3</sup>".

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Results on I-131, Cs-134 and Cs-137 were announced on July 12.

( Evaluation )

H-3 and all beta-radioactivity were detected, which is considered to be caused by this nuclear accident.