

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <1/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 17)

Place of Collection	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)			
	Time and date of sample collection	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)		Scaling factor ( / )		
	2011/08/16 06:45		-			2011/08/16 06:54			2011/08/16 07:00			2011/08/16 07:03		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )		
I-131 (about 8 days)	ND	-			ND	-	ND	-	ND	-	ND	-	40	
Cs-134 (about 2 years)	81	1.4			270	4.5	270	4.5	300	5.0	300	5.0	60	
Cs-137 (about 30 years)	110	1.2			290	3.2	320	3.6	360	4.0	360	4.0	90	

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 27Bq/L), "ND" is represented.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <2/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 17)

Place of Collection	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	300	5.0	430	7.2	460	7.7	800	13	350	5.8	60
Cs-137 (about 30 years)	350	3.9	490	5.4	490	5.4	960	11	400	4.4	90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 19Bq/L), "ND" is represented.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <3/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 17)

Place of Collection	Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi Nuclear Power Plant						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	2011/08/16 07:30		2011/08/16 07:36		-					
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	ND	-							40
Cs-134 (about 2 years)	560	9.3	390	6.5							60
Cs-137 (about 30 years)	690	7.7	460	5.1							90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 21Bq/L), "ND" is represented.