Nuclide Analysis Results of Seawater < Coast>

Reference

(Data summarized on August 24)

Place of Sampling	North of Discha of 5-6u o (approx. 30m n discharge o	of 1F orth of 5-6u			arge Channel c -4u Discharge		Around North Channel (Around 3,4u Chanr (approx. 10 ki	of 2F I Discharge nel)	Around Iwasawa (appox. 7 km s Discharge 0 (appox. 16 km	south of 1,2u Channel)	② Density limit by the announcement of Reactor Regulation (Bq/L)	
Time and Date of Sample Collection	10:05 am August 23, 2011		9:45 A ugust 23		2:45 pm August 23, 2011		8:20 August 23		7:50 August 23	, 2011	(the density limit in the water outside of	
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	ı	40	
Cs-134 (about 2 years)	ND	_	ND	_	ND	-	ND		ND	_	60	
Cs-137 (about 30 years)	ND	_	ND	_	ND	-	ND	_	ND	_	90	

X Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

Detection limits of the three main nuclides on North of Discharge Channel of 5-6u of 1F and around South Discharge Channel of 1F are as follows:

I-131: approx. 9Bq/L., Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L.

Detection limits of the three main nuclides around North Discharge Channel of 2F and Iwasawa Shore of 2F are as follows:

I-131: approx. 4Bq/L., Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L.

[※] Data of other nuclides are under evaluation.

 $[\]mbox{\%}$ In the case that the data is below measurable limit, "ND" is stated.

Results of Nuclide Analysis of Seawater < Offshore 1/2>

Reference

(Data summarized on August 24)

Place of Sampling	15 km offshore of MinamiSouma City Upper layer		15 km offshore of MinamiSouma City Lower layer		15 km offshore of Ukedo-gawa Upper layer		15 km offshore of Ukedo-gawa Lower layer		15 km offshore of Fukushima Daiichi Upper layer		15 km offshore of Fukushima Daiichi Lower layer		② Density limit by the announcement of Reactor Regulation
Time and Date of Sample Collection	9:00 am August 23, 2011		9:00 am August 23, 2011		8:35 am August 23, 2011		8:35 am August 23, 2011		8:30 am August 23, 2011		8:30 am August 23, 2011		(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	water outside of
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	15 km offshore of Fukushima Daini Upper layer		15 km offshore of Fukushima Daini Lower layer		15 km offshore of Iwasawa Shore Upper layer		15 km offshore of Iwasawa Shore Lower layer		15 km offshore of Hirono- machi Upper layer		15 km offshore of Hirono- machi Lower layer		② Density limit by the announcement of
Time and Date of Sample Collection	7:55 am August 23, 2011		7:55 am August 23, 2011		7:25 am August 23, 2011		7:25 am August 23, 2011		6:55 am August 23, 2011		6:55 am August 23, 2011		Reactor Regulation (Bq/L) (the density limit in
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	the water outside of
I-131 (about 8 days)	ND	ı	ND	-	ND	-	ND	-	ND	ı	ND	_	40
Cs-134 (about 2 years)	ND	ı	ND	-	ND	-	ND	-	ND	ı	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	_	ND	_	ND	_	ND	ı	ND	_	90

X Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

X Data of other nuclides are under evaluation.

[%] In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

X In the case that the data is below detective limits (I-131: approx. 4Bq/L., Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L), "ND" is stated.

Results of Nuclide Analysis of Seawater < Offshore 2/2>

Reference

(Data summarized on August 24)

Place of Sampling Time and Date of Sample Collection	3 km offshore of Iwaki Upper layer N/A		3 km offshore of Iwaki Lower layer N/A		3 km offshore of Natsui river Upper layer N/A		3 km offshore of Natsui river Lower layer N/A		3 km offshore of Onahama port Upper layer N/A		3 km offshore of Onahama port Lower layer N/A		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	water outside of
I-131 (about 8 days)													40
Cs-134 (about 2 years)													60
Cs-137 (about 30 years)													90

Place of Sampling	3 km offshore of Ena Upper layer		3 km offshore of Ena Lower layer		3 km offshore of Numanouchi Upper layer		3 km offshore of Numanouchi Lower layer		3 km offshore of Toyoma Upper layer		3 km offshore of Toyoma Lower layer		② Density limit by the announcement of
Time and Date of Sample Collection	5:35 am August 23, 2011		5:35 am August 23, 2011		N/A		N/A		N/A		N/A		Reactor Regulation (Bq/L) (the density limit in
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	①Density of Sample (Bq/L)	Scaling Factor (1)/2)	the water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-									40
Cs-134 (about 2 years)	ND	-	ND	1									60
Cs-137 (about 30 years)	ND	_	ND	_									90

X Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

^{*} Data of other nuclides are under evaluation.

X In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below detective limits (I-131: approx. 4Bq/L., Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L), "ND" is stated.