

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <1/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 26)

Place of Collection	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	2011/8/25 7:40	N/A		2011/8/25 7:52	2011/8/25 7:58		2011/8/25 8:00			
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-			ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	29	0.48			77	1.3	39	0.65	49	0.82	60
Cs-137 (about 30 years)	46	0.51			86	0.96	59	0.66	38	0.42	90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold (I-131: approx. 13Bq/L), "ND" is represented.

However, these nuclides are sometimes detected even when they are below the measurable limits, as the limitis differ in detectors or specifications of samples.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <2/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 26)

Place of Collection	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	
2011/8/25 8:09	2011/8/25 8:13	2011/8/25 8:19	2011/8/25 8:23	2011/8/25 8:27							
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	73	1.2	110	1.8	41	0.68	120	2.0	46	0.77	60
Cs-137 (about 30 years)	79	0.88	110	1.2	65	0.72	130	1.4	49	0.54	90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold (I-131: approx. 15Bq/L), "ND" is represented.

However, these nuclides are sometimes detected even when they are below the measurable limits, as the limitis differ in detectors or specifications of samples.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <3/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 26)

Place of Collection	Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi Nuclear Power Plant						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	
2011/8/25 8:30	2011/8/25 8:35	N/A									
I-131 (about 8 days)	ND	-	ND	-							40
Cs-134 (about 2 years)	76	1.3	57	0.95							60
Cs-137 (about 30 years)	89	0.99	88	0.98							90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold (I-131: approx. 14Bq/L), "ND" is represented.

However, these nuclides are sometimes detected even when they are below the measurable limits, as the limitis differ in detectors or specifications of samples.