

Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on August 30)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)				Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	10:10 Aug 29 2011	09:50 Aug 29 2011		14:55 Aug 29 2011		08:20 Aug 29 2011		07:55 Aug 29 2011		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. Detection limits of the three main nuclides on North of Discharge Channel of 5-6u of 1F and around South Discharge Channel of 1F are as follows: I-131: approx. 9Bq/L, Cs-134: approx. 21Bq/L, Cs-137: approx. 24Bq/L Detection limits of the three main nuclides around North Discharge Channel of 2F and Iwasawa Shore of 2F are as follows: I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on August 30)

Place of Sampling	15 km offshore of Minami-Souma City Upper layer		15 km offshore of Minami-Souma City Lower layer		15 km offshore of Ukedo-river aUpper layer		15 km offshore of Ukedo-river Lower layer		15 km offshore of Fukushima Daiichi Upper layer		15 km offshore of Fukushima Daiichi Lower layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (approx. 8 days)	/	/	/	/	/	/	/	/	/	/	/	/	40
Cs-134 (approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	/	60
Cs-137 (approx. 30 years)	/	/	/	/	/	/	/	/	/	/	/	/	90

Place of Sampling	15 km offshore of Fukushima Daini Upper layer		15 km offshore of Fukushima Daini Lower layer		15 km offshore of Iwasawa Shore Upper layer		15 km offshore of Iwasawa Shore Lower layer		15 km offshore of Hirono-town Upper layer		15 km offshore of Hirono-town Lower layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		2011 Aug 29 (Not sampled)		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (approx. 8 days)	/	/	/	/	/	/	/	/	/	/	/	/	40
Cs-134 (approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	/	60
Cs-137 (approx. 30 years)	/	/	/	/	/	/	/	/	/	/	/	/	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

Results of Nuclide Analysis of Seawater <Offshore 2/2>

Reference

(Data summarized on August 30)

Place of Sampling	3 km offshore of Iwaki Upper layer		3 km offshore of Iwaki Lower layer		3 km offshore of Natsui river Upper layer		3 km offshore of Natsui river Lower layer		3 km offshore of Onahama port Upper layer		3 km offshore of Onahama port Lower layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	06:25 Aug 29 2011	06:25 Aug 29 2011	06:05 Aug 29 2011	06:05 Aug 29 2011	05:35 Aug 29 2011	05:35 Aug 29 2011						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore of Ena Upper layer		3 km offshore of Ena Lower layer		3 km offshore of Numanouchi Upper layer		3 km offshore of Numanouchi Lower layer		3 km offshore of Toyoma Upper layer		3 km offshore of Toyoma Lower layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time of Sampling	05:45 Aug 29 2011	05:45 Aug 29 2011	05:50 Aug 29 2011	05:50 Aug 29 2011	05:35 Aug 29 2011	05:35 Aug 29 2011						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L