

Result of nuclide analysis of sub drains at Fukushima Daiichi Nuclear Power Plant

Appendix 2

(Data summarized on September 3)

Place of Sampling	Unit 2	Unit 5	Unit 4
Date of sampling	2011/8/15	2011/8/15	2011/8/15
Detected Nuclides (Half-life)	density of sample (Bq/cm3)		
I-131 (about 8 days)	ND	ND	ND
Cs-134 (about 2 years)	5.2E+00	ND	ND
Cs-137 (about 30 years)	6.5E+00	ND	ND
Sr-89(about 51 years)	2.3E+00	ND	ND
Sr-90 (about 29 years)	2.3E+00	8.8E-05	7.2E-05

* E± is same as . × 1 0± .

* I-131 , Cs-134 , Cs-137 informed on August 16.

*Analysis Institute : JCAC (Sr-89 , Sr-90) , TEPCO (I-131 , Cs-134 , Cs-137)

(Evaluation)

Sr-89 , Sr-90 detected causedby this accident.