

Nuclide Analysis Results of Radioactive Materials
in the Air at the Sites of Fukushima Nuclear Power Stations < 1/3 >

Reference

(Data summarized on September 8)

Place of Sampling	West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2)
Time of Sampling	2011/9/7 7:00 ~ 12:00		2011/9/7 9:26 ~ 9:36				
Detected Nuclides (Half-life)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	/	/	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	/	/	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	/	/	3E-03

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10-O

Data of other nuclides are under examination.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

Detection limits of 3 nuclides on the West Gate of Fukushima Daiichi are as follows:

Volatile: I-131: approx. 2E-7Bq/cm³, Cs-134: approx. 4E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Particulate: I-131: approx. 7E-8Bq/cm³, Cs-134: approx. 2E-7Bq/cm³, Cs-137: approx. 2E-7Bq/cm³

Detection limits of 3 nuclides on MP-1 of Fukushima Daini are as follows:

Volatile: I-131: approx. 2E-6Bq/cm³, Cs-134: approx. 4E-6Bq/cm³, Cs-137: approx. 4E-6Bq/cm³

Particulate: I-131: approx. 1E-6Bq/cm³, Cs-134: approx. 2E-6Bq/cm³, Cs-137: approx. 2E-6Bq/cm³

Nuclide Analysis Results of Radioactive Materials
in the Air at the Sites of Fukushima Nuclear Power Stations < 2/3 >

Reference

(Data summarized on September 8)

Place of Sampling	Fukushima Daiichi MP-1		Fukushima Daiichi MP-3		Fukushima Daiichi MP-8		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2)
Time of Sampling	N/A		N/A		2011/9/7 10:34 ~ 15:34		
Detected Nuclides (Half-life)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	1E-03
Cs-134 (about 2 years)	-	-	-	-	ND	-	2E-03
Cs-137 (about 30 years)	-	-	-	-	ND	-	3E-03

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10^{-O}

Data of other nuclides are under examination.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. The followings show the detection limits.

Volatile: I-131: approx. 2E-7Bq/cm³, Cs-134: approx. 6E-7Bq/cm³, Cs-137: approx. 6E-7Bq/cm³

Particulate: I-131: approx. 1E-7Bq/cm³, Cs-134: approx. 3E-7Bq/cm³, Cs-137: approx. 4E-7Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Nuclide Analysis Results of Radioactive Materials
in the Air at the Sites of Fukushima Nuclear Power Stations < 3/3 >

Reference

(Data summarized on September 8)

Place of Sampling	Fukushima Daiichi NPS Unit 1 Mountainside	Fukushima Daiichi NPS Unit 1 Mountainside	Fukushima Daiichi NPS Unit 3 Mountainside	Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2)			
Time of Sampling	2011/9/7 11:02 ~ 13:02	2011/9/7 11:04 ~ 13:04	N/A				
Detected Nuclides (Half-life)	density of sample (Bq/cm ³)	Scaling Factor (/)	density of sample (Bq/cm ³)				
I-131 (about 8 days)	ND	-	ND	-	-	-	1E-03
Cs-134 (about 2 years)	3.6E-05	0.02	ND	-	-	-	2E-03
Cs-137 (about 30 years)	1.8E-05	0.01	ND	-	-	-	3E-03

* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE - O means O.O x 10-O

Data of other nuclides are under examination.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. The followings show the detection limits.

Volatile: I-131: approx. 6E-6Bq/cm³, Cs-134: approx. 1E-5Bq/cm³, Cs-137: approx. 2E-5Bq/cm³

Particulate: I-131: approx. 3E-6Bq/cm³, Cs-134: approx. 7E-6Bq/cm³, Cs-137: approx. 8E-6Bq/cm³

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.