

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on September 8)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	10:50 Sep 07 2011	10:55 Sep 07 2011	11:00 Sep 07 2011	09:52 Sep 07 2011	10:45 Sep 07 2011	10:40 Sep 07 2011	10:25 Sep 07 2011
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	9.5E-01	4.9E+00	3.6E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	1.2E+00	6.2E+00	6.2E-02	3.9E-02	ND	ND	ND

* O.OE - O means O.O x 10-O

* Data of other nuclides are under examination.

* "ND" means the sampled data is below measurable limit. I-131: approx. 5E-2Bq/cm3, Cs-134: approx. 3E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3 Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.