

Pu analysis of seawater at Fukushima Daiichi Nuclear Power Station

1. Place of sampling :

15km offshore of Fukushima Daiichi Nuclear Power Station

15km offshore of Fukushima Daini Nuclear Power Station

2. Analyzed by : Japan chemical analysis center

3. Result :

(unit : mBq/L)

Place of sampling	Date of sampling	Pu-238	Pu-239,Pu-240
15km offshore, 1F	8/27	N.D. [$<4.5 \times 10^{-1}$]	N.D. [$<4.3 \times 10^{-1}$]
15km offshore, 2F		N.D. [$<4.5 \times 10^{-1}$]	N.D. [$<4.5 \times 10^{-1}$]

[] is the lower measurable limit

4. Evaluation:

We did not detect Pu-238, Pu-239 or Pu-240 from samples analyzed this time.

End