

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

(Data summarized on September 17)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	11:30 Sep 16 2011	11:35 Sep 16 2011	11:40 Sep 16 2011	09:43 Sep 16 2011	11:25 Sep 16 2011	11:20 Sep 16 2011	09:45 Sep 16 2011
Detected Nuclides (Half-life)	Density of sample ( Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	8.3E-01	4.8E+00	ND	1.2E-01	ND	ND	ND
Cs-137 (about 30 years)	1.0E+00	6.3E+00	3.9E-02	1.6E-01	ND	ND	ND

\* O.OE - O means O.O x 10-O

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit. I-131: approx. 5E-2Bq/cm<sup>3</sup>, Cs-134: approx. 3E-2Bq/cm<sup>3</sup>, Cs-137: approx. 3E-2Bq/cm<sup>3</sup> )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.