

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on September 24)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	10:45 Sep 23 2011	10:50 Sep 23 2011	10:55 Sep 23 2011	09:37 Sep 23 2011	10:30 Sep 23 2011	10:35 Sep 23 2011	10:05 Sep 23 2011
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	4.3E+00	2.1E+00	1.7E-01	1.0E-01	ND	ND	ND
Cs-137 (about 30 years)	5.7E+00	2.7E+00	1.9E-01	1.2E-01	ND	ND	ND

* O.OE - O means O.O x 10-O

* Data of other nuclides are under evaluation.

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.