

Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on October 4)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	2011/10/3 8:50		2011/10/3 8:30		2011/10/3 8:25		2011/10/3 7:55		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on October 4)

Place of Sampling	3 km offshore of Haramachi Ward Upper layer	3 km offshore of Haramachi Ward Lower layer	3 km offshore of Odaka Ward Upper layer	3 km offshore of Odaka Ward Lower layer	3 km offshore of Iwasawa shore Upper layer	3 km offshore of Iwasawa shore Lower layer	Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)						
Time of Sampling	2011/10/3 (Not sampled)		2011/10/3 (Not sampled)		2011/10/3 (Not sampled)			2011/10/3 7:15		2011/10/3 7:15			
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)		Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)		
I-131 (about 8 days)	-	-	-	-	-	-	-	-	ND	-	ND	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	ND	-	ND	-	90

Place of Sampling	8 km offshore of Odaka Ward Upper layer	8 km offshore of Odaka Ward Lower layer	8 km offshore of Iwasawa shore Upper layer	8 km offshore of Iwasawa shore Lower layer									Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	2011/10/3 0:00 (Not sampled)		2011/10/3 0:00 (Not sampled)		2011/10/3 0:00 7:35		2011/10/3 0:00 7:35		/		/		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	ND	-	ND	-	/		/		40
Cs-134 (about 2 years)	-	-	-	-	ND	-	ND	-	/		/		60
Cs-137 (about 30 years)	-	-	-	-	ND	-	ND	-	/		/		90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L

Results of Nuclide Analysis of Seawater <Offshore 2/2>

Reference

(Data summarized on October 4)

Place of Sampling	3 km offshore of Souma City Upper layer		3 km offshore of Souma City Lower layer		5 km offshore of Souma City Upper layer		5 km offshore of Souma City Lower layer		5 km offshore of Kashima City Upper layer		5 km offshore of Kashima City Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	N/A		N/A		N/A		N/A		N/A		N/A		
Time of Sampling													
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore of Ena Upper layer		3 km offshore of Ena Lower layer		3 km offshore of Numanouchi Upper layer		3 km offshore of Numanouchi Lower layer		3 km offshore of Toyoma Upper layer		3 km offshore of Toyoma Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	2011/10/3 5:50		2011/10/3 5:50		2011/10/3 6:10		2011/10/3 6:10		2011/10/3 5:55		2011/10/3 5:55		
Time of Sampling													
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L