

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

(Data summarized on October 4)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Date of Sampling	2011/10/3 9:25	2011/10/3 9:30	2011/10/3 9:35	2011/10/3 10:03	2011/10/3 9:20	2011/10/3 9:15	2011/10/3 9:00
Detected Nuclides (Half-life)	Density of sample ( Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	6.8E-01	1.1E+00	8.5E-02	9.0E-02	ND	ND	ND
Cs-137 (about 30 years)	8.6E-01	1.4E+00	1.1E-01	8.2E-02	ND	ND	ND

\* O.OE - O means O.O x 10-O

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit. I-131: approx. 3E-2Bq/cm3, Cs-134: approx. 3E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3 )  
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.