

Result of nuclide analysis of sub drain

Attachment

(Data summarized on October 15)

Place of Sampling	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain
Date of sampling	2011/9/12	2011/9/12	2011/9/12
Detected Nuclides (Half-life)	density of sample (Bq/cm ³)		
I-131 (about 8 days)	ND	ND	ND
Cs-134 (about 2 years)	4.9E+00	ND	ND
Cs-137 (about 30 years)	6.3E+00	ND	ND
H-3 (about 12 years)	2.4E+00	ND	ND
all alpha-radioactivity	ND	ND	ND
all beta-radioactivity	1.5E+01	ND	ND

* 0.0E+0 means 0.0 x 10+0

* Analysis result of I-131 , Cs-134 and Cs-137 was released on Sep. 13.

(Evaluation)

H-3 and all beta-radioactivity were detected, which is considered to be caused by the accident of this time.