

Result of Pu Analysis of the air at Fukushima Daiichi Nuclear Power Station

1. Place of Sampling: West Gate of Fukushima Daiichi Nuclear Power Station
2. Organization: Japan Chemical Analysis Center
3. Result of Analysis :

( Unit: mBq/m<sup>3</sup> )

Detected Nuclides	Date of Sampling	Pu-238	Pu-239,Pu-240
Volatile	9/26	N.D. [ $<5.4 \times 10^{-1}$ ]	N.D. [ $<5.5 \times 10^{-1}$ ]
Particle		N.D. [ $<5.7 \times 10^{-1}$ ]	N.D. [ $<5.6 \times 10^{-1}$ ]

Detection limits are shown in [    ].

4. Evaluation:

No Pu-238,Pu-239,Pu-240 was detected in the samples this time.

End