

Nuclide Analysis Result of Seawater <Offshore of Ibaraki Prefecture>

Reference

(Data summarized on October 22)

Place of Sampling	3 km offshore of Takadokobama shore Upper Layer	3 km offshore of Takadokobama shore Lower Layer	3 km offshore of Kujihama shore Upper Layer	3 km offshore of Kujihama shore Lower Layer	3 km offshore of Oarai shore Upper Layer	3 km offshore of Oarai shore Lower Layer	Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)				
Time of Sampling	Oct 18, 2011 07:48 am	Oct 18, 2011 07:45 am	Oct 19, 2011 07:24 am	Oct 19, 2011 07:21 am	Oct 19, 2011 01:25 pm	Oct 19, 2011 01:23 pm					
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)		Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore of Hirai shore Upper Layer	3 km offshore of Hirai shore Lower Layer	3 km offshore of Hasaki shore Upper Layer	3 km offshore of Hasaki shore Lower Layer			Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 2 of the appendix 2)				
Time of Sampling	Oct 18, 2011 02:03 pm	Oct 18, 2011 02:01 pm	Oct 18, 2011 08:02 am	Oct 18, 2011 08:00 am	/	/					
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)		Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4Bq/L, Cs-134: approx. 6Bq/L, Cs-137: approx. 9Bq/L