

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

(Data summarized on November 1)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	2011/10/31 9:55	2011/10/31 9:57	2011/10/31 10:00	2011/10/31 9:50	2011/10/31 9:45	2011/10/31 9:40	2011/10/31 9:20
Detected Nuclides (Half-life)	Density of sample (Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	6.7E-01	1.0E+00	3.8E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	8.9E-01	1.4E+00	2.4E-02	ND	ND	ND	ND

\* 0.0E-0 means 0.0 x 10-0

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit. I-131: approx. 2E-2Bq/cm<sup>3</sup>, Cs-134: approx. 2E-2Bq/cm<sup>3</sup>, Cs-137: approx. 3E-2Bq/cm<sup>3</sup>)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.