

Pu analysis result at sub-drains of Fukushima Daiichi Nuclear Power Plant

1. Sampling points : Fukushima Daiichi Nuclear Power Plant Unit 2 sub-drains
Unit 5 sub-drains
Deep well
2. Analysis Institute: Japan Chemical Analysis Center
3. Results :

(mBq/L)

Point	Date	Pu-238	Pu-239,Pu-240
Unit 2 sub-drains	10/10	N.D. [$<4.9 \times 10^{-1}$]	N.D. [$<4.5 \times 10^{-1}$]
Unit 5 sub-drains		N.D. [$<4.9 \times 10^{-1}$]	N.D. [$<5.2 \times 10^{-1}$]
Deep well		N.D. [$<5.3 \times 10^{-1}$]	N.D. [$<4.8 \times 10^{-1}$]

[]:measurable limit

4. Evaluation:

No Pu-238,Pu-239,Pu-240 were detected.

END