

Result of nuclide analysis of sub drain etc.

Attachment 2

(Data collected : Nov. 4)

Place of Sampling	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS deep well
Date of Sampling	2011/10/10	2011/10/10	2011/10/10
Detected Nuclides (Half-life)	Density of sample (Bq/cm ³)		
I-131 (about 8 days)	ND	ND	ND
Cs-134 (about 2 years)	7.6E-01	ND	ND
Cs-137 (about 30 years)	1.0E+00	ND	ND
Sr-89 (about 51 days)	1.2E-01	ND	ND
Sr-90 (about 29 years)	2.2E-01	ND	ND

* O.OE - O means O.O x 10-O

I-131, Cs-134, Cs-137 are announced on October 11.

2. Analysis Institute: Japan Chemical Analysis Center (Sr-89, Sr-90),
Tokyo Electric Power Company (I-131, Cs-134, Cs-137)

(Evaluation)

Sr-89, Sr-90 has been detected and the cause is assumed to be the nuclear accident.