

Pu analysis result in the air at Fukushima Daiichi Nuclear Power Plant

1. Sampling points : Fukushima Daiichi Nuclear Power Plant West gate
2. Analysis Institute: Japan Chemical Analysis Center
3. Results :

(Unit: mBq/m³)

Sampling type	Date	Pu-238	Pu-239,Pu-240
Volatile	10/10	N.D. [$<6.6 \times 10^{-1}$]	N.D. [$<7.2 \times 10^{-1}$]
Particle		N.D. [$<8.7 \times 10^{-1}$]	N.D. [$<9.2 \times 10^{-1}$]

[]:measurable limit

4. Evaluation:

No Pu-238,Pu-239,Pu-240 were detected.

END