

Detection of Sr in the soil in Fukushima Daiichi Nuclear Power Station

1. Result of Analysis

(Unit: Bq/kg · Dry soil)

Place of Sampling Distance from 1, Unit 2 stack	Date of sampling Organization	Sr-89	Sr-90
Ground (West-northwest approx. 500m)	October 10 Japan Chemical Analysis Center	$(1.8 \pm 0.05) \times 10^2$	$(2.5 \pm 0.04) \times 10^2$
Wild birds' forest (West approx. 500m)		N.D.	N.D.
Near the industrial waste disposal facility (South-southwest approx. 500m)		$(2.0 \pm 0.07) \times 10^2$	$(3.2 \pm 0.05) \times 10^2$
Range of previous measurement*		-	ND ~ 4.3

* Report on Radioactive Material Measurement Analysis at around Nuclear Power Stations (1999 - 2008), 2009

* Avoiding duplicates, we collected samples from adjacent area for (1) Playground and (3) Adjacent to industrial waste disposal facility.

We collected samples depth direction at same point for (2) Forest of wild birds. (In case we unable to collect samples at the same point, we will collect from new point.)

2. Evaluation

Detected density of Sr-90 is the higher level than that of the measured fallouts in Japan in the cases of previous nuclear tests in the atmosphere, which indicates this is considered to be caused by the nuclear accident of this time.

End