

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater at Fukushima Daiichi Nuclear Power Plant intake of unit 5 and 6.

(Data summarized on November 20)

Place of Sampling	Intake of Fukushima Daiichi Nuclear Power Plant Unit 6						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	2011/11/19 15:10						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-					40
Cs-134 (about 2 years)	ND	-					60
Cs-137 (about 30 years)	ND	-					90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 2Bq/L, Cs-134: approx. 5Bq/L, Cs-137: approx. 6Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.