

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

| |
|-----------|
| Reference |
|-----------|

(Data summarized on November 22)

| Place of Sampling | Fukushima Daiichi NPS 1U sub-drain | Fukushima Daiichi NPS 2U sub-drain | Fukushima Daiichi NPS 3U sub-drain | Fukushima Daiichi NPS 4U sub-drain | Fukushima Daiichi NPS 5U sub-drain | Fukushima Daiichi NPS 6U sub-drain | Fukushima Daiichi NPS Deep well |
|----------------------------------|---|------------------------------------|------------------------------------|------------------------------------|------------------------------------|------------------------------------|---------------------------------|
| Time of Sampling | November 21, 2011 9:55 AM | November 21, 2011 9:59 AM | November 21, 2011 10:04 AM | November 21, 2011 9:43 AM | November 21, 2011 9:49 AM | November 21, 2011 9:43 AM | November 21, 2011 9:20 AM |
| Detected Nuclides (Half-life) | Density of sample (Bq/cm ³) | | | | | | |
| I-131 (about 8 days) | ND | ND | ND | ND | ND | ND | ND |
| Cs-134 (about 2 years) | 1.3E+00 | 9.1E-01 | ND | ND | ND | ND | ND |
| Cs-137 (about 30 years) | 1.7E+00 | 1.3E+00 | ND | ND | ND | ND | ND |

* 0.0E-0 means 0.0 x 10-0

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 3E-2Bq/cm³, Cs-134: approx. 3E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.