Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on November 23)

Place of Sampling	North of Discha of 5-6u (approx. 30m n discharge o	of 1F orth of 5-6u	Around South Channel (appox. 330m Discharge (of 1F south of 1-4u	Around North Channel (Around 3,4u Chanr (approx. 10 kr	of 2F I Discharge nel)	Around Iwasawa (appox. 7 km s Discharge ((appox. 16 kr	south of 1,2u Channel)	Density limit by the announcement of Reactor Regulation (Bq/L)	
Time of Sampling	Nov 22, 08:45		Nov 22, 08:20		Nov 22, 08:25		Nov 22, 07:55		(the density limit in the water outside of	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40	
Cs-134 (about 2 years)	3.4	0.06	1.4	0.02	ND	-	1.0	0.02	60	
Cs-137 (about 30 years)	4.8	0.05	1.5	0.02	ND	-	1.5	0.02	90	

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 0.71Bq/L, Cs-134: approx. 0.88Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on November 23)

Place of Sampling	15 km offshore of Minami-Souma CityUpper layer		Minami-Souma		15 km offshore of Ukedo-gawa Upper layer		15 km offshore of Ukedo-gawa Lower layer		15 km offshore of Fukushima Daiichi Upper layer		15 km offshore of Fukushima Daiichi Lower layer		Density limit by the announcement of Reactor Regulation
Time of Sampling	N/A		N/A		Nov 21, 2011 (Not sampled)		Nov 21, 2011 (Not sampled)		Nov 21, 2011 (Not sampled)		Nov 21, 2011 (Not sampled)		(Bq/L) (the density limit in the water outside of
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

Place of Sampling	Fukushima Da	n offshore of na Daini Upper layer 15 km offshore of Fukushima Daini Lower layer		15 km offshore of Iwasawa Shore Upper layer		15 km offshore of Iwasawa Shore Lower layer		15 km offshore of Hirono-town Upper layer		15 km offshore of Hirono-town Lower layer		Density limit by the announcement of Reactor Regulation	
Time of Sampling	Nov 21, 2 (Not samp		Nov 21, 2011 (Not sampled)		N/A		N/A		N/A		N/A		(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

Results of Nuclide Analysis of Seawater <Offshore 2/2>

Reference

(Data summarized on November 23)

Place of Sampling		n offshore of North Iwaki Upper layer of Iwaki Lower layer		3 km offshore of Natsui river Upper layer		3 km offshore of Natsui river Lower layer		3 km offshore of Onahama port Upper layer		3 km offshore of Onahama port Lower layer		Density limit by the announcement of Reactor Regulation	
Time of Sampling		Nov 21, 2011 07:25 am		Nov 21, 2011 07:25 am		Nov 21, 2011 07:00 am		Nov 21, 2011 07:00 am		Nov 21, 2011 06:15 am		011 m	(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore Upper la				3 km ottshore ot Numanouchi Upper laver		3 km offshore of Numanouchi Lower laver		3 km offshore of Toyoma Upper layer		3 km offshore of Toyoma Lower layer		Density limit by the announcement of Reactor Regulation
Time of Sampling	Nov 21, 2011 06:35 am		Nov 21, 2011 06:35 am		Nov 21, 2011 06:40 am		Nov 21, 2011 06:40 am		Nov 21, 2011 06:25 am		Nov 21, 2011 06:25 am		(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
l-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 0.75Bq/L, Cs-134: approx. 0.98Bq/L, Cs-137: approx. 1.1Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.