

(Attachment)

The result of Pu analysis in the air at Fukushima Daiichi Nuclear Power Station

1. Place of Sampling : West Gate of Fukushima Daiichi Nuclear Power Station
2. Analysis Agency : Japan Chemical Analysis Center
3. Result of Analysis :

(Unit : mBq/m³)

Type of Sample	Date of Sampling	Pu-238	Pu-239, Pu-240
Volatile	Nov 7	N.D. [$<6.3 \times 10^{-1}$]	N.D. [$<5.7 \times 10^{-1}$]
Particulate		N.D. [$<5.9 \times 10^{-1}$]	N.D. [$<5.9 \times 10^{-1}$]

Number shown in [] were the detection limit

4. Evaluation:

No Pu-238, Pu-239 and Pu-240 were detected from the sample analyzed this time.

End