

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

| |
|-----------|
| Reference |
|-----------|

(Data summarized on November 24)

| Place of Sampling | Fukushima Daiichi NPS 1U sub-drain | Fukushima Daiichi NPS 2U sub-drain | Fukushima Daiichi NPS 3U sub-drain | Fukushima Daiichi NPS 4U sub-drain | Fukushima Daiichi NPS 5U sub-drain | Fukushima Daiichi NPS 6U sub-drain | Fukushima Daiichi NPS Deep well |
|----------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|------------------------------------|
| Time of Sampling | 2011/11/23 9:50 | 2011/11/23 9:55 | 2011/11/23 10:00 | 2011/11/23 9:55 | 2011/11/23 9:35 | 2011/11/23 9:25 | 2011/11/23 9:15 |
| Detected Nuclides (Half-life) | Density of sample (Bq/cm3) | | | | | | |
| I-131 (about 8 days) | ND | ND | ND | ND | ND | ND | ND |
| Cs-134 (about 2 years) | 9.2E-01 | 7.1E-01 | ND | ND | ND | ND | ND |
| Cs-137 (about 30 years) | 1.3E+00 | 9.3E-01 | ND | ND | ND | ND | ND |

* O.OE - O means $O.O \times 10^{-O}$

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit.

I-131: approx. $2E-2Bq/cm^3$, Cs-134: approx. $2E-2Bq/cm^3$, Cs-137: approx. $3E-2Bq/cm^3$)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.