

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

Data summarized on November 26)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	2011/11/25 10:20 AM	2011/11/25 10:25 AM	2011/11/25 10:30 AM	2011/11/25 10:07 AM	2011/11/25 10:10 AM	2011/11/25 10:00 AM	2011/11/25 9:10 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm ³)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	7.2E-01	6.6E-01	2.8E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	1.0E+00	8.6E-01	3.1E-02	ND	ND	ND	ND

* O.OE - O means O.O x 10-O

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 2E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 3E-2Bq/cm³)

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.