

Major revision

○Update

- The residual heat removal system (RHR) (A) of Unit 1 was repaired and all of the Units were therefore multiplexed. (Summary, 5 page in the revised report, etc.)
- Countermeasures for Tunami such as expansion of the embankments were implemented. (Summary, 3 page in the revised report, etc.)
- The emergency equipment cooling water pump electric motor (B) was installed. (Refer the revised report, 3-3 page in the attached, etc.)

○Revision such as transition of parameters

- Transcription error of Temperatures of reactor water, sampling results of reactor water and spent fuel water.
  - \* No effect on the evaluation for the report.
- Additional request during the on-site inspection
  - (1) Graphs and description of temperatures' of spent fuel water and reactor water level.
  - (2) Layout sketch of the clean up water system
  - (3) Layout sketch of the fuel pool cooling and filtering (clean up) system

○Revision of the expressions

END