

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater inside Water Intake Canal of Units 5 & 6 at Fukushima Daiichi

(Data summarized on December 3)

Place of Sampling	Seawater inside Water Intake Canal of Units 5 & 6 at Fukushima Daiichi						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	2011/12/2 3:25 PM						
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-					40
Cs-134 (about 2 years)	7.5	0.13					60
Cs-137 (about 30 years)	10	0.11					90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 3Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.